

# DAKSHIN HARYANA BIJLI VITRAN NIGAM LIMITED

SCHEME FOR  
HOUSEHOLD ELECTRIFICATION  
DISTRICT : Rewari (HARYANA)  
(AS PER SUPPLEMENTRY DPR)

DEEN DAYAL UPADHYAYA GRAM JYOTI YOJANA

## Table of Contents

Sl.No.	Format No.	Name	Page No.
1	<b>A</b>	<b>General Information</b>	1
2	A(I)	Brief Writeup	2
3	A(II)	Minutes	2
4	A(III)	Pert Chart	2
5	A(IV)	Certificate	2
6	A(V)	Basic Details of District	2
7	A(VI)	Abstract : Scope of Work & Estimated Cost	4
8	A(VII)	Financial Bankability	10
9	<b>B</b>	<b>Electrification of UE villages</b>	12
10	B(I)	Block-wise coverage of villages	13
11	B(II)	Villagewise/Habitation wise coverage	14
12	B(III)	Existing Habitation Wise Infrastructure	14
13	B(IV)	Village Wise/Habitation Proposed Works	14
14	B(V)	Existing REDB Infrastructure	14
15	B(VI)	Block-Wise Substation	16
16	B(VII)	Feederwise DTs	17
17	<b>C</b>	<b>Feeder Segregation</b>	27
18	<b>D</b>	<b>Connecting unconnected RHHs</b>	28
19	D(I)	Block-wise coverage of villages	29
20	D(II)	Villagewise/Habitation wise coverage	30
21	D(III)	Existing Habitation Wise Infrastructure	30
22	D(IV)	Village Wise/Habitation Proposed Works	30
23	D(V)	Existing REDB Infrastructure	30
24	D(VI)	Block-Wise Substation	32
25	D(VII)	Feederwise DTs	33
26	<b>E</b>	<b>Metering</b>	43
27	E(I)	DTR Metering	44
28	E(II)	Consumer Metering	133
29	E(III)	Shifting of Meters	135
30	E(IV)	Feeder Metering	136
31	<b>F</b>	<b>System Strengthening and Augmentation</b>	137
32	F(I)	Block-Wise Substation	138
33	F(II)	EHV Substation Feeding the District	139
34	F(III)	Districtwise Details of Existing 66 KV or 33 KV Lines	145
35	F(IV)	Districtwise Details of Existing 11 KV or 22 KV Lines	147

36	F(V)	Augmentation of 11 KV or 22 KV Line	156
37	<b>G</b>	<b>SAGY</b>	160
38	G(I)	Block-wise coverage of villages	161
39	G(II)	Villagewise/Habitation wise coverage	162
40	G(III)	Existing Habitation Wise Infrastructure	163
41	G(IV)	Village Wise/Habitation Proposed Works	164
42	G(V)	Details of New 11 KV or 22 KV Lines	166

**Section -A**  
**Basic Details of District**

State : HARYANA

District : Rewari

## Basic Details of District for Supplementary DPR

**State** : HARYANA  
**District** : Rewari

Name of Project Implementing Agency	Dakshin Haryana Bijli Vitran Nigam Limited
Name of DISCOM	Dakshin Haryana Bijli Vitran Nigam Limited
Name of State	HARYANA
Name of District	Rewari
Total Population of district	900332
Total Geographical Area(SqKm)	1181
Percentage of Hilly area	0.5
Total Block in the district	5
Total Urban Town in the district	1
Total Urban Population in the district	233430
Population Of Urban Area	233430
Total Census Revenue Villages in the district	409
Total Habitations in the district	0
Total Rural Population in the district	666902

### House Holds Details :-

Description	2001 Census	2011 Census	CAGR	Total HHs by 31.03.2015 as derived	Total HHs by 31.03.2019 as derived
Total House Holds in the district	135560	178043	0.09	201139	229155
Rural HH in the district	110852	130299	0.02	139002	148286
Urban HH in the district	24708	47744	0.07	62137	80869
Total Energised HH in the district	126823	175921	0.03	200524	228567
Urban HH electrified in the district	24655	47663	0.07	62043	80761
Rural HH electrified in the district	102168	128258	0.01	140473	153851
Balance Un-electrified Rural HH	8684	2041	0.01	-1471	-5565

## Basic Details of District for Supplementary DPR

**State** : HARYANA  
**District** : Rewari

Balance Un-electrified Urban HH	53	81	0	94	108					
Balance Total un-electrified HH in the district	0	0	0	0	0					
<b>Status of Already Sanctioned 10th / 11th / 12th Plan Projects :-</b>										
Plan	Un-Electrified Villages		Intensive Electrified Villages		Total Habitation		RHH Incl. BPL		BPL	
	Coverage	Achievement	Coverage	Achievement	Coverage	Achievement	Coverage	Achievement	Coverage	Achievement
<b>10th</b>	0	0	0	0	0	0	0	0	0	0
<b>11th</b>	0	0	0	0	0	0	0	0	16684	16684
<b>12th</b>	0	0	0	0	0	0	0	0	0	0

## Abstract : Scope of Work & Estimated Cost for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
<b>C.Sansad Adarsh Gram Yozna</b>						
<b>Capacity Augmentation of DTR</b>						
1	Bawal	From Existing to 63 KVA	Nos.	3	1.3917	4.1751
<b>Sub-Total (Capacity Augmentation of DTR)</b>				<b>3</b>		<b>4.1751</b>
<b>Conversion of existing LT Overhead lines to ABC Cable</b>						
2	Bawal	3X95+1X70	Kms.	0.5	5.3706	2.6853
<b>Sub-Total (Conversion of existing LT Overhead lines to ABC Cable)</b>				<b>0.5</b>		<b>2.6853</b>
<b>New 11 KV Line</b>						
3	BOLNI FEEDER DS(JC IV To BOLNI VILLAGE)	PCC POLES WITH RABBIT CONDUCTOR	Kms.	21	4.2398	89.0358
<b>Sub-Total (New 11 KV Line)</b>				<b>21</b>		<b>89.0358</b>
<b>New 11 KV Line DTR</b>						
4	Bawal	25 KVA (3 Ph)	Nos.	8	1.2065	9.652
		63 KVA (3 Ph)	Nos.	2	1.8003	3.6006
<b>Sub-Total (New 11 KV Line DTR)</b>				<b>10</b>		<b>13.2526</b>
<b>New 11 KV Spur Line</b>						
5	Bawal	11 KV Raccon Conductor	Kms.	2.5	4.9245	12.31125
<b>Sub-Total (New 11 KV Spur Line)</b>				<b>2.5</b>		<b>12.31125</b>
<b>New LT AB Cable</b>						
6	Bawal	3X95+1X70	Kms.	0.12	5.3706	0.64447
<b>Sub-Total (New LT AB Cable)</b>				<b>0.12</b>		<b>0.64447</b>
<b>New LT Overhead Line</b>						
7	Bawal	Raccoon (75sqmm) 3Ph-N (4W)	Kms.	1	4.038	4.038

## Abstract : Scope of Work & Estimated Cost for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
<b>Sub-Total (New LT Overhead Line)</b>				<b>1</b>		<b>4.038</b>
	<b>Reconductoring of existing LT Overhead line</b>					
8	Bawal	Raccoon (75sqmm) 3Ph-N (4W)	Kms.	5.2	4.038	20.9976
<b>Sub-Total (Reconductoring of existing LT Overhead line)</b>				<b>5.2</b>		<b>20.9976</b>
<b>Total (C.Sansad Adarsh Gram Yozna)</b>						<b>147.14012</b>
	<b>E.Metering</b>					
	<b>LT Metering(Shifting of Meter)</b>					
1	Bawal	Total Requirement of shifting of meters outside(1-Ph Domestic and Commercial Meters)	Nos.	1000	0.0064	6.4
		Total Requirement of shifting of meters outside(3-Ph Domestic and Commercial Meters)	Nos.	195	0.0143	2.7885
2	Jatusana	Total Requirement of shifting of meters outside(1-Ph Domestic and Commercial Meters)	Nos.	1000	0.0064	6.4
		Total Requirement of shifting of meters outside(3-Ph Domestic and Commercial Meters)	Nos.	15	0.0143	0.2145
3	Khol At Rewari	Total Requirement of shifting of meters outside(1-Ph Domestic and Commercial Meters)	Nos.	1000	0.0064	6.4
		Total Requirement of shifting of meters outside(3-Ph Domestic and Commercial Meters)	Nos.	26	0.0143	0.3718
4	Nahar (P)	Total Requirement of shifting of meters outside(1-Ph Domestic and Commercial Meters)	Nos.	1300	0.0064	8.32
		Total Requirement of shifting of meters outside(3-Ph Domestic and Commercial Meters)	Nos.	75	0.0143	1.0725
5	Rewari	Total Requirement of shifting of meters outside(1-Ph Domestic and Commercial Meters)	Nos.	2000	0.0064	12.8
		Total Requirement of shifting of meters outside(3-Ph Domestic and Commercial Meters)	Nos.	227	0.0143	3.2461
<b>Sub-Total (LT Metering(Shifting of Meter))</b>				<b>6838</b>		<b>48.0134</b>



## Abstract : Scope of Work & Estimated Cost for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
<b>Total (E.Metering)</b>						<b>48.0134</b>
<b>F.System Strengthening</b>						
<b>11 KV or 22 KV Line Augmentation</b>						
1	132 KV Buroli-11 KV Aulant AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	10	0.0252	0.252
2	132 KV Buroli-11 KV Aulant AP(WATER SUPPLY T OFF To 63 KVA GHISA RAM)	Raccon-80 sqmm.	Kms.	4.5	4.038	18.171
3	132 KV Kosli-Gudiyani DS	Control Points	Nos.	2	0.072	0.144
		Poles	Nos.	55	0.0252	1.386
4	132 KV Kosli-Gudiyani DS(132 KV KOSLI To NATHERA)	Raccon-80 sqmm.	Kms.	2	4.038	8.076
5	132 KV Kosli-Gudiyani DS(NATHERA To KANHARWAS)	Raccon-80 sqmm.	Kms.	6	4.038	24.228
6	132 KV Kosli-Jhall DS	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	7	0.0252	0.1764
7	132 KV Kosli-Jhall DS(132 KV KOSLI To DHANI SUDHRANA)	Raccon-80 sqmm.	Kms.	2	4.038	8.076
8	132 KV Kosli-Kosli DS	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	40	0.0252	1.008
9	132 KV Kosli-Kosli DS(132 kv kosli To village chawwa)	Raccon-80 sqmm.	Kms.	5	4.038	20.19
10	132 KV Old Bawal-Pawati AP	Control Points	Nos.	3	0.072	0.216
		Poles	Nos.	58	0.0252	1.4616
11	132 KV Old Bawal-Pawati AP(BANDH WALA To UJJAR KHERI)	Raccon-80 sqmm.	Kms.	4.5	4.038	18.171

## Abstract : Scope of Work & Estimated Cost for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
12	132 KV Old Bawal-Pawati AP(KHERI DALU SINGH To CKT SW BANDH WALA)	Raccon-80 sqmm.	Kms.	18	4.038	72.684
13	132 KV Old Bawal-Pawati AP(S STN To GAS GODAM CKT)	Raccon-80 sqmm.	Kms.	6	4.038	24.228
14	132 KV Old Bawal-Tankari AP	Control Points	Nos.	3	0.072	0.216
		Poles	Nos.	43	0.0252	1.0836
15	132 KV Old Bawal-Tankari AP(BHARANGI To BALAWAS)	Raccon-80 sqmm.	Kms.	6.6	4.038	26.6508
16	132 KV Old Bawal-Tankari AP(SUB STN To MAJRA VILL)	Raccon-80 sqmm.	Kms.	12	4.038	48.456
17	132 KV Old Bawal-Tankari AP(VILL MAJRA To VILL BHARANGI)	Raccon-80 sqmm.	Kms.	15	4.038	60.57
18	33 KV Bharawas-Balawas Jat AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	6	0.0252	0.1512
19	33 KV Bharawas-Balawas Jat AP(SULKHA To GOBINPUR BASS)	Raccon-80 sqmm.	Kms.	3.7	4.038	14.9406
20	33 KV Bharawas-Jatuwas AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	12	0.0252	0.3024
21	33 KV Bharawas-Jatuwas AP(BITHWANA CKT To TF 5 SUNDER LAL)	Raccon-80 sqmm.	Kms.	2.6	4.038	10.4988
22	33 KV Bharawas-Kanuka AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	8	0.0252	0.2016
23	33 KV Bharawas-Kanuka AP(PRAGPURA To ARAM NAGAR)	Raccon-80 sqmm.	Kms.	11.5	4.038	46.437
24	33 KV Bharawas-Rajgarh AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	7	0.0252	0.1764
25	33 KV Bharawas-Rajgarh AP(DHARAN SW To RAJGARH DHANI)	Raccon-80 sqmm.	Kms.	6	4.038	24.228

## Abstract : Scope of Work & Estimated Cost for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
26	33 KV Khol-11 KV Nangal Jamalpur AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	5	0.0252	0.126
27	33 KV Khol-11 KV Nangal Jamalpur AP(T OFF SURAJ BHAN To 63 KVA ROHTASH)	Raccon-80 sqmm.	Kms.	6.1	4.038	24.6318
28	33 KV Khushpura-11 KV Baldhan AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	30	0.0252	0.756
29	33 KV Khushpura-11 KV Baldhan AP(KHUSHPURA To BALDHAN)	Raccon-80 sqmm.	Kms.	9	4.038	36.342
30	33 KV Khushpura-11 KV Daroli AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	15	0.0252	0.378
31	33 KV Khushpura-11 KV Daroli AP(KHUSHPURA To DAROLI)	Raccon-80 sqmm.	Kms.	6	4.038	24.228
32	33 KV Khushpura-11 KV Khuspura AP	Poles	Nos.	10	0.0252	0.252
33	33 KV Khushpura-11 KV Khuspura AP(SUBSTN To KHUSHPURA VILL)	Raccon-80 sqmm.	Kms.	1	4.038	4.038
34	66 KV Dharuhera-Akera AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	13	0.0252	0.3276
35	66 KV Dharuhera-Akera AP(Akera To Ashok Vihar)	Raccon-80 sqmm.	Kms.	4.5	4.038	18.171
36	66 KV Dharuhera-Bhatsana AP	Poles	Nos.	18	0.0252	0.4536
37	66 KV Dharuhera-Bhatsana AP(Jhil Ckt. To Bhatsana ckt.)	Raccon-80 sqmm.	Kms.	9	4.038	36.342
38	66 KV Dharuhera-Khatwali AP	Poles	Nos.	18	0.0252	0.4536
39	66 KV Dharuhera-Khatwali AP(Kutabi Ckt. To Mau)	Raccon-80 sqmm.	Kms.	4.5	4.038	18.171
40	66 KV Dharuhera-Pipaki AP	Control Points	Nos.	1	0.072	0.072
		Poles	Nos.	18	0.0252	0.4536

## Abstract : Scope of Work & Estimated Cost for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Item of Works	Sub Item	Unit	Quantity	Unit Cost(In Lac)	Total Cost(In Lac)
41	66 KV Dharuhera-Pipaki AP(S STN To NRP BASS)	Raccon-80 sqmm.	Kms.	21	4.038	84.798
<b>Sub-Total (11 KV or 22 KV Line Augmentation)</b>				<b>559.5</b>		<b>683.1666</b>
<b>Conversion of existing LT Overhead lines to ABC Cable</b>						
42	Bawal	3X95+1X70	Kms.	20.55	5.3706	110.36583
43	Jatusana	3X95+1X70	Kms.	24.52	5.3706	131.68711
44	Khol At Rewari	3X95+1X70	Kms.	35	5.3706	187.971
45	Nahar (P)	3X95+1X70	Kms.	24.63	5.3706	132.27788
46	Rewari	3X95+1X70	Kms.	20.6	5.3706	110.63436
<b>Sub-Total (Conversion of existing LT Overhead lines to ABC Cable)</b>				<b>125.3</b>		<b>672.93618</b>
<b>Total (F.System Strengthening)</b>						<b>1356.10278</b>
<b>Grand Total (Total DPR Cost)</b>						<b>1551.2563</b>

## Financial Bankability for Supplementary DPR

State : HARYANA  
District : Rewari

\*All Amount in Lacs

Total Cost of the Project		Rs.	<b>1551.2563</b>
<b>Benefits of the Scheme</b>			
a. Value of benefit due to sale of additional energy		Rs.	<b>0</b>
b. Value of benefit due to saving in technical loss		Rs.	<b>0</b>
c. Value of benefit due to saving in commercial loss		Rs.	<b>0</b>
<b>Total financial Benefit</b>		Rs.	<b>0</b>
<b>IRR of The Project</b>			<b>0</b>
Year	Outflow		Inflow
1	50% of Project Cost	692.52513	
2	50% of Project Cost	618.32601	
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			

## Financial Bankability for Supplementary DPR

State : HARYANA  
 District : Rewari

15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
<b>Total</b>	<b>1310.85114</b>		<b>0</b>

# **Electrification of UE villages**

State : HARYANA

District : Rewari

## Block-wise coverage of villages for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
1	Bawal	0	0	0	0	0	0	0	0	0	0
2	Jatusana	0	0	0	0	0	0	0	0	0	0
3	Khol At Rewari	0	0	0	0	0	0	0	0	0	0
4	Nahar (P)	0	0	0	0	0	0	0	0	0	0
5	Rewari	0	0	0	0	0	0	0	0	0	0
<b>Total</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>



## Existing REDB Infrastructure for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
1	Bawal	132 KV Old Bawal	132/11 KV	1x16+1x16+0+0+0	32	1	28 8 43.63N 76 33 50.91E		20	LILO	20
2	Jatusana	33 KV Berli Khurd	33/11 KV	1x10+0+0+0+0	10	4	28 17 25.56N 76 30 56.10E	220 KV Lula Ahir	7.5	Radial	4
		33 KV Khushpura	33/11 KV	1x8+1x10+0+0+0	18	1	28 20 6.61N 76 27 16.43E	220 KV Lula Ahir	2.5	Radial	8
		33 KV Nangal Pathani	33/11 KV	1x10+0+0+0+0	10	4	28 21 10.09N 76 30 25.62E	220 KV Lula Ahir	4.5	Radial	5
		33 KV Palhawas	33/11 KV	1x10+1x5+0+0+0	15	1	28 35 28.73N 76 62 48.43E	132 KV Gangaicha Jant	8.5	Radial	10
		33 KV Gurawara	33/11 KV	1x10+0+0+0+0	10	1	28 23 48.54N 76 38 9.30E	132 KV Gangaicha Jant	12.8	Radial	3
		33 KV JC-II Jatusana	33/11 KV	1x5+1x8+0+0+0	13	1	28 18 37.55N 76 33 4.75E	220 KV S/Stn., Rewari	16	Radial	8
		132 KV Dahina	132/11 KV	1x16+1x16+0+0+0	32	1	28 11 44.44N 76 24 16.04		22	LILO	8
3	Khol At Rewari	33 KV Khol	33/11 KV	1x10+1x5+0+0+0	15	1	28 11 44.44N 76 24 16.02E	132 KV Buroli	8	Radial	7
		33 KV Ahrod	33/11 KV	1x10+0+0+0+0	10	1	28 11 1.12N 76 22 30.25E	132 KV Buroli	12	Radial	4
		132 KV Buroli	132/11 KV	1x16+1x16+0+0+0	32	1	28 14 48.80N 76 26 51.47E	220 KV S/Stn., Rewari	15	LILO	16
		132 KV GOTHRA	132/11 KV	1x16+1x16+0+0+0	32	1	28 19 33.80N 76 23 38.81E	220 KV S/Stn., Rewari	18	LILO	18
4	Nahar (P)	33 KV Jharoda	33/11 KV	1x10+1x10+0+0+0	20	1	28 21 31.23N 76 24 7.16E	220 KV Lula Ahir	5	Radial	8
		33 KV Behrampur	33/11 KV	1x10+0+0+0+0	10	1	28 23 42.83N 76 38 48.16E	132 KV Kosli	13	Radial	3
		33 KV Juddi (MC-I)	33/11 KV	1x5+0+0+0+0	5	1	28 25 44.79N 76 25 6.71E	132 KV Kosli	11	Radial	1

## Existing REDB Infrastructure for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
		33 KV MC-II Bishowa	33/11 KV	1x5+0+0+0+0	5	1	28 23 32.64N 76 20 18 94E	132 KV Kosli	9	Radial	1
		33 KV Bishowa	33/11 KV	1x5+1x10+0+0+0	15	1	28 24 41.35N 76 20 28.37E	220 KV Lula Ahir	13.4	Radial	8
		33 KV JC-I Gudiyani	33/11 KV	1x6.3+1x3.15+0+0+0	9.45	1	28 21 33.08N 76 30 49.40E	132 KV Kosli	10	Radial	4
		132 KV Kosli	132/11 KV	1x20+0+0+0+0	20	1	28 20 6.58N 76 27 16.43E	220 KV Lula Ahir	6	LILO	8
5	Rewari	33 KV Kaluwas	33/11 KV	1x10+0+0+0+0	10	1	28 13 18.88N 76 35 28.08E	220 KV S/Stn., Rewari	2.5	Radial	7
		33 KV Kakoria	33/11 KV	1x10+0+0+0+0	10	4	28 15 12.52N 76 38 43.28E	132 KV Gangaicha Jant	4.5	Radial	6
		33 KV JC-IV	33/11 KV	1x10+1x10+0+0+0	20	1	28 8 54.71N 76 38 6.98E	220 KV S/Stn., Rewari	9.5	Radial	11
		33 KV Bharawas	33/11 KV	1x6.3+1x10+0+0+0	16.3	1	28 8 43.61N 76 33 50.89E	220 KV S/Stn., Rewari	13	Radial	8
		33 KV Jonawas	33/11 KV	1x6.3+1x10+0+0+0	16.3	1	28 12 35.15N 76 42 25.70E	220 KV S/Stn., Rewari	14	Radial	14
		33 KV Jarthal	33/11 KV	1x10+1x10+0+0+0	20	1	28 8 57.07N 76 43 0.60E	220 KV S/Stn., Mau	17	Radial	9
		220 KV Rewari	220/11 KV	1x16+1x16+0+0+0	32	1	28 11 35.06N 76 38 16.99E		70	LILO	15
		66 KV Dharuhera	66/11 KV	0+1x16+1x16+0+0	32	1	28 12 18.96N 76 47 32.05E		10	LILO	10
		66 KV Baliar Kalan	66/11 KV	1x16+1x16+0+0+0	32	1	28 12 35.12N 76 42 25.70E		10	Radial	3
<b>Total</b>					<b>502.05</b>						

## Block-Wise Substation for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
1	Bawal	1	32	0	0	0	0	0	0	1	32
2	Jatusana	7	108	6	76	0	0	0	0	13	184
3	Khol At Rewari	4	89	2	25	0	0	0	0	6	114
4	Nahar (P)	7	84.45	6	64.45	0	0	0	0	13	148.9
5	Rewari	9	188.6	7	121.3	0	0	0	0	16	309.9

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
1	Bawal	132 KV Old Bawal	Panwar DS	172	7.1	4	0.2	18	0.7	190	7.8
		132 KV Old Bawal	Dhani Ahir DS	202	6.3	3	0.2	10	0.4	212	6.7
		132 KV Old Bawal	MP Basai DS	99	3.2	4	0.2	8	0.4	107	3.6
		132 KV Old Bawal	Raipur DS	94	2.7	5	0.3	6	0.2	100	2.9
		132 KV Old Bawal	Pawati AP	144	6.08	3	0.2	10	0.7	154	6.78
		132 KV Old Bawal	Subaseri AP	127	6.3	3	0.2	13	1	140	7.3
		132 KV Old Bawal	Mangleshwar AP	106	5.7	4	0.2	7	0.5	113	6.2
		132 KV Old Bawal	Ibrahimpur AP	54	3.08	5	0.3	6	0.4	60	3.48
		132 KV Old Bawal	Tankari AP	88	3.8	4	0.2	10	0.7	98	4.5
		132 KV Old Bawal	Dulhera AP	112	5.6	5	0.3	13	1	125	6.6
		132 KV Old Bawal	Bidawas AP	131	6.6	3	0.1	15	1.1	146	7.7
		132 KV Old Bawal	Alawalpur AP	54	3.8	3	0.2	7	0.5	61	4.3
		132 KV Old Bawal	Keshopur DS	151	6.5	5	0.3	25	0.7	176	7.2
		132 KV Old Bawal	NSP Garhi DS	157	6.7	5	0.4	27	0.8	184	7.5
		132 KV Old Bawal	Kasola DS	218	5.3	7	0.5	14	0.6	232	5.9
132 KV Old Bawal	Khandora AP	128	5.6	3	0.2	12	0.9	140	6.5		
2	Jatusana	33 KV Berli Khurd	11 KV Berli AP	75	2.52	0	0	0	0	75	2.52
		33 KV Berli Khurd	11 KV Parkhotampur AP	27	1.23	0	0	0	0	27	1.23
		33 KV Berli Khurd	11 KV Musepur DS	102	3.38	0	0	5	0.5	107	3.88
		33 KV Khushpura	11 KV Baldhan AP	60	2.4	0	0	4	0.4	64	2.8
		33 KV Khushpura	11 KV Babroli AP	15	0.86	0	0	0	0	15	0.86

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Khushpura	11 KV Khushpura AP	45	2.12	0	0	3	0.3	48	2.42
		33 KV Khushpura	11 KV Daroli AP	54	2.4	0	0	5	0.5	59	2.9
		33 KV Khushpura	11 KV Fatepuri DS	54	2.23	0	0	6	0.38	60	2.61
		33 KV Khushpura	11 KV Khushpura DS	92	3.53	0	0	5	0.5	97	4.03
		33 KV Khushpura	11 KV Nangal Pathani DS	161	5.1	0	0	15	1.13	176	6.23
		33 KV Nangal Pathani	11 KV Bohtawas AP	66	2.52	0	0	5	0.32	71	2.84
		33 KV Nangal Pathani	11 KV Nangal Pathani DS	22	1.3	0	0	2	0.2	24	1.5
		33 KV Nangal Pathani	11 KV Murlipur DS	84	2.2	0	0	6	0.6	90	2.8
		33 KV Nangal Pathani	11 KV Bohtawas DS	32	1.06	0	0	2	0.2	34	1.26
		33 KV Palhawas	11 KV Gurawara AP	8	0.31	0	0	2	0.1	10	0.41
		33 KV Palhawas	11 KV Gangaicha AP	151	5.47	0	0	6	0.2	157	5.67
		33 KV Palhawas	11 KV Jiwera AP	6	0.34	0	0	0	0	6	0.34
		33 KV Palhawas	11 KV Choki AP	98	5.24	0	0	4	0.1	102	5.34
		33 KV Palhawas	11 KV Lala AP	86	3.1	0	0	5	0.32	91	3.42
		33 KV Palhawas	11 KV Mastapur DS	131	3.59	0	0	8	0.2	139	3.79
		33 KV Palhawas	11 KV Karawara DS	212	6.19	0	0	10	0.4	222	6.59
		33 KV Palhawas	11 KV Noorgarh DS	53	2.12	0	0	6	0.2	59	2.32
		33 KV Gurawara	11 KV Kanhori AP	95	3.7	0	0	8	0.2	103	3.9
		33 KV Gurawara	11 KV Gurawara AP	45	1.87	0	0	5	0.1	50	1.97
		33 KV Gurawara	11 KV Gurawara DS	83	3.36	0	0	8	0.2	91	3.56
		33 KV JC-II Jatusana	11 KV Jatusana AP	134	4.29	0	0	8	0.5	142	4.79

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV JC-II Jatusana	11 KV Kishangarh AP	66	2.07	0	0	7	0.44	73	2.51
		33 KV JC-II Jatusana	11 KV Berli Kalan AP	36	1.62	0	0	5	0.32	41	1.94
		33 KV JC-II Jatusana	11 KV Murlipur DS	133	4.15	0	0	8	0.4	141	4.55
		132 KV Dahina	11 KV Nimoth AP	107	5.8	0	0	7	0.44	114	6.24
		132 KV Dahina	11 KV Jainabad AP	115	6.5	0	0	7	0.44	122	6.94
		132 KV Dahina	11 KV Kanwali AP	156	7.6	0	0	9	0.56	165	8.16
		132 KV Dahina	11 KV Dahina AP	92	5.1	0	0	3	0.18	95	5.28
		132 KV Dahina	11 KV Mitc -15 AP	33	1.6	0	0	0	0	33	1.6
		132 KV Dahina	11 KV Dhanibad DS	104	3.8	0	0	0	0	104	3.8
		132 KV Dahina	11 KV Gothra DS	142	5.6	0	0	0	0	142	5.6
3	Khol At Rewari	33 KV Khol	11 KV Nangal Jamalpur AP	105	5.4	0	0	5	0.31	110	5.71
		33 KV Khol	11 KV Bohka AP	76	4.08	0	0	5	0.31	81	4.39
		33 KV Khol	11 KV Khol AP	50	3.04	0	0	4	0.25	54	3.29
		33 KV Khol	11 KV Mandola AP	76	3.4	0	0	5	0.31	81	3.71
		33 KV Khol	11 KV Khol DS	28	0.9	0	0	0	0	28	0.9
		33 KV Khol	11 KV Mandola/Bohka DS	107	2.2	0	0	0	0	107	2.2
		33 KV Khol	11 KV Dhani Kolana DS	53	1.3	0	0	0	0	53	1.3
		33 KV Khol	11 KV Nangal Jamalpur AP	105	5.4	0	0	5	0.31	110	5.71
		33 KV Khol	11 KV Bohka AP	76	4.08	0	0	5	0.31	81	4.39
		33 KV Khol	11 KV Khol AP	50	3.04	0	0	4	0.25	54	3.29
		33 KV Khol	11 KV Mandola AP	76	3.4	0	0	5	0.31	81	3.71

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Khol	11 KV Khol DS	28	0.9	0	0	0	0	28	0.9
		33 KV Khol	11 KV Mandola/Bohka DS	107	2.2	0	0	0	0	107	2.2
		33 KV Khol	11 KV Dhani Kolana DS	53	1.3	0	0	0	0	53	1.3
		33 KV Ahrod	11 KV Ahrod DS	222	7.9	2	0.2	6	0.3	228	8.2
		33 KV Ahrod	11 KV Nangle Jamalpur AP	100	4	2	0.2	8	0.5	108	4.5
		33 KV Ahrod	11 KV Uncha AP	51	2.2	2	0.2	7	0.4	58	2.6
		33 KV Ahrod	11 KV Bas Duda AP	98	3.2	2	0.2	8	0.5	106	3.7
		33 KV Ahrod	11 KV Ahrod DS	222	7.9	2	0.2	6	0.3	228	8.2
		33 KV Ahrod	11 KV Nangle Jamalpur AP	100	4	2	0.2	8	0.5	108	4.5
		33 KV Ahrod	11 KV Uncha AP	51	2.2	2	0.2	7	0.4	58	2.6
		33 KV Ahrod	11 KV Bas Duda AP	98	3.2	2	0.2	8	0.5	106	3.7
		132 KV Buroli	11 KV Dhawana AP	93	4.9	0	0	10	0.63	103	5.53
		132 KV Buroli	11 KV Masit AP	132	8.6	0	0	12	0.7	144	9.3
		132 KV Buroli	11 KV Kahari AP	155	8.7	0	0	3	0.18	158	8.88
		132 KV Buroli	11 KV Gumina AP	128	8.1	0	0	5	0.3	133	8.4
		132 KV Buroli	11 KV Khaleta AP	159	8.09	0	0	10	0.63	169	8.72
		132 KV Buroli	11 KV Siha AP	173	8.7	0	0	12	0.7	185	9.4
		132 KV Buroli	11 KV Aulant AP	261	16.1	0	0	10	0.63	271	16.73
		132 KV Buroli	11 KV Mundi DS	183	4.5	0	0	0	0	183	4.5
		132 KV Buroli	11 KV Kumrodha DS	122	3.3	0	0	0	0	122	3.3
		132 KV Buroli	11 KV Delhawas DS	129	3.4	0	0	0	0	129	3.4

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		132 KV Buroli	11 KV Mayan DS	52	1.8	0	0	2	0.05	54	1.85
		132 KV Buroli	11 KV Luhana DS	66	2.1	0	0	0	0	66	2.1
		132 KV Buroli	11 KV Dhawana DS	12	0.6	0	0	0	0	12	0.6
		132 KV Buroli	11 KV Rampuri DS	25	1.4	0	0	0	0	25	1.4
		132 KV Buroli	11 KV Dhawana AP	93	4.9	0	0	10	0.63	103	5.53
		132 KV Buroli	11 KV Masit AP	132	8.6	0	0	12	0.7	144	9.3
		132 KV Buroli	11 KV Kahari AP	155	8.7	0	0	3	0.18	158	8.88
		132 KV Buroli	11 KV Gumina AP	128	8.1	0	0	5	0.3	133	8.4
		132 KV Buroli	11 KV Khaleta AP	159	8.09	0	0	10	0.63	169	8.72
		132 KV Buroli	11 KV Siha AP	173	8.7	0	0	12	0.7	185	9.4
		132 KV Buroli	11 KV Aulant AP	261	16.1	0	0	10	0.63	271	16.73
		132 KV Buroli	11 KV Mundi DS	183	4.5	0	0	0	0	183	4.5
		132 KV Buroli	11 KV Kumrodha DS	122	3.3	0	0	0	0	122	3.3
		132 KV Buroli	11 KV Delhawas DS	129	3.4	0	0	0	0	129	3.4
		132 KV Buroli	11 KV Mayan DS	52	1.8	0	0	2	0.05	54	1.85
		132 KV Buroli	11 KV Luhana DS	66	2.1	0	0	0	0	66	2.1
		132 KV Buroli	11 KV Dhawana DS	12	0.6	0	0	0	0	12	0.6
		132 KV Buroli	11 KV Rampuri DS	25	1.4	0	0	0	0	25	1.4
		132 KV GOTHRA	11 KV Chitadungra AP	109	4.9	2	0.2	6	0.3	115	5.2
		132 KV GOTHRA	11 KV Khoru AP	121	6.4	3	0.03	7	0.4	128	6.8
		132 KV GOTHRA	11 KV Gumina AP-II	127	5.4	2	0.02	5	0.3	132	5.7



## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		132 KV GOTHRA	11 KV Punsika AP	101	4.4	3	0.03	7	0.4	108	4.8
		132 KV GOTHRA	11 Gothra AP	63	3.1	3	0.03	5	0.3	68	3.4
		132 KV GOTHRA	11 KV Balwari AP	54	4.5	2	0.2	8	0.5	62	5
		132 KV GOTHRA	11 KV Kund AP	112	5.4	2	0.2	9	0.5	121	5.9
		132 KV GOTHRA	11 KV Dhani Manethi AP	66	3.1	3	0.03	5	0.3	71	3.4
		132 KV GOTHRA	11 KV Kundal AP	137	5.1	3	0.03	8	0.5	145	5.6
		132 KV GOTHRA	11 KV Bhandor DS	140	5.6	3	0.03	4	0.2	144	5.8
		132 KV GOTHRA	11 KV Pali DS	91	3.2	3	0.03	5	0.3	96	3.5
		132 KV GOTHRA	11 KV Thothwal DS	82	3.8	2	0.2	4	0.2	86	4
		132 KV GOTHRA	11 KV Sundroj DS	128	4.2	2	0.2	5	0.3	133	4.5
		132 KV GOTHRA	11 KV Nandha DS	170	6.2	3	0.03	7	0.4	177	6.6
4	Nahar (P)	33 KV Jharoda	Nahar II AP	150	6	0	0	10	0.63	160	6.63
		33 KV Jharoda	Jharoda AP	110	4.8	0	0	8	0.5	118	5.3
		33 KV Jharoda	Gamri DS	72	2.8	0	0	10	0.85	82	3.65
		33 KV Jharoda	Lissan DS	51	2.1	0	0	0	0	51	2.1
		33 KV Jharoda	Nangal Kheri AP	70	3	0	0	9	0.72	79	3.72
		33 KV Jharoda	Lissan AP	73	1.9	0	0	5	0.31	78	2.21
		33 KV Jharoda	Dakhora DS	65	1.9	0	0	9	0.75	74	2.65
		33 KV Behrampur	Surkhpur DS	100	2.66	0	0	17	1.4	117	4.06
		33 KV Behrampur	Rattanthal AP	40	1.8	0	0	5	0.31	45	2.11
		33 KV Behrampur	Rattanthal DS	170	4.9	0	0	20	1.6	190	6.5

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Juddi (MC-I)	Irrigation	1	5	0	0	0	0	1	5
		33 KV MC-II Bishowa	Irrigation	1	5	0	0	0	0	1	5
		33 KV Bishowa	Mumtajpur AP	80	3	0	0	10	0.63	90	3.63
		33 KV Bishowa	Bishowa AP	25	1.1	0	0	5	0.31	30	1.41
		33 KV Bishowa	Jhorli AP	40	1.5	0	0	5	0.31	45	1.81
		33 KV Bishowa	Bisowa DS	29	0.73	0	0	3	0.19	32	0.92
		33 KV Bishowa	Garhi DS	96	3.3	0	0	18	1.5	114	4.8
		33 KV Bishowa	Bharangi DS	74	2.7	0	0	15	1.4	89	4.1
		33 KV Bishowa	Bawwa AP	75	3.6	0	0	10	0.63	85	4.23
		33 KV Bishowa	Karoli Ds	66	2.6	0	0	10	0.77	76	3.37
		33 KV JC-I Gudiyani	Gudiyani-II AP	45	2.3	0	0	10	0.63	55	2.93
		33 KV JC-I Gudiyani	Murlipur AP	22	1.2	0	0	10	0.63	32	1.83
		33 KV JC-I Gudiyani	Bhuriwas DS	70	2.7	0	0	15	1.2	85	3.9
		132 KV Kosli	Nathera AP	40	1.9	0	0	10	0.63	50	2.53
		132 KV Kosli	Tumna AP	52	2.2	0	0	11	0.84	63	3.04
		132 KV Kosli	Nahar-1 AP	40	1.8	0	0	10	0.63	50	2.43
		132 KV Kosli	Jakhala AP	110	3.9	0	0	12	0.83	122	4.73
		132 KV Kosli	Jhall DS	50	1.6	0	0	9	0.75	59	2.35
		132 KV Kosli	Gudiyani DS	123	6.8	0	0	19	1.6	142	8.4
		132 KV Kosli	Kosli DS	75	4.6	0	0	20	1.6	95	6.2
5	Rewari	33 KV Kaluwas	Nangal pathani AP	130	4.87	0	0	0	0	130	4.87

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Kaluwas	Haluhera DS	139	4.05	0	0	4	0.4	143	4.45
		33 KV Kaluwas	Bihariapur DS	223	6.2	0	0	0	0	223	6.2
		33 KV Kaluwas	Balawas AP	155	5.99	0	0	0	0	155	5.99
		33 KV Kaluwas	Kaluwas DS	38	0.91	0	0	0	0	38	0.91
		33 KV Kakoria	Kakoria DS	41	1.11	0	0	0	0	41	1.11
		33 KV Kakoria	Naya Gaon AP	43	1.94	0	0	0	0	43	1.94
		33 KV Kakoria	Janti DS	144	3.99	0	0	0	0	144	3.99
		33 KV Kakoria	Jat Bhurthal DS	119	3.55	0	0	0	0	119	3.55
		33 KV Kakoria	Dohki AP	153	6.36	0	0	0	0	153	6.36
		33 KV JC-IV	Bithwana AP	66	2.34	0	0	0	0	66	2.34
		33 KV JC-IV	Bhawari DS	144	3.4	0	0	8	0.28	152	3.68
		33 KV JC-IV	Sangwari AP	70	3.8	0	0	0	0	70	3.8
		33 KV JC-IV	Salawas AP	57	2.4	0	0	0	0	57	2.4
		33 KV JC-IV	Ladhuwas Gujjar DS	100	3.3	0	0	26	1.3	126	4.6
		33 KV Bharawas	Jatuwas AP	127	5.8	2	0.2	8	0.8	135	6.6
		33 KV Bharawas	Bithwana DS	107	4.8	2	0.2	15	1.5	122	6.3
		33 KV Bharawas	Kanuka AP	97	4.6	2	0.1	8	2.3	105	6.9
		33 KV Bharawas	Rajgarh AP	97	4	3	0.1	6	0.37	103	4.37
		33 KV Bharawas	Balawas Jat AP	54	2.3	2	0.1	5	0.4	59	2.7
		33 KV Bharawas	Dharan DS	127	4.7	3	0.1	7	0.4	134	5.1
		33 KV Bharawas	Badhrana DS	73	3.5	2	0.2	5	0.3	78	3.8

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Jonawas	Massani AP	135	6.03	3	0.3	7	0.7	142	6.73
		33 KV Jonawas	Meerpur AP	72	2.7	3	0.3	3	3	75	5.7
		33 KV Jonawas	Surajpura AP	128	4.1	2	0.2	6	0.6	134	4.7
		33 KV Jonawas	Rojka DS	224	5.04	2	0.2	12	1.2	236	6.24
		33 KV Jonawas	Ramgaeh DS	237	5.03	4	0.4	14	1.4	251	6.43
		33 KV Jarthal	Bolni AP	122	5.6	3	0.3	8	0.5	130	6.1
		33 KV Jarthal	Jarthal AP	144	5.5	2	0.2	6	0.3	150	5.8
		33 KV Jarthal	Nikhri AP	90	4.7	2	0.16	7	0.4	97	5.1
		33 KV Jarthal	Raliawas DS	217	5.3	2	0.2	10	1	227	6.3
		220 KV Rewari	Jant DS	23	0.46	0	0	0	0	23	0.46
		220 KV Rewari	Bikaner AP	122	4.71	0	0	0	0	122	4.71
		220 KV Rewari	Ghasera DS	100	3.62	0	0	8	0.18	108	3.8
		66 KV Dharuhera	Pipaki AP	64	3.5	3	0.3	8	0.8	72	4.3
		66 KV Dharuhera	Maheshwari AP	43	2.9	2	0.2	3	0.3	46	3.2
		66 KV Dharuhera	Bhatsana AP	109	8	3	0.3	8	8	117	16
		66 KV Dharuhera	Khatwali AP	122	5.1	3	0.3	8	0.8	130	5.9
		66 KV Dharuhera	Akera AP	40	2.5	2	0.2	3	0.3	43	2.8
		66 KV Dharuhera	Kapriwas AP	48	2.2	2	0.2	4	0.4	52	2.6
		66 KV Dharuhera	NRP Bass DS	218	5	3	0.3	16	1.6	234	6.6
		66 KV Dharuhera	Joniawas DS	176	5.1	3	0.3	17	1.7	193	6.8
		66 KV Baliar Kalan	Hanaska DS	163	3.5	2	0.2	8	0.8	171	4.3

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		66 KV Baliar Kalan	Khijuri AP	44	1.9	2	0.2	2	0.2	46	2.1
		66 KV Baliar Kalan	Baliar Khurd AP	22	0.7	2	0.2	2	2	24	2.7

# **Feeder Segregation**

State : HARYANA

District : Rewari

# Connecting unconnected RHHs

State : HARYANA

District : Rewari

## Block-wise coverage of villages for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
1	Bawal	104	0	0	0	0	0	0	0	0	0
2	Jatusana	73	0	0	0	0	0	0	0	0	0
3	Khol At Rewari	63	0	0	0	0	0	0	0	0	0
4	Nahar (P)	48	0	0	0	0	0	0	0	0	0
5	Rewari	121	0	0	0	0	0	0	0	0	0
<b>Total</b>		<b>409</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>



## Existing REDB Infrastructure for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
1	Bawal	132 KV Old Bawal	132/11 KV	1x16+1x16+0+0+0	32	1	28 8 43.63N 76 33 50.91E		20	LILO	20
2	Jatusana	33 KV Berli Khurd	33/11 KV	1x10+0+0+0+0	10	4	28 17 25.56N 76 30 56.10E	220 KV Lula Ahir	7.5	Radial	4
		33 KV Khushpura	33/11 KV	1x8+1x10+0+0+0	18	1	28 20 6.61N 76 27 16.43E	220 KV Lula Ahir	2.5	Radial	8
		33 KV Nangal Pathani	33/11 KV	1x10+0+0+0+0	10	4	28 21 10.09N 76 30 25.62E	220 KV Lula Ahir	4.5	Radial	5
		33 KV Palhawas	33/11 KV	1x10+1x5+0+0+0	15	1	28 35 28.73N 76 62 48.43E	132 KV Gangaicha Jant	8.5	Radial	10
		33 KV Gurawara	33/11 KV	1x10+0+0+0+0	10	1	28 23 48.54N 76 38 9.30E	132 KV Gangaicha Jant	12.8	Radial	3
		33 KV JC-II Jatusana	33/11 KV	1x5+1x8+0+0+0	13	1	28 18 37.55N 76 33 4.75E	220 KV S/Stn., Rewari	16	Radial	8
		132 KV Dahina	132/11 KV	1x16+1x16+0+0+0	32	1	28 11 44.44N 76 24 16.04		22	LILO	8
3	Khol At Rewari	33 KV Khol	33/11 KV	1x10+1x5+0+0+0	15	1	28 11 44.44N 76 24 16.02E	132 KV Buroli	8	Radial	7
		33 KV Ahrod	33/11 KV	1x10+0+0+0+0	10	1	28 11 1.12N 76 22 30.25E	132 KV Buroli	12	Radial	4
		132 KV Buroli	132/11 KV	1x16+1x16+0+0+0	32	1	28 14 48.80N 76 26 51.47E	220 KV S/Stn., Rewari	15	LILO	16
		132 KV GOTHRA	132/11 KV	1x16+1x16+0+0+0	32	1	28 19 33.80N 76 23 38.81E	220 KV S/Stn., Rewari	18	LILO	18
4	Nahar (P)	33 KV Jharoda	33/11 KV	1x10+1x10+0+0+0	20	1	28 21 31.23N 76 24 7.16E	220 KV Lula Ahir	5	Radial	8
		33 KV Behrampur	33/11 KV	1x10+0+0+0+0	10	1	28 23 42.83N 76 38 48.16E	132 KV Kosli	13	Radial	3
		33 KV Juddi (MC-I)	33/11 KV	1x5+0+0+0+0	5	1	28 25 44.79N 76 25 6.71E	132 KV Kosli	11	Radial	1

## Existing REDB Infrastructure for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of SubStation	Type of Sub-Station (33/11 or 66/11 KV)	Power Transformer Detail (MVA)	Total Power Transformer Capacity (MVA)	Constructed Under(Scheme)	GPS Co-ordinate	Name of Feeding EHV SubStation	Distance from Feeding EHV SubStation (in KM)	Type	Existing 11 KV Bay
		33 KV MC-II Bishowa	33/11 KV	1x5+0+0+0+0	5	1	28 23 32.64N 76 20 18 94E	132 KV Kosli	9	Radial	1
		33 KV Bishowa	33/11 KV	1x5+1x10+0+0+0	15	1	28 24 41.35N 76 20 28.37E	220 KV Lula Ahir	13.4	Radial	8
		33 KV JC-I Gudiyani	33/11 KV	1x6.3+1x3.15+0+0+0	9.45	1	28 21 33.08N 76 30 49.40E	132 KV Kosli	10	Radial	4
		132 KV Kosli	132/11 KV	1x20+0+0+0+0	20	1	28 20 6.58N 76 27 16.43E	220 KV Lula Ahir	6	LILO	8
5	Rewari	33 KV Kaluwas	33/11 KV	1x10+0+0+0+0	10	1	28 13 18.88N 76 35 28.08E	220 KV S/Stn., Rewari	2.5	Radial	7
		33 KV Kakoria	33/11 KV	1x10+0+0+0+0	10	4	28 15 12.52N 76 38 43.28E	132 KV Gangaicha Jant	4.5	Radial	6
		33 KV JC-IV	33/11 KV	1x10+1x10+0+0+0	20	1	28 8 54.71N 76 38 6.98E	220 KV S/Stn., Rewari	9.5	Radial	11
		33 KV Bharawas	33/11 KV	1x6.3+1x10+0+0+0	16.3	1	28 8 43.61N 76 33 50.89E	220 KV S/Stn., Rewari	13	Radial	8
		33 KV Jonawas	33/11 KV	1x6.3+1x10+0+0+0	16.3	1	28 12 35.15N 76 42 25.70E	220 KV S/Stn., Rewari	14	Radial	14
		33 KV Jarthal	33/11 KV	1x10+1x10+0+0+0	20	1	28 8 57.07N 76 43 0.60E	220 KV S/Stn., Mau	17	Radial	9
		220 KV Rewari	220/11 KV	1x16+1x16+0+0+0	32	1	28 11 35.06N 76 38 16.99E		70	LILO	15
		66 KV Dharuhera	66/11 KV	0+1x16+1x16+0+0	32	1	28 12 18.96N 76 47 32.05E		10	LILO	10
		66 KV Baliar Kalan	66/11 KV	1x16+1x16+0+0+0	32	1	28 12 35.12N 76 42 25.70E		10	Radial	3
<b>Total</b>					<b>502.05</b>						

## Block-Wise Substation for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
1	Bawal	1	32	0	0	0	0	0	0	1	32
2	Jatusana	7	108	6	76	0	0	0	0	13	184
3	Khol At Rewari	4	89	2	25	0	0	0	0	6	114
4	Nahar (P)	7	84.45	6	64.45	0	0	0	0	13	148.9
5	Rewari	9	188.6	7	121.3	0	0	0	0	16	309.9

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
1	Bawal	132 KV Old Bawal	Panwar DS	172	7.1	4	0.2	18	0.7	190	7.8
		132 KV Old Bawal	Dhani Ahir DS	202	6.3	3	0.2	10	0.4	212	6.7
		132 KV Old Bawal	MP Basai DS	99	3.2	4	0.2	8	0.4	107	3.6
		132 KV Old Bawal	Raipur DS	94	2.7	5	0.3	6	0.2	100	2.9
		132 KV Old Bawal	Pawati AP	144	6.08	3	0.2	10	0.7	154	6.78
		132 KV Old Bawal	Subaseri AP	127	6.3	3	0.2	13	1	140	7.3
		132 KV Old Bawal	Mangleshwar AP	106	5.7	4	0.2	7	0.5	113	6.2
		132 KV Old Bawal	Ibrahimpur AP	54	3.08	5	0.3	6	0.4	60	3.48
		132 KV Old Bawal	Tankari AP	88	3.8	4	0.2	10	0.7	98	4.5
		132 KV Old Bawal	Dulhera AP	112	5.6	5	0.3	13	1	125	6.6
		132 KV Old Bawal	Bidawas AP	131	6.6	3	0.1	15	1.1	146	7.7
		132 KV Old Bawal	Alawalpur AP	54	3.8	3	0.2	7	0.5	61	4.3
		132 KV Old Bawal	Keshopur DS	151	6.5	5	0.3	25	0.7	176	7.2
		132 KV Old Bawal	NSP Garhi DS	157	6.7	5	0.4	27	0.8	184	7.5
		132 KV Old Bawal	Kasola DS	218	5.3	7	0.5	14	0.6	232	5.9
		132 KV Old Bawal	Khandora AP	128	5.6	3	0.2	12	0.9	140	6.5
2	Jatusana	33 KV Berli Khurd	11 KV Berli AP	75	2.52	0	0	0	0	75	2.52
		33 KV Berli Khurd	11 KV Parkhotampur AP	27	1.23	0	0	0	0	27	1.23
		33 KV Berli Khurd	11 KV Musepur DS	102	3.38	0	0	5	0.5	107	3.88
		33 KV Khushpura	11 KV Baldhan AP	60	2.4	0	0	4	0.4	64	2.8
		33 KV Khushpura	11 KV Babroli AP	15	0.86	0	0	0	0	15	0.86

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Khushpura	11 KV Khushpura AP	45	2.12	0	0	3	0.3	48	2.42
		33 KV Khushpura	11 KV Daroli AP	54	2.4	0	0	5	0.5	59	2.9
		33 KV Khushpura	11 KV Fatepuri DS	54	2.23	0	0	6	0.38	60	2.61
		33 KV Khushpura	11 KV Khushpura DS	92	3.53	0	0	5	0.5	97	4.03
		33 KV Khushpura	11 KV Nangal Pathani DS	161	5.1	0	0	15	1.13	176	6.23
		33 KV Nangal Pathani	11 KV Bohtawas AP	66	2.52	0	0	5	0.32	71	2.84
		33 KV Nangal Pathani	11 KV Nangal Pathani DS	22	1.3	0	0	2	0.2	24	1.5
		33 KV Nangal Pathani	11 KV Murlipur DS	84	2.2	0	0	6	0.6	90	2.8
		33 KV Nangal Pathani	11 KV Bohtawas DS	32	1.06	0	0	2	0.2	34	1.26
		33 KV Palhawas	11 KV Gurawara AP	8	0.31	0	0	2	0.1	10	0.41
		33 KV Palhawas	11 KV Gangaicha AP	151	5.47	0	0	6	0.2	157	5.67
		33 KV Palhawas	11 KV Jiwera AP	6	0.34	0	0	0	0	6	0.34
		33 KV Palhawas	11 KV Choki AP	98	5.24	0	0	4	0.1	102	5.34
		33 KV Palhawas	11 KV Lala AP	86	3.1	0	0	5	0.32	91	3.42
		33 KV Palhawas	11 KV Mastapur DS	131	3.59	0	0	8	0.2	139	3.79
		33 KV Palhawas	11 KV Karawara DS	212	6.19	0	0	10	0.4	222	6.59
		33 KV Palhawas	11 KV Noorgarh DS	53	2.12	0	0	6	0.2	59	2.32
		33 KV Gurawara	11 KV Kanhori AP	95	3.7	0	0	8	0.2	103	3.9
		33 KV Gurawara	11 KV Gurawara AP	45	1.87	0	0	5	0.1	50	1.97
		33 KV Gurawara	11 KV Gurawara DS	83	3.36	0	0	8	0.2	91	3.56
		33 KV JC-II Jatusana	11 KV Jatusana AP	134	4.29	0	0	8	0.5	142	4.79

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV JC-II Jatusana	11 KV Kishangarh AP	66	2.07	0	0	7	0.44	73	2.51
		33 KV JC-II Jatusana	11 KV Berli Kalan AP	36	1.62	0	0	5	0.32	41	1.94
		33 KV JC-II Jatusana	11 KV Murlipur DS	133	4.15	0	0	8	0.4	141	4.55
		132 KV Dahina	11 KV Nimoth AP	107	5.8	0	0	7	0.44	114	6.24
		132 KV Dahina	11 KV Jainabad AP	115	6.5	0	0	7	0.44	122	6.94
		132 KV Dahina	11 KV Kanwali AP	156	7.6	0	0	9	0.56	165	8.16
		132 KV Dahina	11 KV Dahina AP	92	5.1	0	0	3	0.18	95	5.28
		132 KV Dahina	11 KV Mitc -15 AP	33	1.6	0	0	0	0	33	1.6
		132 KV Dahina	11 KV Dhanibad DS	104	3.8	0	0	0	0	104	3.8
		132 KV Dahina	11 KV Gothra DS	142	5.6	0	0	0	0	142	5.6
3	Khol At Rewari	33 KV Khol	11 KV Nangal Jamalpur AP	105	5.4	0	0	5	0.31	110	5.71
		33 KV Khol	11 KV Bohka AP	76	4.08	0	0	5	0.31	81	4.39
		33 KV Khol	11 KV Khol AP	50	3.04	0	0	4	0.25	54	3.29
		33 KV Khol	11 KV Mandola AP	76	3.4	0	0	5	0.31	81	3.71
		33 KV Khol	11 KV Khol DS	28	0.9	0	0	0	0	28	0.9
		33 KV Khol	11 KV Mandola/Bohka DS	107	2.2	0	0	0	0	107	2.2
		33 KV Khol	11 KV Dhani Kolana DS	53	1.3	0	0	0	0	53	1.3
		33 KV Khol	11 KV Nangal Jamalpur AP	105	5.4	0	0	5	0.31	110	5.71
		33 KV Khol	11 KV Bohka AP	76	4.08	0	0	5	0.31	81	4.39
		33 KV Khol	11 KV Khol AP	50	3.04	0	0	4	0.25	54	3.29
		33 KV Khol	11 KV Mandola AP	76	3.4	0	0	5	0.31	81	3.71

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Khol	11 KV Khol DS	28	0.9	0	0	0	0	28	0.9
		33 KV Khol	11 KV Mandola/Bohka DS	107	2.2	0	0	0	0	107	2.2
		33 KV Khol	11 KV Dhani Kolana DS	53	1.3	0	0	0	0	53	1.3
		33 KV Ahrod	11 KV Ahrod DS	222	7.9	2	0.2	6	0.3	228	8.2
		33 KV Ahrod	11 KV Nangle Jamalpur AP	100	4	2	0.2	8	0.5	108	4.5
		33 KV Ahrod	11 KV Uncha AP	51	2.2	2	0.2	7	0.4	58	2.6
		33 KV Ahrod	11 KV Bas Duda AP	98	3.2	2	0.2	8	0.5	106	3.7
		33 KV Ahrod	11 KV Ahrod DS	222	7.9	2	0.2	6	0.3	228	8.2
		33 KV Ahrod	11 KV Nangle Jamalpur AP	100	4	2	0.2	8	0.5	108	4.5
		33 KV Ahrod	11 KV Uncha AP	51	2.2	2	0.2	7	0.4	58	2.6
		33 KV Ahrod	11 KV Bas Duda AP	98	3.2	2	0.2	8	0.5	106	3.7
		132 KV Buroli	11 KV Dhawana AP	93	4.9	0	0	10	0.63	103	5.53
		132 KV Buroli	11 KV Masit AP	132	8.6	0	0	12	0.7	144	9.3
		132 KV Buroli	11 KV Kahari AP	155	8.7	0	0	3	0.18	158	8.88
		132 KV Buroli	11 KV Gumina AP	128	8.1	0	0	5	0.3	133	8.4
		132 KV Buroli	11 KV Khaleta AP	159	8.09	0	0	10	0.63	169	8.72
		132 KV Buroli	11 KV Siha AP	173	8.7	0	0	12	0.7	185	9.4
		132 KV Buroli	11 KV Aulant AP	261	16.1	0	0	10	0.63	271	16.73
		132 KV Buroli	11 KV Mundi DS	183	4.5	0	0	0	0	183	4.5
		132 KV Buroli	11 KV Kumrodha DS	122	3.3	0	0	0	0	122	3.3
		132 KV Buroli	11 KV Delhawas DS	129	3.4	0	0	0	0	129	3.4

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		132 KV Buroli	11 KV Mayan DS	52	1.8	0	0	2	0.05	54	1.85
		132 KV Buroli	11 KV Luhana DS	66	2.1	0	0	0	0	66	2.1
		132 KV Buroli	11 KV Dhawana DS	12	0.6	0	0	0	0	12	0.6
		132 KV Buroli	11 KV Rampuri DS	25	1.4	0	0	0	0	25	1.4
		132 KV Buroli	11 KV Dhawana AP	93	4.9	0	0	10	0.63	103	5.53
		132 KV Buroli	11 KV Masit AP	132	8.6	0	0	12	0.7	144	9.3
		132 KV Buroli	11 KV Kahari AP	155	8.7	0	0	3	0.18	158	8.88
		132 KV Buroli	11 KV Gumina AP	128	8.1	0	0	5	0.3	133	8.4
		132 KV Buroli	11 KV Khaleta AP	159	8.09	0	0	10	0.63	169	8.72
		132 KV Buroli	11 KV Siha AP	173	8.7	0	0	12	0.7	185	9.4
		132 KV Buroli	11 KV Aulant AP	261	16.1	0	0	10	0.63	271	16.73
		132 KV Buroli	11 KV Mundi DS	183	4.5	0	0	0	0	183	4.5
		132 KV Buroli	11 KV Kumrodha DS	122	3.3	0	0	0	0	122	3.3
		132 KV Buroli	11 KV Delhawas DS	129	3.4	0	0	0	0	129	3.4
		132 KV Buroli	11 KV Mayan DS	52	1.8	0	0	2	0.05	54	1.85
		132 KV Buroli	11 KV Luhana DS	66	2.1	0	0	0	0	66	2.1
		132 KV Buroli	11 KV Dhawana DS	12	0.6	0	0	0	0	12	0.6
		132 KV Buroli	11 KV Rampuri DS	25	1.4	0	0	0	0	25	1.4
		132 KV GOTHRA	11 KV Chitadungra AP	109	4.9	2	0.2	6	0.3	115	5.2
		132 KV GOTHRA	11 KV Khoru AP	121	6.4	3	0.03	7	0.4	128	6.8
		132 KV GOTHRA	11 KV Gumina AP-II	127	5.4	2	0.02	5	0.3	132	5.7



## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		132 KV GOTHRA	11 KV Punsika AP	101	4.4	3	0.03	7	0.4	108	4.8
		132 KV GOTHRA	11 Gothra AP	63	3.1	3	0.03	5	0.3	68	3.4
		132 KV GOTHRA	11 KV Balwari AP	54	4.5	2	0.2	8	0.5	62	5
		132 KV GOTHRA	11 KV Kund AP	112	5.4	2	0.2	9	0.5	121	5.9
		132 KV GOTHRA	11 KV Dhani Manethi AP	66	3.1	3	0.03	5	0.3	71	3.4
		132 KV GOTHRA	11 KV Kundal AP	137	5.1	3	0.03	8	0.5	145	5.6
		132 KV GOTHRA	11 KV Bhandor DS	140	5.6	3	0.03	4	0.2	144	5.8
		132 KV GOTHRA	11 KV Pali DS	91	3.2	3	0.03	5	0.3	96	3.5
		132 KV GOTHRA	11 KV Thothwal DS	82	3.8	2	0.2	4	0.2	86	4
		132 KV GOTHRA	11 KV Sundroj DS	128	4.2	2	0.2	5	0.3	133	4.5
		132 KV GOTHRA	11 KV Nandha DS	170	6.2	3	0.03	7	0.4	177	6.6
4	Nahar (P)	33 KV Jharoda	Nahar II AP	150	6	0	0	10	0.63	160	6.63
		33 KV Jharoda	Jharoda AP	110	4.8	0	0	8	0.5	118	5.3
		33 KV Jharoda	Gamri DS	72	2.8	0	0	10	0.85	82	3.65
		33 KV Jharoda	Lissan DS	51	2.1	0	0	0	0	51	2.1
		33 KV Jharoda	Nangal Kheri AP	70	3	0	0	9	0.72	79	3.72
		33 KV Jharoda	Lissan AP	73	1.9	0	0	5	0.31	78	2.21
		33 KV Jharoda	Dakhora DS	65	1.9	0	0	9	0.75	74	2.65
		33 KV Behrampur	Surkhpur DS	100	2.66	0	0	17	1.4	117	4.06
		33 KV Behrampur	Rattanthal AP	40	1.8	0	0	5	0.31	45	2.11
		33 KV Behrampur	Rattanthal DS	170	4.9	0	0	20	1.6	190	6.5

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Juddi (MC-I)	Irrigation	1	5	0	0	0	0	1	5
		33 KV MC-II Bishowa	Irrigation	1	5	0	0	0	0	1	5
		33 KV Bishowa	Mumtajpur AP	80	3	0	0	10	0.63	90	3.63
		33 KV Bishowa	Bishowa AP	25	1.1	0	0	5	0.31	30	1.41
		33 KV Bishowa	Jhorli AP	40	1.5	0	0	5	0.31	45	1.81
		33 KV Bishowa	Bisowa DS	29	0.73	0	0	3	0.19	32	0.92
		33 KV Bishowa	Garhi DS	96	3.3	0	0	18	1.5	114	4.8
		33 KV Bishowa	Bharangi DS	74	2.7	0	0	15	1.4	89	4.1
		33 KV Bishowa	Bawwa AP	75	3.6	0	0	10	0.63	85	4.23
		33 KV Bishowa	Karoli Ds	66	2.6	0	0	10	0.77	76	3.37
		33 KV JC-I Gudiyani	Gudiyani-II AP	45	2.3	0	0	10	0.63	55	2.93
		33 KV JC-I Gudiyani	Murlipur AP	22	1.2	0	0	10	0.63	32	1.83
		33 KV JC-I Gudiyani	Bhuriwas DS	70	2.7	0	0	15	1.2	85	3.9
		132 KV Kosli	Nathera AP	40	1.9	0	0	10	0.63	50	2.53
		132 KV Kosli	Tumna AP	52	2.2	0	0	11	0.84	63	3.04
		132 KV Kosli	Nahar-1 AP	40	1.8	0	0	10	0.63	50	2.43
		132 KV Kosli	Jakhala AP	110	3.9	0	0	12	0.83	122	4.73
		132 KV Kosli	Jhall DS	50	1.6	0	0	9	0.75	59	2.35
		132 KV Kosli	Gudiyani DS	123	6.8	0	0	19	1.6	142	8.4
		132 KV Kosli	Kosli DS	75	4.6	0	0	20	1.6	95	6.2
5	Rewari	33 KV Kaluwas	Nangal pathani AP	130	4.87	0	0	0	0	130	4.87

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Kaluwas	Haluhera DS	139	4.05	0	0	4	0.4	143	4.45
		33 KV Kaluwas	Bihariapur DS	223	6.2	0	0	0	0	223	6.2
		33 KV Kaluwas	Balawas AP	155	5.99	0	0	0	0	155	5.99
		33 KV Kaluwas	Kaluwas DS	38	0.91	0	0	0	0	38	0.91
		33 KV Kakoria	Kakoria DS	41	1.11	0	0	0	0	41	1.11
		33 KV Kakoria	Naya Gaon AP	43	1.94	0	0	0	0	43	1.94
		33 KV Kakoria	Janti DS	144	3.99	0	0	0	0	144	3.99
		33 KV Kakoria	Jat Bhurthal DS	119	3.55	0	0	0	0	119	3.55
		33 KV Kakoria	Dohki AP	153	6.36	0	0	0	0	153	6.36
		33 KV JC-IV	Bithwana AP	66	2.34	0	0	0	0	66	2.34
		33 KV JC-IV	Bhawari DS	144	3.4	0	0	8	0.28	152	3.68
		33 KV JC-IV	Sangwari AP	70	3.8	0	0	0	0	70	3.8
		33 KV JC-IV	Salawas AP	57	2.4	0	0	0	0	57	2.4
		33 KV JC-IV	Ladhuwas Gujjar DS	100	3.3	0	0	26	1.3	126	4.6
		33 KV Bharawas	Jatuwas AP	127	5.8	2	0.2	8	0.8	135	6.6
		33 KV Bharawas	Bithwana DS	107	4.8	2	0.2	15	1.5	122	6.3
		33 KV Bharawas	Kanuka AP	97	4.6	2	0.1	8	2.3	105	6.9
		33 KV Bharawas	Rajgarh AP	97	4	3	0.1	6	0.37	103	4.37
		33 KV Bharawas	Balawas Jat AP	54	2.3	2	0.1	5	0.4	59	2.7
		33 KV Bharawas	Dharan DS	127	4.7	3	0.1	7	0.4	134	5.1
		33 KV Bharawas	Badhrana DS	73	3.5	2	0.2	5	0.3	78	3.8

## Feederwise DTs for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		33 KV Jonawas	Massani AP	135	6.03	3	0.3	7	0.7	142	6.73
		33 KV Jonawas	Meerpur AP	72	2.7	3	0.3	3	3	75	5.7
		33 KV Jonawas	Surajpura AP	128	4.1	2	0.2	6	0.6	134	4.7
		33 KV Jonawas	Rojka DS	224	5.04	2	0.2	12	1.2	236	6.24
		33 KV Jonawas	Ramgaeh DS	237	5.03	4	0.4	14	1.4	251	6.43
		33 KV Jarthal	Bolni AP	122	5.6	3	0.3	8	0.5	130	6.1
		33 KV Jarthal	Jarthal AP	144	5.5	2	0.2	6	0.3	150	5.8
		33 KV Jarthal	Nikhri AP	90	4.7	2	0.16	7	0.4	97	5.1
		33 KV Jarthal	Raliawas DS	217	5.3	2	0.2	10	1	227	6.3
		220 KV Rewari	Jant DS	23	0.46	0	0	0	0	23	0.46
		220 KV Rewari	Bikaner AP	122	4.71	0	0	0	0	122	4.71
		220 KV Rewari	Ghasera DS	100	3.62	0	0	8	0.18	108	3.8
		66 KV Dharuhera	Pipaki AP	64	3.5	3	0.3	8	0.8	72	4.3
		66 KV Dharuhera	Maheshwari AP	43	2.9	2	0.2	3	0.3	46	3.2
		66 KV Dharuhera	Bhatsana AP	109	8	3	0.3	8	8	117	16
		66 KV Dharuhera	Khatwali AP	122	5.1	3	0.3	8	0.8	130	5.9
		66 KV Dharuhera	Akera AP	40	2.5	2	0.2	3	0.3	43	2.8
		66 KV Dharuhera	Kapriwas AP	48	2.2	2	0.2	4	0.4	52	2.6
		66 KV Dharuhera	NRP Bass DS	218	5	3	0.3	16	1.6	234	6.6
		66 KV Dharuhera	Joniawas DS	176	5.1	3	0.3	17	1.7	193	6.8
		66 KV Baliar Kalan	Hanaska DS	163	3.5	2	0.2	8	0.8	171	4.3

## Feederwise DTs for Supplementary DPR

**State** : HARYANA  
**District** : Rewari

Sl.No.	Name of Block	Name of 33/11 KV Source Substation	Name of 11 KV or 22 KV Feeder	Existing Distribution Transformer (DTs) as on 31.03.2015		Already sanctioned and under execution in RGGVY/State/Other schemes		DTs proposed to be installed under present scheme		Total DT capacity	
		66 KV Baliar Kalan	Khijuri AP	44	1.9	2	0.2	2	0.2	46	2.1
		66 KV Baliar Kalan	Baliar Khurd AP	22	0.7	2	0.2	2	2	24	2.7

# Metering

State : HARYANA

District : Rewari

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Sub-station	Name of Feeder	Description	No. of DTR installed	No. of DTR metered	No. of DTR meters already installed and to be installed under ongoing approved schemes (RGGVY/State/Other)	No. of DTR meter Proposed in DDUJY
1	Rewari	220 KV Rewari	Ghasera DS	10 KVA	0	0	0	0
				16 KVA	14	0	0	0
				25 KVA	660	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
630 KVA	0	0	0	0				
2	Rewari	220 KV Rewari	Jant DS	10 KVA	0	0	0	0
				16 KVA	11	0	0	0
				25 KVA	5	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
3	Rewari	33 KV Kaluwas	Haluhera DS	10 KVA	0	0	0	0
				16 KVA	45	0	0	0
				25 KVA	78	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	10	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
4	Rewari	33 KV Kaluwas	Biharpur DS	10 KVA	0	0	0	0
				16 KVA	52	0	0	0
				25 KVA	153	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	11	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
5	Rewari	33 KV JC-IV	Ladhuwas Gujjar DS	10 KVA	0	0	0	0
				16 KVA	20	0	0	0
				25 KVA	72	0	0	0
				40 KVA	0	0	0	0
				63 KVA	11	0	0	0
				100 KVA	20	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
6	Rewari	33 KV JC-IV	Bhawari DS	10 KVA	0	0	0	0
				16 KVA	47	0	0	0
				25 KVA	97	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
7	Jatusana	132 KV Dahina	11 KV Nimoth AP	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	49	0	0	0
				40 KVA	0	0	0	0
				63 KVA	27	0	0	0
				100 KVA	29	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
8	Jatusana	132 KV Dahina	11 KV Jainabad AP	10 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	5	0	0	0
				25 KVA	48	0	0	0
				40 KVA	0	0	0	0
				63 KVA	25	0	0	0
				100 KVA	37	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
9	Jatusana	132 KV Dahina	11 KV Kanwali AP	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	79	0	0	0
				40 KVA	0	0	0	0
				63 KVA	49	0	0	0
				100 KVA	26	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
10	Jatusana	132 KV Dahina	11 KV Dahina AP	10 KVA	0	0	0	0
				16 KVA	5	0	0	0
				25 KVA	29	0	0	0
				40 KVA	0	0	0	0
				63 KVA	32	0	0	0
				100 KVA	26	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
11	Jatusana	132 KV Dahina	11 KV Mitc -15 AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	77	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0
				100 KVA	15	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
12	Jatusana	132 KV Dahina	11 KV Dhanibad DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	77	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0
				100 KVA	15	0	0	0
				160 KVA	0	0	0	0
				200 KVA	1	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				13	Jatusana	132 KV Dahina	11 KV Gothra DS	10 KVA
16 KVA	0	0	0					0
25 KVA	100	0	0					0
40 KVA	0	0	0					0
63 KVA	22	0	0					0
100 KVA	23	0	0					0
160 KVA	0	0	0					0
200 KVA	0	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
14	Khol At Rewari	132 KV Buroli	11 KV Dhawana AP	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	43	0	0	0
				40 KVA	0	0	0	0
				63 KVA	26	0	0	0
				100 KVA	22	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
15	Khol At Rewari	132 KV Buroli	11 KV Masit AP	10 KVA	0	0	0	0
				16 KVA	10	0	0	0
				25 KVA	35	0	0	0
				40 KVA	0	0	0	0
				63 KVA	29	0	0	0
				100 KVA	58	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
16	Khol At Rewari	132 KV Buroli	11 KV Kahari AP	10 KVA	0	0	0	0
				16 KVA	10	0	0	0
				25 KVA	48	0	0	0
				40 KVA	0	0	0	0
				63 KVA	62	0	0	0
				100 KVA	35	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
17	Khol At Rewari	132 KV Buroli	11 KV Gumina AP	10 KVA	0	0	0	0
				16 KVA	26	0	0	0
				25 KVA	25	0	0	0
				40 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	16	0	0	0
				100 KVA	61	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
18	Khol At Rewari	132 KV Buroli	11 KV Khaleta AP	10 KVA	0	0	0	0
				16 KVA	25	0	0	0
				25 KVA	56	0	0	0
				40 KVA	0	0	0	0
				63 KVA	43	0	0	0
				100 KVA	35	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
19	Khol At Rewari	132 KV Buroli	11 KV Siha AP	10 KVA	0	0	0	0
				16 KVA	27	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	69	0	0	0
				40 KVA	0	0	0	0
				63 KVA	30	0	0	0
				100 KVA	47	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
20	Khol At Rewari	132 KV Buroli	11 KV Aulant AP	10 KVA	0	0	0	0
				16 KVA	27	0	0	0
				25 KVA	23	0	0	0
				40 KVA	0	0	0	0
				63 KVA	104	0	0	0
				100 KVA	25	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

21	Khol At Rewari	132 KV Buroli	11 KV Mundi DS	10 KVA	0	0	0	0
				16 KVA	15	0	0	0
				25 KVA	135	0	0	0
				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
22	Khol At Rewari	132 KV Buroli	11 KV Kumrodha DS	10 KVA	0	0	0	0
				16 KVA	23	0	0	0
				25 KVA	95	0	0	0
				40 KVA	0	0	0	0
				63 KVA	3	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
23	Khol At Rewari	132 KV Buroli	11 KV Delhawas DS	10 KVA	0	0	0	0
				16 KVA	44	0	0	0
				25 KVA	81	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
24	Khol At Rewari	132 KV Buroli	11 KV Mayan DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	48	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
25	Khol At Rewari	132 KV Buroli	11 KV Luhana DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	50	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
26	Khol At Rewari	132 KV Buroli	11 KV Dhawana DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	6	0	0	0
				40 KVA	0	0	0	0
				63 KVA	3	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
27	Khol At Rewari	132 KV Buroli	11 KV Rampuri DS	10 KVA	0	0	0	0
				16 KVA	9	0	0	0
				25 KVA	39	0	0	0
				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
28	Khol At Rewari	33 KV Khol	11 KV Nangal Jamalpur AP	10 KVA	0	0	0	0
				16 KVA	5	0	0	0
				25 KVA	48	0	0	0
				40 KVA	0	0	0	0
				63 KVA	29	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	23	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
29	Khol At Rewari	33 KV Khol	11 KV Bohka AP	10 KVA	0	0	0	0
				16 KVA	8	0	0	0
				25 KVA	32	0	0	0
				40 KVA	0	0	0	0
				63 KVA	12	0	0	0
				100 KVA	24	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				30	Khol At Rewari	33 KV Khol	11 KV Khol AP	10 KVA
16 KVA	2	0	0					0
25 KVA	15	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	18	0	0	0
				100 KVA	15	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
31	Khol At Rewari	33 KV Khol	11 KV Mandola AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	43	0	0	0
				40 KVA	0	0	0	0
				63 KVA	16	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
32	Khol At Rewari	33 KV Khol	11 KV Khol DS	10 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	4	0	0	0
				25 KVA	20	0	0	0
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
33	Khol At Rewari	33 KV Khol	11 KV Mandola/Bohka DS	10 KVA	0	0	0	0
				16 KVA	11	0	0	0
				25 KVA	57	0	0	0
				40 KVA	0	0	0	0
				63 KVA	10	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
34	Khol At Rewari	33 KV Khol	11 KV Dhani Kolana DS	10 KVA	0	0	0	0
				16 KVA	11	0	0	0
				25 KVA	46	0	0	0
				40 KVA	0	0	0	0
				63 KVA	0	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
35	Nahar (P)	33 KV Jharoda	Lissan DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	38	0	0	0
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
36	Nahar (P)	33 KV Jharoda	Lissan AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	28	0	0	0
				40 KVA	0	0	0	0
				63 KVA	25	0	0	0
				100 KVA	16	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				37	Rewari	33 KV Kakoria	Kakoria DS	10 KVA
16 KVA	7	0	0					0
25 KVA	31	0	0					0
40 KVA	0	0	0					0
63 KVA	2	0	0					0
100 KVA	1	0	0					0
160 KVA	0	0	0					0
200 KVA	0	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
38	Rewari	33 KV Kakoria	Janti DS	10 KVA	0	0	0	0
				16 KVA	20	0	0	0
				25 KVA	113	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	4	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
39	Rewari	33 KV Kakoria	Dohki AP	10 KVA	0	0	0	0
				16 KVA	3	0	0	0
				25 KVA	106	0	0	0
				40 KVA	0	0	0	0
				63 KVA	20	0	0	0
				100 KVA	24	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
40	Jatusana	33 KV Nangal Pathani	11 KV Bohtawas AP	10 KVA	4	0	0	0
				16 KVA	5	0	0	0
				25 KVA	33	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	12	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
41	Jatusana	33 KV JC-II Jatusana	11 KV Kishangarh AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	55	0	0	0
				40 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	2	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
42	Jatusana	33 KV Berli Khurd	11 KV Berli AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	59	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
43	Jatusana	33 KV Berli Khurd	11 KV Parkhotampur AP	10 KVA	0	0	0	0
				16 KVA	1	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	16	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
44	Jatusana	33 KV JC-II Jatusana	11 KV Berli Kalan AP	10 KVA	2	0	0	0
				16 KVA	4	0	0	0
				25 KVA	17	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

45	Rewari	33 KV Kakoria	Naya Gaon AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	26	0	0	0
				40 KVA	0	0	0	0
				63 KVA	11	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
46	Rewari	220 KV Rewari	Bikaner AP	10 KVA	4	0	0	0
				16 KVA	1	0	0	0
				25 KVA	87	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0
				100 KVA	16	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
47	Rewari	66 KV Dharuhera	Khatwali AP	10 KVA	1	0	0	0
				16 KVA	15	0	0	0
				25 KVA	65	0	0	0
				40 KVA	0	0	0	0
				63 KVA	21	0	0	0
				100 KVA	20	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
48	Rewari	66 KV Dharuhera	Maheshwari AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	13	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0
				100 KVA	21	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
49	Rewari	66 KV Dharuhera	Kapriwas AP	10 KVA	2	0	0	0
				16 KVA	12	0	0	0
				25 KVA	7	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
50	Rewari	66 KV Dharuhera	Pipaki AP	10 KVA	3	0	0	0
				16 KVA	2	0	0	0
				25 KVA	38	0	0	0
				40 KVA	0	0	0	0
				63 KVA	15	0	0	0
				100 KVA	23	0	0	0
				160 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
51	Rewari	66 KV Dharuhera	Bhatsana AP	10 KVA	14	0	0	0
				16 KVA	9	0	0	0
				25 KVA	50	0	0	0
				40 KVA	0	0	0	0
				63 KVA	30	0	0	0
				100 KVA	23	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
52	Rewari	66 KV Dharuhera	Akera AP	10 KVA	4	0	0	0
				16 KVA	3	0	0	0
				25 KVA	9	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
53	Rewari	66 KV Dharuhera	NRP Bass DS	10 KVA	27	0	0	0
				16 KVA	92	0	0	0
				25 KVA	81	0	0	0
				40 KVA	0	0	0	0
				63 KVA	12	0	0	0
				100 KVA	11	0	0	0
				160 KVA	0	0	0	0
				200 KVA	1	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				54	Rewari	66 KV Dharuhera	Joniaswas DS	10 KVA
16 KVA	48	0	0					0
25 KVA	111	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	16	0	0	0
				160 KVA	0	0	0	0
				200 KVA	2	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
55	Rewari	66 KV Baliar Kalan	Hanaska DS	10 KVA	4	0	0	0
				16 KVA	59	0	0	0
				25 KVA	105	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
56	Rewari	66 KV Baliar Kalan	Khijuri AP	10 KVA	3	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	5	0	0	0
				25 KVA	17	0	0	0
				40 KVA	0	0	0	0
				63 KVA	13	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
57	Rewari	66 KV Baliar Kalan	Baliar Khurd AP	10 KVA	0	0	0	0
				16 KVA	3	0	0	0
				25 KVA	14	0	0	0
				40 KVA	0	0	0	0
				63 KVA	3	0	0	0
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
58	Jatusana	33 KV Gurawara	11 KV Kanhori AP	10 KVA	0	0	0	0
				16 KVA	8	0	0	0
				25 KVA	59	0	0	0
				40 KVA	0	0	0	0
				63 KVA	15	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
59	Jatusana	33 KV Gurawara	11 KV Gurawara AP	10 KVA	0	0	0	0
				16 KVA	5	0	0	0
				25 KVA	24	0	0	0
				40 KVA	0	0	0	0
				63 KVA	11	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
60	Jatusana	33 KV Gurawara	11 KV Gurawara DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	61	0	0	0
				40 KVA	0	0	0	0
				63 KVA	10	0	0	0
				100 KVA	12	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				61	Jatusana	33 KV Palhawas	11 KV Gurawara AP	10 KVA
16 KVA	0	0	0					0
25 KVA	6	0	0					0
40 KVA	0	0	0					0
63 KVA	1	0	0					0
100 KVA	1	0	0					0
160 KVA	0	0	0					0
200 KVA	0	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
62	Jatusana	33 KV Palhawas	11 KV Gangaicha AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	119	0	0	0
				40 KVA	0	0	0	0
				63 KVA	19	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
63	Jatusana	33 KV Palhawas	11 KV Jiwera AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	1	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
64	Jatusana	33 KV Palhawas	11 KV Choki AP	10 KVA	0	0	0	0
				16 KVA	8	0	0	0
				25 KVA	25	0	0	0
				40 KVA	0	0	0	0
				63 KVA	51	0	0	0
				100 KVA	14	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
65	Jatusana	33 KV Palhawas	11 KV Lala AP	10 KVA	0	0	0	0
				16 KVA	3	0	0	0
				25 KVA	62	0	0	0
				40 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	15	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
66	Jatusana	33 KV Palhawas	11 KV Mastapur DS	10 KVA	0	0	0	0
				16 KVA	25	0	0	0
				25 KVA	90	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
67	Jatusana	33 KV Palhawas	11 KV Karawara DS	10 KVA	0	0	0	0
				16 KVA	8	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	184	0	0	0
				40 KVA	0	0	0	0
				63 KVA	11	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
68	Jatusana	33 KV Palhawas	11 KV Noorgarh DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	38	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

69	Jatusana	33 KV JC-II Jatusana	11 KV Jatusana AP	10 KVA	10	0	0	0
				16 KVA	9	0	0	0
				25 KVA	89	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
70	Jatusana	33 KV JC-II Jatusana	11 KV Murlipur DS	10 KVA	0	0	0	0
				16 KVA	49	0	0	0
				25 KVA	146	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0
				100 KVA	12	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
71	Jatusana	33 KV Nangal Pathani	11 KV Nangal Pathani DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	9	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
72	Jatusana	33 KV Khushpura	11 KV Khushpura DS	10 KVA	0	0	0	0
				16 KVA	6	0	0	0
				25 KVA	80	0	0	0
				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
73	Jatusana	33 KV Khushpura	11 KV Fatepuri DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	47	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
74	Nahar (P)	132 KV Kosli	Gudiyani DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	70	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0
				100 KVA	24	0	0	0
				160 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	5	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
75	Nahar (P)	132 KV Kosli	Kosli DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	39	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	25	0	0	0
				160 KVA	0	0	0	0
				200 KVA	4	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
76	Nahar (P)	33 KV Jharoda	Gamri DS	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	81	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
77	Nahar (P)	33 KV Jharoda	Dakhora DS	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	43	0	0	0
				40 KVA	0	0	0	0
				63 KVA	11	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
78	Nahar (P)	33 KV Bishowa	Bisowa DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	28	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
79	Nahar (P)	33 KV Bishowa	Garhi DS	10 KVA	0	0	0	0
				16 KVA	13	0	0	0
				25 KVA	86	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	0	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
80	Nahar (P)	33 KV Bishowa	Bharangi DS	10 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	0	0	0	0
				25 KVA	82	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	17	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
81	Rewari	33 KV Kakoria	Jat Bhurthal DS	10 KVA	0	0	0	0
				16 KVA	24	0	0	0
				25 KVA	83	0	0	0
				40 KVA	0	0	0	0
				63 KVA	3	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
82	Rewari	33 KV Jarthal	Bolni AP	10 KVA	8	0	0	0
				16 KVA	10	0	0	0
				25 KVA	30	0	0	0
				40 KVA	0	0	0	0
				63 KVA	33	0	0	0
				100 KVA	21	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
83	Rewari	33 KV Jarthal	Jarthal AP	10 KVA	6	0	0	0
				16 KVA	7	0	0	0
				25 KVA	57	0	0	0
				40 KVA	0	0	0	0
				63 KVA	21	0	0	0
				100 KVA	23	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
84	Rewari	33 KV Kaluwas	Kaluwas DS	10 KVA	0	0	0	0
				16 KVA	21	0	0	0
				25 KVA	15	0	0	0
				40 KVA	0	0	0	0
				63 KVA	0	0	0	0
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
85	Rewari	33 KV Jarthal	Nikhri AP	10 KVA	6	0	0	0
				16 KVA	10	0	0	0
				25 KVA	25	0	0	0
				40 KVA	0	0	0	0
				63 KVA	26	0	0	0
				100 KVA	23	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
86	Rewari	33 KV Jarthal	Raliawas DS	10 KVA	13	0	0	0
				16 KVA	53	0	0	0
				25 KVA	130	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	4	0	0	0
				160 KVA	0	0	0	0
				200 KVA	2	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
87	Rewari	33 KV Kaluwas	Nangal pathani AP	10 KVA	0	0	0	0
				16 KVA	9	0	0	0
				25 KVA	86	0	0	0
				40 KVA	0	0	0	0
				63 KVA	25	0	0	0
				100 KVA	10	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
88	Rewari	33 KV Jonawas	Massani AP	10 KVA	0	0	0	0
				16 KVA	13	0	0	0
				25 KVA	76	0	0	0
				40 KVA	0	0	0	0
				63 KVA	21	0	0	0
				100 KVA	24	0	0	0
				160 KVA	0	0	0	0
				200 KVA	1	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
89	Rewari	33 KV JC-IV	Bithwana AP	10 KVA	0	0	0	0
				16 KVA	7	0	0	0
				25 KVA	46	0	0	0
				40 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	6	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
90	Rewari	33 KV JC-IV	Sangwari AP	10 KVA	0	0	0	0
				16 KVA	3	0	0	0
				25 KVA	39	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0
				100 KVA	19	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
91	Rewari	33 KV Jonawas	Meerpur AP	10 KVA	0	0	0	0
				16 KVA	10	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	41	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
92	Rewari	33 KV Jonawas	Surajpura AP	10 KVA	1	0	0	0
				16 KVA	51	0	0	0
				25 KVA	50	0	0	0
				40 KVA	0	0	0	0
				63 KVA	13	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

93	Rewari	33 KV JC-IV	Salawas AP	10 KVA	3	0	0	0
				16 KVA	7	0	0	0
				25 KVA	28	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0
				100 KVA	10	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
94	Rewari	33 KV Jonawas	Rojka DS	10 KVA	26	0	0	0
				16 KVA	50	0	0	0
				25 KVA	128	0	0	0
				40 KVA	0	0	0	0
				63 KVA	10	0	0	0
				100 KVA	4	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
95	Rewari	33 KV Jonawas	Ramgaeh DS	10 KVA	31	0	0	0
				16 KVA	34	0	0	0
				25 KVA	125	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	3	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
96	Rewari	33 KV Bharawas	Jatuwas AP	10 KVA	8	0	0	0
				16 KVA	3	0	0	0
				25 KVA	64	0	0	0
				40 KVA	0	0	0	0
				63 KVA	29	0	0	0
				100 KVA	23	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
97	Rewari	33 KV Bharawas	Bithwana DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	61	0	0	0
				40 KVA	0	0	0	0
				63 KVA	34	0	0	0
				100 KVA	12	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
98	Rewari	33 KV Bharawas	Kanuka AP	10 KVA	8	0	0	0
				16 KVA	1	0	0	0
				25 KVA	45	0	0	0
				40 KVA	0	0	0	0
				63 KVA	19	0	0	0
				100 KVA	24	0	0	0
				160 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
99	Rewari	33 KV Bharawas	Rajgarh AP	10 KVA	3	0	0	0
				16 KVA	16	0	0	0
				25 KVA	57	0	0	0
				40 KVA	0	0	0	0
				63 KVA	22	0	0	0
				100 KVA	11	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
100	Rewari	33 KV Bharawas	Balawas Jat AP	10 KVA	2	0	0	0
				16 KVA	3	0	0	0
				25 KVA	27	0	0	0
				40 KVA	0	0	0	0
				63 KVA	16	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
101	Rewari	33 KV Bharawas	Dharan DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	98	0	0	0
				40 KVA	0	0	0	0
				63 KVA	15	0	0	0
				100 KVA	14	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
102	Rewari	33 KV Bharawas	Badhrana DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	40	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	20	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
103	Khol At Rewari	33 KV Ahrod	11 KV Ahrod DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	182	0	0	0
				40 KVA	0	0	0	0
				63 KVA	22	0	0	0
				100 KVA	18	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
104	Khol At Rewari	33 KV Ahrod	11 KV Nangle Jamalpur AP	10 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	2	0	0	0
				25 KVA	65	0	0	0
				40 KVA	0	0	0	0
				63 KVA	25	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
105	Khol At Rewari	33 KV Ahrod	11 KV Uncha AP	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	27	0	0	0
				40 KVA	0	0	0	0
				63 KVA	17	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
106	Khol At Rewari	33 KV Ahrod	11 KV Bas Duda AP	10 KVA	2	0	0	0
				16 KVA	7	0	0	0
				25 KVA	63	0	0	0
				40 KVA	0	0	0	0
				63 KVA	21	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
107	Nahar (P)	33 KV Bishowa	Karoli Ds	10 KVA	0	0	0	0
				16 KVA	1	0	0	0
				25 KVA	64	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
108	Rewari	33 KV Kaluwas	Balawas AP	10 KVA	0	0	0	0
				16 KVA	16	0	0	0
				25 KVA	101	0	0	0
				40 KVA	0	0	0	0
				63 KVA	16	0	0	0
				100 KVA	22	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				109	Bawal	132 KV Old Bawal	Panwar DS	10 KVA
16 KVA	0	0	0					0
25 KVA	115	0	0					0
40 KVA	0	0	0					0
63 KVA	37	0	0					0
100 KVA	19	0	0					0
160 KVA	0	0	0					0
200 KVA	0	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
110	Bawal	132 KV Old Bawal	Dhani Ahir DS	10 KVA	0	0	0	0
				16 KVA	24	0	0	0
				25 KVA	154	0	0	0
				40 KVA	0	0	0	0
				63 KVA	9	0	0	0
				100 KVA	15	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
111	Bawal	132 KV Old Bawal	MP Basai DS	10 KVA	10	0	0	0
				16 KVA	17	0	0	0
				25 KVA	54	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	10	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
112	Bawal	132 KV Old Bawal	Raipur DS	10 KVA	9	0	0	0
				16 KVA	16	0	0	0
				25 KVA	57	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
113	Bawal	132 KV Old Bawal	Pawati AP	10 KVA	0	0	0	0
				16 KVA	10	0	0	0
				25 KVA	82	0	0	0
				40 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	36	0	0	0
				100 KVA	16	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
114	Bawal	132 KV Old Bawal	Subaseri AP	10 KVA	0	0	0	0
				16 KVA	3	0	0	0
				25 KVA	81	0	0	0
				40 KVA	0	0	0	0
				63 KVA	17	0	0	0
				100 KVA	26	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
115	Bawal	132 KV Old Bawal	Mangleshwar AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	30	0	0	0
				40 KVA	0	0	0	0
				63 KVA	17	0	0	0
				100 KVA	15	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
116	Bawal	132 KV Old Bawal	Ibrahimpur AP	10 KVA	4	0	0	0
				16 KVA	2	0	0	0
				25 KVA	13	0	0	0
				40 KVA	0	0	0	0
				63 KVA	22	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

117	Bawal	132 KV Old Bawal	Tankari AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	55	0	0	0
				40 KVA	0	0	0	0
				63 KVA	12	0	0	0
				100 KVA	17	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
118	Bawal	132 KV Old Bawal	Dulhera AP	10 KVA	0	0	0	0
				16 KVA	1	0	0	0
				25 KVA	58	0	0	0
				40 KVA	0	0	0	0
				63 KVA	29	0	0	0
				100 KVA	24	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
119	Bawal	132 KV Old Bawal	Bidawas AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	70	0	0	0
				40 KVA	0	0	0	0
				63 KVA	33	0	0	0
				100 KVA	28	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
120	Bawal	132 KV Old Bawal	Keshopur DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	99	0	0	0
				40 KVA	0	0	0	0
				63 KVA	30	0	0	0
				100 KVA	22	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
121	Bawal	132 KV Old Bawal	NSP Garhi DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	103	0	0	0
				40 KVA	0	0	0	0
				63 KVA	32	0	0	0
				100 KVA	22	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
122	Bawal	132 KV Old Bawal	Kasola DS	10 KVA	19	0	0	0
				16 KVA	45	0	0	0
				25 KVA	142	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	4	0	0	0
				160 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
123	Bawal	132 KV Old Bawal	Khandora AP	10 KVA	0	0	0	0
				16 KVA	1	0	0	0
				25 KVA	79	0	0	0
				40 KVA	0	0	0	0
				63 KVA	32	0	0	0
				100 KVA	16	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
124	Bawal	132 KV Old Bawal	Alawalpur AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	20	0	0	0
				40 KVA	0	0	0	0
				63 KVA	12	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	12	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
125	Khol At Rewari	132 KV GOTHRA	11 KV Chitadungra AP	10 KVA	2	0	0	0
				16 KVA	4	0	0	0
				25 KVA	61	0	0	0
				40 KVA	0	0	0	0
				63 KVA	23	0	0	0
				100 KVA	19	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				126	Khol At Rewari	132 KV GOTHRA	11 KV Khorl AP	10 KVA
16 KVA	3	0	0					0
25 KVA	51	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	40	0	0	0
				100 KVA	26	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
127	Khol At Rewari	132 KV GOTHRA	11 KV Gumina AP-II	10 KVA	4	0	0	0
				16 KVA	10	0	0	0
				25 KVA	72	0	0	0
				40 KVA	0	0	0	0
				63 KVA	18	0	0	0
				100 KVA	23	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
128	Khol At Rewari	132 KV GOTHRA	11 KV Punsika AP	10 KVA	1	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	7	0	0	0
				25 KVA	53	0	0	0
				40 KVA	0	0	0	0
				63 KVA	26	0	0	0
				100 KVA	14	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
129	Khol At Rewari	132 KV GOTHRA	11 Gothra AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	31	0	0	0
				40 KVA	0	0	0	0
				63 KVA	21	0	0	0
				100 KVA	11	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
130	Khol At Rewari	132 KV GOTHRA	11 KV Balwari AP	10 KVA	2	0	0	0
				16 KVA	3	0	0	0
				25 KVA	27	0	0	0
				40 KVA	0	0	0	0
				63 KVA	16	0	0	0
				100 KVA	6	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
131	Khol At Rewari	132 KV GOTHRA	11 KV Kund AP	10 KVA	2	0	0	0
				16 KVA	6	0	0	0
				25 KVA	54	0	0	0
				40 KVA	0	0	0	0
				63 KVA	28	0	0	0
				100 KVA	22	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
132	Khol At Rewari	132 KV GOTHRA	11 KV Dhani Manethi AP	10 KVA	1	0	0	0
				16 KVA	4	0	0	0
				25 KVA	36	0	0	0
				40 KVA	0	0	0	0
				63 KVA	16	0	0	0
				100 KVA	10	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
				133	Khol At Rewari	132 KV GOTHRA	11 KV Kundal AP	10 KVA
16 KVA	32	0	0					0
25 KVA	67	0	0					0
40 KVA	0	0	0					0
63 KVA	22	0	0					0
100 KVA	15	0	0					0
160 KVA	0	0	0					0
200 KVA	0	0	0					0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
134	Khol At Rewari	132 KV GOTHRA	11 KV Bhandor DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	99	0	0	0
				40 KVA	0	0	0	0
				63 KVA	27	0	0	0
				100 KVA	14	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
135	Khol At Rewari	132 KV GOTHRA	11 KV Pali DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	71	0	0	0
				40 KVA	0	0	0	0
				63 KVA	13	0	0	0
				100 KVA	7	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
136	Khol At Rewari	132 KV GOTHRA	11 KV Thothwal DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	62	0	0	0
				40 KVA	0	0	0	0
				63 KVA	19	0	0	0
				100 KVA	11	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
137	Khol At Rewari	132 KV GOTHRA	11 KV Sundroj DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	105	0	0	0
				40 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	18	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
138	Khol At Rewari	132 KV GOTHRA	11 KV Nandha DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	134	0	0	0
				40 KVA	0	0	0	0
				63 KVA	21	0	0	0
				100 KVA	14	0	0	0
				160 KVA	0	0	0	0
				200 KVA	1	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
139	Jatusana	33 KV Khushpura	11 KV Babroli AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	8	0	0	0
				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
140	Nahar (P)	33 KV Bishowa	Mumtajpur AP	10 KVA	1	0	0	0
				16 KVA	2	0	0	0
				25 KVA	34	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

141	Nahar (P)	33 KV Bishowa	Bishowa AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	40	0	0	0
				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
142	Nahar (P)	33 KV Bishowa	Jhorli AP	10 KVA	2	0	0	0
				16 KVA	2	0	0	0
				25 KVA	43	0	0	0
				40 KVA	0	0	0	0
				63 KVA	12	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
143	Nahar (P)	33 KV Bishowa	Bawwa AP	10 KVA	0	0	0	0
				16 KVA	5	0	0	0
				25 KVA	80	0	0	0
				40 KVA	0	0	0	0
				63 KVA	16	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
144	Nahar (P)	33 KV Behrampur	Rattanthal AP	10 KVA	0	0	0	0
				16 KVA	13	0	0	0
				25 KVA	20	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	5	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
145	Nahar (P)	33 KV Behrampur	Surkhpur DS	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	90	0	0	0
				40 KVA	0	0	0	0
				63 KVA	4	0	0	0
				100 KVA	2	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
146	Nahar (P)	33 KV Behrampur	Rattanthal DS	10 KVA	0	0	0	0
				16 KVA	10	0	0	0
				25 KVA	145	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
147	Nahar (P)	33 KV Jharoda	Nahar II AP	10 KVA	0	0	0	0
				16 KVA	9	0	0	0
				25 KVA	140	0	0	0
				40 KVA	0	0	0	0
				63 KVA	15	0	0	0
				100 KVA	25	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
148	Nahar (P)	33 KV Jharoda	Jharoda AP	10 KVA	0	0	0	0
				16 KVA	4	0	0	0
				25 KVA	60	0	0	0
				40 KVA	0	0	0	0
				63 KVA	14	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				100 KVA	12	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
149	Nahar (P)	33 KV Jharoda	Nangal Kheri AP	10 KVA	0	0	0	0
				16 KVA	2	0	0	0
				25 KVA	25	0	0	0
				40 KVA	0	0	0	0
				63 KVA	5	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
150	Nahar (P)	33 KV JC-I Gudiyani	Gudiyani-II AP	10 KVA	10	0	0	0
				16 KVA	6	0	0	0
				25 KVA	53	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				40 KVA	0	0	0	0
				63 KVA	24	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
151	Nahar (P)	33 KV JC-I Gudiyani	Murlipur AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	44	0	0	0
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	7	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
152	Nahar (P)	33 KV JC-I Gudiyani	Bhuriwas DS	10 KVA	0	0	0	0



## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				16 KVA	0	0	0	0
				25 KVA	53	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	10	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
153	Nahar (P)	132 KV Kosli	Nathera AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	63	0	0	0
				40 KVA	0	0	0	0
				63 KVA	18	0	0	0
				100 KVA	24	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				630 KVA	0	0	0	0
154	Nahar (P)	132 KV Kosli	Tumna AP	10 KVA	0	0	0	0
				16 KVA	5	0	0	0
				25 KVA	43	0	0	0
				40 KVA	0	0	0	0
				63 KVA	19	0	0	0
				100 KVA	19	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
155	Nahar (P)	132 KV Kosli	Nahar-1 AP	10 KVA	0	0	0	0
				16 KVA	16	0	0	0
				25 KVA	132	0	0	0
				40 KVA	0	0	0	0
				63 KVA	48	0	0	0
				100 KVA	22	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
156	Nahar (P)	132 KV Kosli	Jakhala AP	10 KVA	3	0	0	0
				16 KVA	0	0	0	0
				25 KVA	79	0	0	0
				40 KVA	0	0	0	0
				63 KVA	22	0	0	0
				100 KVA	32	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
157	Nahar (P)	132 KV Kosli	Jhall DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	65	0	0	0
				40 KVA	0	0	0	0
				63 KVA	2	0	0	0
				100 KVA	13	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
158	Jatusana	33 KV Nangal Pathani	11 KV Murlipur DS	10 KVA	0	0	0	0
				16 KVA	20	0	0	0
				25 KVA	57	0	0	0
				40 KVA	0	0	0	0
				63 KVA	6	0	0	0
				100 KVA	1	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
159	Jatusana	33 KV Nangal Pathani	11 KV Bohtawas DS	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	26	0	0	0
				40 KVA	0	0	0	0
				63 KVA	1	0	0	0
				100 KVA	3	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
160	Jatusana	33 KV Berli Khurd	11 KV Musepur DS	10 KVA	0	0	0	0
				16 KVA	36	0	0	0
				25 KVA	24	0	0	0
				40 KVA	0	0	0	0
				63 KVA	19	0	0	0
				100 KVA	16	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
161	Jatusana	33 KV Khushpura	11 KV Baldhan AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	43	0	0	0
				40 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				63 KVA	9	0	0	0
				100 KVA	8	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
162	Jatusana	33 KV Khushpura	11 KV Khushpura AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0
				25 KVA	30	0	0	0
				40 KVA	0	0	0	0
				63 KVA	7	0	0	0
				100 KVA	9	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
163	Jatusana	33 KV Khushpura	11 KV Daroli AP	10 KVA	0	0	0	0
				16 KVA	0	0	0	0

## DTR Metering for Supplementary DPR

State : HARYANA  
District : Rewari

				25 KVA	36	0	0	0
				40 KVA	0	0	0	0
				63 KVA	8	0	0	0
				100 KVA	10	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0
164	Jatusana	33 KV Khushpura	11 KV Nangal Pathani DS	10 KVA	0	0	0	0
				16 KVA	11	0	0	0
				25 KVA	129	0	0	0
				40 KVA	0	0	0	0
				63 KVA	10	0	0	0
				100 KVA	11	0	0	0
				160 KVA	0	0	0	0
				200 KVA	0	0	0	0
				250 KVA	0	0	0	0
				315 KVA	0	0	0	0
				400 KVA	0	0	0	0
				500 KVA	0	0	0	0
				630 KVA	0	0	0	0

## Consumer Metering for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Description	1-Ph Domestic & Commercial	3-Ph Domestic & Commercial	3-Ph Water works	3-Ph Agriculture
1	Bawal	Existing Consumers	20058	157	95	5365
		Defective Meters	2547	100	0	1247
		Un-metered	0	0	0	2542
		Existing Electro-Mechanical Meters	3654	145	0	2012
		Installation of New Meters	0	0	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
2	Jatusana	Existing Consumers	16272	71	61	4890
		Defective Meters	1029	10	16	1019
		Un-metered	0	0	0	1287
		Existing Electro-Mechanical Meters	6878	0	0	0
		Installation of New Meters	0	0	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
3	Khol At Rewari	Existing Consumers	32709	558	183	4092
		Defective Meters	3000	61	18	2013
		Un-metered	0	0	0	2867
		Existing Electro-Mechanical Meters	0	0	0	0
		Installation of New Meters	0	0	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
4	Nahar (P)	Existing Consumers	28234	131	109	5986
		Defective Meters	2133	50	78	1411



## Consumer Metering for Supplementary DPR

State : HARYANA  
District : Rewari

		Un-metered	0	0	0	2139
		Existing Electro-Mechanical Meters	9255	0	0	0
		Installation of New Meters	0	0	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0
5	Rewari	Existing Consumers	54191	1605	192	5351
		Defective Meters	4704	100	25	2061
		Un-metered	0	0	0	3122
		Existing Electro-Mechanical Meters	7388	0	0	0
		Installation of New Meters	0	0	0	0
		Replacement of Defective Meters	0	0	0	0
		Replacement of Electro-Mechanical Meters	0	0	0	0

## Shifting of Meters for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Description	1-Ph Domestic & Commercial	3-Ph Domestic & Commercial	3-Ph Water works	3-Ph Agriculture
1	Bawal	Total Existing consumers	20058	157	145	5365
		Total Metered Consumer	20058	157	145	3917
		Total Requirement of shifting of meters outside	1000	195	0	0
2	Jatusana	Total Existing consumers	16272	71	61	4890
		Total Metered Consumer	16272	71	61	3603
		Total Requirement of shifting of meters outside	1000	15	0	0
3	Khol At Rewari	Total Existing consumers	32709	558	183	4092
		Total Metered Consumer	32709	558	183	1816
		Total Requirement of shifting of meters outside	1000	26	0	0
4	Nahar (P)	Total Existing consumers	28234	131	109	5986
		Total Metered Consumer	28234	131	109	3847
		Total Requirement of shifting of meters outside	1300	75	0	0
5	Rewari	Total Existing consumers	54191	1605	192	5351
		Total Metered Consumer	54191	1605	192	3283
		Total Requirement of shifting of meters outside	2000	227	0	0

## Feeder Metering for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No	Name of Block	33 KV Feeder									11 KV or 22 KV Feeder				
		No of Feeders( Existing Under Execution and Proposed )	Meters Already Installed		Balance for Meterization		Defective Meter		Meters Required for Meterization		No of Feeders( Existing Under Execution and Proposed )	Meters Already Installed	Defective Meter	Meters Required	
			At 132 KV S/s End	At 33/11 KV S/s	At 132 KV S/s End	At 33/11 KV S/s	At 132 KV S/s End	At 33/11 KV S/s	With CT/PT	Without CT/PT				With CT/PT	Without CT/PT
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	Bawal	0	0	0	0	0	0	0	0	0	16	16	0	0	0
2	Jatusana	0	0	0	0	0	0	0	0	0	35	35	0	0	0
3	Khol At Rewari	0	0	0	0	0	0	0	0	0	39	39	0	0	0
4	Nahar (P)	0	0	0	0	0	0	0	0	0	30	30	0	0	0
5	Rewari	0	0	0	0	0	0	0	0	0	45	45	0	0	0
<b>Total</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>165</b>	<b>165</b>	<b>0</b>	<b>0</b>	<b>0</b>

# **System Strengthening and Augmentation**

State : HARYANA

District : Rewari

## Block-Wise Substation for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of Block	Existing 33/11 kV Sub-Station as on 31.03.2015		33/11 kV Sub-Station already sanctioned and under execution in RGGVY/State/Other schemes as on 31.03.2015		New 33/11 kV Sub-Stations proposed under present scheme		Aug of existing 33/11kV Sub-Stations proposed in the scheme		Total 33/11 kV	
		No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)	No. of S/s (Nos)	PT Capacity (MVA)
1	Bawal	1	32	0	0	0	0	0	0	1	32
2	Jatusana	7	108	6	76	0	0	0	0	13	184
3	Khol At Rewari	4	89	2	25	0	0	0	0	6	114
4	Nahar (P)	7	84.45	6	64.45	0	0	0	0	13	148.9
5	Rewari	9	188.6	7	121.3	0	0	0	0	16	309.9

## EHV Substation Feeding the District for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate								Capacity of Substation (In KVA)		
1	<b>220 KV S/Stn., Rewari</b>															<b>28.2033967,76.6331231</b>								<b>407000</b>		
<b>Feeder Details :-</b>																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		25		33 KV	338	33 KV	120	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	458	26.18	104.71
PTR-2		25		33 KV	320	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	320	18.29	73.16
PTR-3		25		33 KV	275	33 KV	230	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	505	28.86	115.46
PTR-4		16		11 KV	100	11 KV	10	11 KV	260	11 KV	270	11 KV	70	11 KV	110	110 KV	10	11 KV	10	0	0	0	0	840	15.81	98.83
PTR-5		16		11 KV	250	11 KV	10	11 KV	290	11 KV	110	11 KV	170	11 KV	260	0	0	0	0	0	0	0	0	1090	20.77	129.79
2	<b>220 KV Lula Ahir</b>															<b>28 20 6.61N 76 27 16.43E</b>								<b>100000</b>		
<b>Feeder Details :-</b>																										
Name of PTR		Capacity (In MVA)		Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded
				Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10				
				Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity			
PTR-1		100		33 KV	289	33 KV	188	33 KV	297	33 KV	143	0	0	0	0	0	0	0	0	0	0	0	0	917	52.41	52.41
PTR-2		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

## EHV Substation Feeding the District for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)						
<b>3</b>	<b>132 KV Buroli</b>															<b>28 17 25.58N 76 30 56.10E</b>						<b>48000</b>						
<b>Feeder Details :-</b>																												
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10								
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity							
PTR-1	16	33 KV	220	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	220	12.57	78.59		
PTR-2	16	11 KV	250	11 KV	220	11 KV	100	11 KV	180	11 KV	90	11 KV	100	11 KV	80	0	0	0	0	0	0	0	0	1020	19.43	121.46		
PTR-3	16	11 KV	180	11 KV	240	11 KV	20	11 KV	30	11 KV	220	11 KV	140	11 KV	40	11 KV	40	11 KV	150	11 KV	5	0	0	1065	20.29	126.81		
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>4</b>	<b>132 KV Gangaicha Jant</b>															<b>28 13 90.10N 76 35 28.09E</b>						<b>50000</b>						
<b>Feeder Details :-</b>																												
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded				
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10								
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity							
PTR-1	25	33 KV	300	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	300	17.15	68.59	
PTR-2	25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

## EHV Substation Feeding the District for Supplementary DPR

State : HARYANA  
 District : Rewari

Sl.No.	Name of existing 33/11 KV substation															GPS Coordinate						Capacity of Substation (In KVA)					
<b>5</b>	<b>66 KV Dharuhera</b>															<b>28 12 5.17N 76 47 32.05E</b>						<b>52000</b>					
<b>Feeder Details :-</b>																											
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1	20	33 KV	74	33 KV	30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	104	5.94	29.72	
PTR-2	16	11 KV	250	11 KV	150	11 KV	200	11 KV	300	11 KV	300	11 KV	300	0	0	0	0	0	0	0	0	0	0	0	1500	28.58	178.61
PTR-3	16	11 KV	150	11 KV	160	11 KV	280	11 KV	300	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	890	16.96	105.98
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>6</b>	<b>220 KV S/Stn., Mau</b>															<b>28 12 5.20N 76 47 32.05E</b>						<b>300000</b>					
<b>Feeder Details :-</b>																											
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded			
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1	100	33 KV	168	33 KV	375	33 KV	275	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	818	46.75	46.75
PTR-2	200	66 KV	282	66 KV	182	66 KV	174	66 KV	300	66 KV	392	66 KV	384	0	0	0	0	0	0	0	0	0	0	0	1714	195.93	97.97
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0



## EHV Substation Feeding the District for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)				
7	66 KV Balar Kalan												28 12 35.12N 76 42 25.70E								32000				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	16	11 KV	110	11 KV	36	11 KV	15	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	161	3.07	19.17
PTR-2	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	132 KV Kosli												28 20 6.58N 76 27 16.43E								76500				
Feeder Details :-																									
Name of PTR	Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded	
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10					
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1	25	33 KV	100	33 KV	120	33 KV	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	320	18.29	73.16
PTR-2	31.5	33 KV	210	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	210	12	38.1
PTR-3	20	11 KV	140	11 KV	190	11 KV	110	11 KV	110	11 KV	70	11 KV	120	11 KV	10	11 KV	90	0	0	0	0	0	840	16	80.02
PTR-4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

## EHV Substation Feeding the District for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)					
<b>9</b>	<b>132 KV Old S/Stn. Bawal</b>												<b>28 8 43.63N 76 33 50.91E</b>								<b>32000</b>					
Feeder Details :-																										
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		16	11 KV 300	11 KV 300	11 KV 150	11 KV 260	11 KV 260	11 KV 4700	11 KV 210	11 KV 200	11 KV 120	11 KV 180											6680	127.27	795.42	
PTR-2		16	11 KV 290	11 KV 270	11 KV 320	11 KV 310	11 KV 130	11 KV 180	11 KV 70	11 KV 360	11 KV 280	11 KV 0	11 KV 0											2210	42.1	263.16
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
<b>10</b>	<b>132 KV S/Stn., HSIIDC Bawal</b>												<b>28 8 43.62N 76 33 50.90E</b>								<b>90000</b>					
Feeder Details :-																										
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																			Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10						
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity					
PTR-1		20	11 KV 400	11 KV 80	11 KV 190	11 KV 300	11 KV 60	11 KV 350	11 KV 80	11 KV 70	11 KV 110	11 KV 0	11 KV 0											1640	31.25	156.23
PTR-2		50	33 KV 200	33 KV 40	33 KV 30	33 KV 60	33 KV 60	33 KV 40	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	33 KV 0	
PTR-3		20	11 KV 300	11 KV 350	11 KV 60	11 KV 160	11 KV 2	11 KV 40	11 KV 170	11 KV 70	11 KV 0	11 KV 0	11 KV 0											1152	21.95	109.74
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

## EHV Substation Feeding the District for Supplementary DPR

State : HARYANA  
 District : Rewari

Sl.No.	Name of existing 33/11 KV substation												GPS Coordinate								Capacity of Substation (In KVA)						
<b>11</b>	<b>132 KV S/Stn., Gothra</b>												<b>28 11 1.10N 76 22 30.24E</b>								<b>32000</b>						
Feeder Details :-																											
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity						
PTR-1		16	11 KV 215	11 KV 175	11 KV 275	11 KV 110	11 KV 225	11 KV 5	11 KV 90	11 KV 175	11 KV 170	0	0											1440	27.43	171.47	
PTR-2		16	11 KV 250	11 KV 250	11 KV 280	11 KV 330	11 KV 150	11 KV 70	11 KV 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1335	25.43	158.97
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>12</b>	<b>132 KV S/Stn., Dahina</b>												<b>28 11 44.44N 76 24 16.04E</b>								<b>32000</b>						
Feeder Details :-																											
Name of PTR		Capacity (In MVA)	Total Recorded Maximum Loading on Feeders(In Amp.)																				Total (In Amp.)	Equivalent MVA Loading	Max % Loading Recorded		
		Feeder 1		Feeder 2		Feeder 3		Feeder 4		Feeder 5		Feeder 6		Feeder 7		Feeder 8		Feeder 9		Feeder 10							
		Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity	Type	Capacity				
PTR-1		16	11 KV 180	11 KV 250	11 KV 250	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	680	12.96	80.97	
PTR-2		16	11 KV 200	11 KV 10	11 KV 240	11 KV 70	11 KV 180	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	700	13.34	83.35	
PTR-3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTR-5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

## Districtwise Details of Existing 66 KV or 33 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of 132/33 kV Source Substation	Name of Destination Substation	Line Type	Length of line(kms.)
1	2	3	4	5	6
2	Jatusana	220 KV Lula Ahir	33 KV Berli Khurd	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	8
		220 KV Lula Ahir	33 KV Khushpura	33 KV LINE ON PANTHER CONDUCTOR	3
		220 KV Lula Ahir	33 KV Nangal Pathani	33 KV LINE ON PANTHER CONDUCTOR	5
		132 KV Gangaicha Jant	33 KV Palhawas	33KV LINE ON STEEL TUBULAR POLES WITH DOG CONDUCTOR	9
		132 KV Gangaicha Jant	33 KV Gurawara	33KV LINE ON STEEL TUBULAR POLES WITH DOG CONDUCTOR	4
		220 KV S/Stn., Rewari	33 KV JC-II Jatusana	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	16
9	Khol At Rewari	132 KV Buroli	33 KV Khol	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	8
		132 KV Buroli	33 KV Ahrod	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	12
12	Nahar (P)	220 KV Lula Ahir	33 KV Jharoda	33 KV LINE ON PANTHER CONDUCTOR	3
		132 KV Kosli	33 KV Behrampur	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	13
		132 KV Kosli	33 KV Juddi (MC-I)	33KV LINE ON PCC POLES WITH RACCOON CONDUCTOR	11
		132 KV Kosli	33 KV MC-II Bishowa	33KV LINE ON PCC POLES WITH RACCOON CONDUCTOR	9
		220 KV Lula Ahir	33 KV Bishowa	33 KV LINE ON PANTHER CONDUCTOR	13
		132 KV Kosli	33 KV JC-I Gudiyani	33KV LINE ON PCC POLES WITH RACCOON CONDUCTOR	10
19	Rewari	220 KV S/Stn., Rewari	33 KV Kaluwas	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	3
		132 KV Gangaicha Jant	33 KV Kakoria	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	5
		220 KV S/Stn., Rewari	33 KV JC-IV	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	9
		220 KV S/Stn., Rewari	33 KV Bharawas	33KV LINE ON PCC POLES WITH DOG CONDUCTOR	19
		220 KV S/Stn., Rewari	33 KV Jonawas	33KV LINE ON STEEL TUBULAR POLES WITH DOG CONDUCTOR	14
		220 KV S/Stn., Mau	33 KV Jarthal	33 KV LINE ON PANTHER CONDUCTOR	15
		220 KV S/Stn., Mau	66 KV Baliar Kalan	66 KV LINE ON H-BEAMS WITH WOLF CONDUCTOR	10
		220 KV S/Stn., Mau	66 KV Dharuhera	66 KV LINE ON H-BEAMS WITH WOLF CONDUCTOR	10

## Districtwise Details of Existing 66 KV or 33 KV Lines for Supplementary DPR

State : HARYANA  
 District : Rewari

S.No.	Name of Block	Name of 132/33 kV Source Substation	Name of Destination Substation	Line Type	Length of line(kms.)
1	2	3	4	5	6
<b>Total</b>					<b>209</b>

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
1	Bawal	132 KV Old Bawal	Panwar DS	Rabbit-50 sqmm.	PCC	18.6
		132 KV Old Bawal	Dhani Ahir DS	Rabbit-50 sqmm.	PCC	23.5
		132 KV Old Bawal	MP Basai DS	Rabbit-50 sqmm.	PCC	24.5
		132 KV Old Bawal	Raipur DS	Rabbit-50 sqmm.	PCC	17.7
		132 KV Old Bawal	Pawati AP	Weasel-30 sqmm.	PCC	32.8
		132 KV Old Bawal	Subaseri AP	Weasel-30 sqmm.	PCC	27.8
		132 KV Old Bawal	Mangleshwar AP	Weasel-30 sqmm.	PCC	25.5
		132 KV Old Bawal	Ibrahimpur AP	Weasel-30 sqmm.	PCC	22.5
		132 KV Old Bawal	Tankari AP	Weasel-30 sqmm.	PCC	27.4
		132 KV Old Bawal	Dulhera AP	Weasel-30 sqmm.	PCC	24.4
		132 KV Old Bawal	Bidawas AP	Weasel-30 sqmm.	PCC	22.5
		132 KV Old Bawal	Alawalpur AP	Weasel-30 sqmm.	PCC	19.2
		132 KV Old Bawal	Keshopur DS	Rabbit-50 sqmm.	PCC	31.8
		132 KV Old Bawal	NSP Garhi DS	Rabbit-50 sqmm.	PCC	24.7
		132 KV Old Bawal	Kasola DS	Rabbit-50 sqmm.	PCC	25
132 KV Old Bawal	Khandora AP	Rabbit-50 sqmm.	PCC	63.5		
2	Jatusana	33 KV Berli Khurd	11 KV Berli AP	Weasel-30 sqmm.	PCC	19.9
		33 KV Berli Khurd	11 KV Parkhotampur AP	Weasel-30 sqmm.	PCC	10.81
		33 KV Berli Khurd	11 KV Musepur DS	Rabbit-50 sqmm.	PCC	13.8
		33 KV Khushpura	11 KV Baldhan AP	Weasel-30 sqmm.	PCC	8
		33 KV Khushpura	11 KV Babroli AP	Weasel-30 sqmm.	PCC	1.3
		33 KV Khushpura	11 KV Khushpura AP	Weasel-30 sqmm.	PCC	7.5

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		33 KV Khushpura	11 KV Daroli AP	Weasel-30 sqmm.	PCC	9.5
		33 KV Khushpura	11 KV Fatepuri DS	Rabbit-50 sqmm.	PCC	4.5
		33 KV Khushpura	11 KV Khushpura DS	Rabbit-50 sqmm.	PCC	4.9
		33 KV Khushpura	11 KV Nangal Pathani DS	Rabbit-50 sqmm.	PCC	4.5
		33 KV Nangal Pathani	11 KV Bohtawas AP	Weasel-30 sqmm.	PCC	26.7
		33 KV Nangal Pathani	11 KV Nangal Pathani DS	Rabbit-50 sqmm.	PCC	4.5
		33 KV Nangal Pathani	11 KV Murlipur DS	Rabbit-50 sqmm.	PCC	8.5
		33 KV Nangal Pathani	11 KV Bohtawas DS	Rabbit-50 sqmm.	PCC	15.7
		33 KV Palhawas	11 KV Gurawara AP	Weasel-30 sqmm.	PCC	3
		33 KV Palhawas	11 KV Gangaicha AP	Weasel-30 sqmm.	RS Joist	20
		33 KV Palhawas	11 KV Jiwera AP	Weasel-30 sqmm.	PCC	16
		33 KV Palhawas	11 KV Choki AP	Weasel-30 sqmm.	PCC	19
		33 KV Palhawas	11 KV Lala AP	Rabbit-50 sqmm.	PCC	26
		33 KV Palhawas	11 KV Mastapur DS	Rabbit-50 sqmm.	PCC	21
		33 KV Palhawas	11 KV Karawara DS	Rabbit-50 sqmm.	PCC	30
		33 KV Palhawas	11 KV Noorgarh DS	Rabbit-50 sqmm.	PCC	11
		33 KV Gurawara	11 KV Kanhori AP	Weasel-30 sqmm.	PCC	30
		33 KV Gurawara	11 KV Gurawara AP	Weasel-30 sqmm.	PCC	8
		33 KV Gurawara	11 KV Gurawara DS	Rabbit-50 sqmm.	PCC	12
		33 KV JC-II Jatusana	11 KV Jatusana AP	Weasel-30 sqmm.	PCC	42
		33 KV JC-II Jatusana	11 KV Kishangarh AP	Weasel-30 sqmm.	PCC	17.5
		33 KV JC-II Jatusana	11 KV Berli Kalan AP	Weasel-30 sqmm.	PCC	15.6

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		33 KV JC-II Jatusana	11 KV Murlipur DS	Rabbit-50 sqmm.	PCC	46
		132 KV Dahina	11 KV Nimoth AP	Rabbit-50 sqmm.	PCC	21.66
		132 KV Dahina	11 KV Jainabad AP	Weasel-30 sqmm.	PCC	17.83
		132 KV Dahina	11 KV Kanwali AP	Rabbit-50 sqmm.	PCC	15.21
		132 KV Dahina	11 KV Dahina AP	Weasel-30 sqmm.	PCC	18.35
		132 KV Dahina	11 KV Mitc -15 AP	Weasel-30 sqmm.	PCC	10.6
		132 KV Dahina	11 KV Dhanibad DS	Rabbit-50 sqmm.	PCC	12.96
		132 KV Dahina	11 KV Gothra DS	Rabbit-50 sqmm.	PCC	12.98
3	Khol At Rewari	33 KV Khol	11 KV Nangal Jamalpur AP	Rabbit-50 sqmm.	PCC	19.9
		33 KV Khol	11 KV Bohka AP	Rabbit-50 sqmm.	PCC	18.12
		33 KV Khol	11 KV Khol AP	Rabbit-50 sqmm.	PCC	22.56
		33 KV Khol	11 KV Mandola AP	Rabbit-50 sqmm.	PCC	18.23
		33 KV Khol	11 KV Khol DS	Rabbit-50 sqmm.	PCC	5.01
		33 KV Khol	11 KV Mandola/Bohka DS	Rabbit-50 sqmm.	PCC	10.76
		33 KV Khol	11 KV Dhani Kolana DS	Rabbit-50 sqmm.	PCC	9.84
		33 KV Khol	11 KV Nangal Jamalpur AP	Rabbit-50 sqmm.	PCC	19.9
		33 KV Khol	11 KV Bohka AP	Rabbit-50 sqmm.	PCC	18.12
		33 KV Khol	11 KV Khol AP	Rabbit-50 sqmm.	PCC	22.56
		33 KV Khol	11 KV Mandola AP	Rabbit-50 sqmm.	PCC	18.23
		33 KV Khol	11 KV Khol DS	Rabbit-50 sqmm.	PCC	5.01
		33 KV Khol	11 KV Mandola/Bohka DS	Rabbit-50 sqmm.	PCC	10.76
		33 KV Khol	11 KV Dhani Kolana DS	Rabbit-50 sqmm.	PCC	9.84



## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		33 KV Ahrod	11 KV Ahrod DS	Rabbit-50 sqmm.	PCC	29.98
		33 KV Ahrod	11 KV Nangle Jamalpur AP	Weasel-30 sqmm.	PCC	18.08
		33 KV Ahrod	11 KV Uncha AP	Weasel-30 sqmm.	PCC	23.47
		33 KV Ahrod	11 KV Bas Duda AP	Weasel-30 sqmm.	PCC	16.08
		33 KV Ahrod	11 KV Ahrod DS	Rabbit-50 sqmm.	PCC	29.98
		33 KV Ahrod	11 KV Nangle Jamalpur AP	Weasel-30 sqmm.	PCC	18.08
		33 KV Ahrod	11 KV Uncha AP	Weasel-30 sqmm.	PCC	23.47
		33 KV Ahrod	11 KV Bas Duda AP	Weasel-30 sqmm.	PCC	16.08
		132 KV Buroli	11 KV Dhawana AP	Rabbit-50 sqmm.	PCC	20.87
		132 KV Buroli	11 KV Masit AP	Rabbit-50 sqmm.	PCC	24.22
		132 KV Buroli	11 KV Kahari AP	Rabbit-50 sqmm.	PCC	17.21
		132 KV Buroli	11 KV Gumina AP	Rabbit-50 sqmm.	PCC	20.09
		132 KV Buroli	11 KV Khaleta AP	Rabbit-50 sqmm.	PCC	24.93
		132 KV Buroli	11 KV Siha AP	Rabbit-50 sqmm.	PCC	18.6
		132 KV Buroli	11 KV Aulant AP	Rabbit-50 sqmm.	PCC	21.84
		132 KV Buroli	11 KV Mundi DS	Rabbit-50 sqmm.	PCC	23.4
		132 KV Buroli	11 KV Kumrodha DS	Rabbit-50 sqmm.	PCC	14.1
		132 KV Buroli	11 KV Delhawas DS	Rabbit-50 sqmm.	PCC	14.5
		132 KV Buroli	11 KV Mayan DS	Rabbit-50 sqmm.	PCC	12.5
		132 KV Buroli	11 KV Luhana DS	Rabbit-50 sqmm.	PCC	13.1
		132 KV Buroli	11 KV Dhawana DS	Rabbit-50 sqmm.	PCC	9.84
		132 KV Buroli	11 KV Rampuri DS	Rabbit-50 sqmm.	PCC	11.8

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		132 KV Buroli	11 KV Dhawana AP	Rabbit-50 sqmm.	PCC	20.87
		132 KV Buroli	11 KV Masit AP	Rabbit-50 sqmm.	PCC	24.22
		132 KV Buroli	11 KV Kahari AP	Rabbit-50 sqmm.	PCC	17.21
		132 KV Buroli	11 KV Gumina AP	Rabbit-50 sqmm.	PCC	20.09
		132 KV Buroli	11 KV Khaleta AP	Rabbit-50 sqmm.	PCC	24.93
		132 KV Buroli	11 KV Siha AP	Rabbit-50 sqmm.	PCC	18.6
		132 KV Buroli	11 KV Aulant AP	Rabbit-50 sqmm.	PCC	21.84
		132 KV Buroli	11 KV Mundi DS	Rabbit-50 sqmm.	PCC	23.4
		132 KV Buroli	11 KV Kumrodha DS	Rabbit-50 sqmm.	PCC	14.1
		132 KV Buroli	11 KV Delhawas DS	Rabbit-50 sqmm.	PCC	14.5
		132 KV Buroli	11 KV Mayan DS	Rabbit-50 sqmm.	PCC	12.5
		132 KV Buroli	11 KV Luhana DS	Rabbit-50 sqmm.	PCC	13.1
		132 KV Buroli	11 KV Dhawana DS	Rabbit-50 sqmm.	PCC	9.84
		132 KV Buroli	11 KV Rampuri DS	Rabbit-50 sqmm.	PCC	11.8
		132 KV GOTHRA	11 KV Chitadungra AP	Rabbit-50 sqmm.	PCC	13.65
		132 KV GOTHRA	11 KV Khor AP	Rabbit-50 sqmm.	PCC	17.33
		132 KV GOTHRA	11 KV Gumina AP-II	Rabbit-50 sqmm.	PCC	19.98
		132 KV GOTHRA	11 KV Punsika AP	Rabbit-50 sqmm.	PCC	13.13
		132 KV GOTHRA	11 Gothra AP	Rabbit-50 sqmm.	PCC	18.4
		132 KV GOTHRA	11 KV Balwari AP	Rabbit-50 sqmm.	PCC	22.98
		132 KV GOTHRA	11 KV Kund AP	Rabbit-50 sqmm.	PCC	22.08
		132 KV GOTHRA	11 KV Dhani Manethi AP	Rabbit-50 sqmm.	PCC	20.06

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		132 KV GOTHRA	11 KV Kundal AP	Rabbit-50 sqmm.	PCC	22.68
		132 KV GOTHRA	11 KV Bhandor DS	Rabbit-50 sqmm.	PCC	19.98
		132 KV GOTHRA	11 KV Pali DS	Rabbit-50 sqmm.	PCC	15.25
		132 KV GOTHRA	11 KV Thothwal DS	Rabbit-50 sqmm.	PCC	18.78
		132 KV GOTHRA	11 KV Sundroj DS	Rabbit-50 sqmm.	PCC	20.8
		132 KV GOTHRA	11 KV Nandha DS	Rabbit-50 sqmm.	PCC	21.63
4	Nahar (P)	33 KV Jharoda	Nahar II AP	Rabbit-50 sqmm.	PCC	10
		33 KV Jharoda	Jharoda AP	Rabbit-50 sqmm.	PCC	11
		33 KV Jharoda	Gamri DS	Rabbit-50 sqmm.	PCC	15
		33 KV Jharoda	Lissan DS	Rabbit-50 sqmm.	PCC	13.1
		33 KV Jharoda	Nangal Kheri AP	Weasel-30 sqmm.	PCC	12
		33 KV Jharoda	Lissan AP	Rabbit-50 sqmm.	PCC	13.4
		33 KV Jharoda	Dakhora DS	Rabbit-50 sqmm.	PCC	17
		33 KV Behrampur	Surkhpur DS	Rabbit-50 sqmm.	PCC	20
		33 KV Behrampur	Rattanthal AP	Rabbit-50 sqmm.	PCC	7
		33 KV Behrampur	Rattanthal DS	Rabbit-50 sqmm.	PCC	24
		33 KV Juddi (MC-I)	Irrigation	Racon-80 sqmm.	PCC	0.02
		33 KV MC-II Bishowa	Irrigation	Racon-80 sqmm.	PCC	0.02
		33 KV Bishowa	Mumtajpur AP	Rabbit-50 sqmm.	PCC	12
		33 KV Bishowa	Bishowa AP	Rabbit-50 sqmm.	PCC	3
		33 KV Bishowa	Jhorli AP	Weasel-30 sqmm.	PCC	4
		33 KV Bishowa	Bisowa DS	Rabbit-50 sqmm.	PCC	5

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		33 KV Bishowa	Garhi DS	Weasel-30 sqmm.	PCC	22
		33 KV Bishowa	Bharangi DS	Weasel-30 sqmm.	PCC	19
		33 KV Bishowa	Bawwa AP	Weasel-30 sqmm.	PCC	18
		33 KV Bishowa	Karoli Ds	Weasel-30 sqmm.	PCC	15
		33 KV JC-I Gudiyani	Gudiyani-II AP	Rabbit-50 sqmm.	PCC	17
		33 KV JC-I Gudiyani	Murlipur AP	Rabbit-50 sqmm.	PCC	8
		33 KV JC-I Gudiyani	Bhuriwas DS	Weasel-30 sqmm.	PCC	15
		132 KV Kosli	Nathera AP	Weasel-30 sqmm.	PCC	9
		132 KV Kosli	Tumna AP	Weasel-30 sqmm.	PCC	10
		132 KV Kosli	Nahar-1 AP	Weasel-30 sqmm.	PCC	13
		132 KV Kosli	Jakhala AP	Weasel-30 sqmm.	PCC	17
		132 KV Kosli	Jhall DS	Weasel-30 sqmm.	PCC	10
		132 KV Kosli	Gudiyani DS	Weasel-30 sqmm.	PCC	10
		132 KV Kosli	Kosli DS	Weasel-30 sqmm.	PCC	12
5	Rewari	33 KV Kaluwas	Nangal pathani AP	Weasel-30 sqmm.	PCC	47.3
		33 KV Kaluwas	Haluhera DS	Rabbit-50 sqmm.	PCC	34.8
		33 KV Kaluwas	Biharipur DS	Rabbit-50 sqmm.	PCC	38.4
		33 KV Kaluwas	Balawas AP	Weasel-30 sqmm.	PCC	47.9
		33 KV Kaluwas	Kaluwas DS	Rabbit-50 sqmm.	PCC	3.1
		33 KV Kakoria	Kakoria DS	Rabbit-50 sqmm.	PCC	9
		33 KV Kakoria	Naya Gaon AP	Weasel-30 sqmm.	PCC	8
		33 KV Kakoria	Janti DS	Raccon-80 sqmm.	PCC	5

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		33 KV Kakoria	Jat Bhurthal DS	Rabbit-50 sqmm.	PCC	4.2
		33 KV Kakoria	Dohki AP	Weasel-30 sqmm.	PCC	47
		33 KV JC-IV	Bithwana AP	Weasel-30 sqmm.	PCC	24.8
		33 KV JC-IV	Bhawari DS	Rabbit-50 sqmm.	PCC	24
		33 KV JC-IV	Sangwari AP	Weasel-30 sqmm.	PCC	23
		33 KV JC-IV	Salawas AP	Weasel-30 sqmm.	PCC	24
		33 KV JC-IV	Ladhuwas Gujjar DS	Rabbit-50 sqmm.	PCC	23.2
		33 KV Bharawas	Jatuwas AP	Rabbit-50 sqmm.	PCC	11.03
		33 KV Bharawas	Bithwana DS	Rabbit-50 sqmm.	PCC	9.45
		33 KV Bharawas	Kanuka AP	Rabbit-50 sqmm.	PCC	23.13
		33 KV Bharawas	Rajgarh AP	Rabbit-50 sqmm.	PCC	28.4
		33 KV Bharawas	Balawas Jat AP	Rabbit-50 sqmm.	PCC	18.8
		33 KV Bharawas	Dharan DS	Rabbit-50 sqmm.	PCC	21.45
		33 KV Bharawas	Badhrana DS	Rabbit-50 sqmm.	PCC	19.2
		33 KV Jonawas	Massani AP	Weasel-30 sqmm.	PCC	48
		33 KV Jonawas	Meerapur AP	Rabbit-50 sqmm.	PCC	42
		33 KV Jonawas	Surajpura AP	Rabbit-50 sqmm.	PCC	32
		33 KV Jonawas	Rojka DS	Rabbit-50 sqmm.	PCC	45
		33 KV Jonawas	Ramgaeh DS	Rabbit-50 sqmm.	PCC	28
		33 KV Jarthal	Bolni AP	Rabbit-50 sqmm.	PCC	52
		33 KV Jarthal	Jarthal AP	Rabbit-50 sqmm.	PCC	38
		33 KV Jarthal	Nikhri AP	Rabbit-50 sqmm.	PCC	22

## Districtwise Details of Existing 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Substation	Name of Feeder	Conductor Name	Pole Type	Length(kms.)
1	2	3	4	5	6	7
		33 KV Jarthal	Raliawas DS	Rabbit-50 sqmm.	PCC	34
		220 KV Rewari	Jant DS	Rabbit-50 sqmm.	PCC	5.18
		220 KV Rewari	Bikaner AP	Weasel-30 sqmm.	PCC	33.17
		220 KV Rewari	Ghasera DS	Rabbit-50 sqmm.	PCC	30
		66 KV Dharuhera	Pipaki AP	Rabbit-50 sqmm.	PCC	47
		66 KV Dharuhera	Maheshwari AP	Rabbit-50 sqmm.	PCC	15
		66 KV Dharuhera	Bhatsana AP	Weasel-30 sqmm.	PCC	80
		66 KV Dharuhera	Khatwali AP	Weasel-30 sqmm.	PCC	49
		66 KV Dharuhera	Akera AP	Weasel-30 sqmm.	PCC	45
		66 KV Dharuhera	Kapriwas AP	Weasel-30 sqmm.	PCC	47
		66 KV Dharuhera	NRP Bass DS	Rabbit-50 sqmm.	PCC	24
		66 KV Dharuhera	Joniawas DS	Rabbit-50 sqmm.	PCC	28
		66 KV Baliar Kalan	Hanaska DS	Rabbit-50 sqmm.	PCC	22
		66 KV Baliar Kalan	Khijuri AP	Weasel-30 sqmm.	PCC	28
		66 KV Baliar Kalan	Baliar Khurd AP	Weasel-30 sqmm.	PCC	22
<b>Total</b>						<b>3816.04</b>

## Augmentation of 11 KV or 22 KV Line for Supplementary DPR

State : HARYANA  
District : Rewari

1	Bawal	132 KV Old Bawal	Pawati AP		Weasel-30 sqmm.		PCC	70	3
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	6.08	S STN	GAS GODAM CKT	6	Rabbit-50 sqmm.	3.15	Racson-80 sqmm.	32
	Section 2	3.2	KHERI DALU SINGH	CKT SW BANDH WALA	18	Weasel-30 sqmm.	0	Racson-80 sqmm.	20
	Section 3	1.2	BANDH WALA	UJJAR KHERI	4.5	Weasel-30 sqmm.	0	Racson-80 sqmm.	6
4	Bawal	132 KV Old Bawal	Tankari AP		Weasel-30 sqmm.		PCC	70	3
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	3.8	SUB STN	MAJRA VILL	12	Rabbit-50 sqmm.	0	Racson-80 sqmm.	10
	Section 2	3.81	VILL MAJRA	VILL BHARANGI	15	Weasel-30 sqmm.	0	Racson-80 sqmm.	17
	Section 3	1	BHARANGI	BALAWAS	6.6	Weasel-30 sqmm.	0	Racson-80 sqmm.	16
7	Jatusana	33 KV Khushpura	11 KV Baldhan AP		Weasel-30 sqmm.		PCC	70	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	1.2	KHUSHPURA	BALDHAN	9	Weasel-30 sqmm.	0.86	Racson-80 sqmm.	30
8	Jatusana	33 KV Khushpura	11 KV Khuspura AP		Weasel-30 sqmm.		PCC	70	0
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	1.2	SUBSTN	KHUSHPURA VILL	1	Weasel-30 sqmm.	0	Racson-80 sqmm.	10
9	Jatusana	33 KV Khushpura	11 KV Daroli AP		Weasel-30 sqmm.		PCC	70	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	3.2	KHUSHPURA	DAROLI	6	Weasel-30 sqmm.	2.3	Racson-80 sqmm.	15

## Augmentation of 11 KV or 22 KV Line for Supplementary DPR

State : HARYANA  
District : Rewari

10	Khol At Rewari	33 KV Khol	11 KV Nangal Jamalpur AP		Rabbit-50 sqmm.		PCC	70	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	0.63	T OFF SURAJ BHAN	63 KVA ROHTASH	6.1	Squirrel-20 sqmm.	0.59	Raccon-80 sqmm.	5
11	Khol At Rewari	132 KV Buroli	11 KV Aulant AP		Rabbit-50 sqmm.		PCC	70	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	0.57	WATER SUPPLY T OFF	63 KVA GHISA RAM	4.5	Squirrel-20 sqmm.	0.53	Raccon-80 sqmm.	10
12	Nahar (P)	132 KV Kosli	Jhall DS		Weasel-30 sqmm.		PCC	50	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	1.6	132 KV KOSLI	DHANI SUDHRANA	2	Weasel-30 sqmm.	0	Raccon-80 sqmm.	7
13	Nahar (P)	132 KV Kosli	Gudiyani DS		Weasel-30 sqmm.		PCC	50	2
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	6.8	132 KV KOSLI	NATHERA	2	Weasel-30 sqmm.	4.89	Raccon-80 sqmm.	25
	Section 2	3.3	NATHERA	KANHARWAS	6	Weasel-30 sqmm.	0	Raccon-80 sqmm.	30
15	Nahar (P)	132 KV Kosli	Kosli DS		Weasel-30 sqmm.		PCC	50	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	4.6	132 kv kosli	village chawwa	5	Weasel-30 sqmm.	0	Raccon-80 sqmm.	40
16	Rewari	33 KV Bharawas	Jatuwas AP		Rabbit-50 sqmm.		PCC	70	1
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)



## Augmentation of 11 KV or 22 KV Line for Supplementary DPR

State : HARYANA  
District : Rewari

	Section 1	0.5	BITHWANA CKT	TF 5 SUNDER LAL	2.6	Weasel-30 sqmm.	0	Racson-80 sqmm.	12
17	<b>Rewari</b>	<b>33 KV Bharawas</b>	<b>Kanuka AP</b>		<b>Rabbit-50 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>1</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	0.7	PRAGPURA	ARAM NAGAR	11.5	Weasel-30 sqmm.	0.5	Racson-80 sqmm.	8
18	<b>Rewari</b>	<b>33 KV Bharawas</b>	<b>Rajgarh AP</b>		<b>Rabbit-50 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>1</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	0.8	DHARAN SW	RAJGARH DHANI	6	Weasel-30 sqmm.	0	Racson-80 sqmm.	7
19	<b>Rewari</b>	<b>33 KV Bharawas</b>	<b>Balawas Jat AP</b>		<b>Rabbit-50 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>1</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	0.54	SULKHA	GOBINPUR BASS	3.7	Weasel-30 sqmm.	0	Racson-80 sqmm.	6
20	<b>Rewari</b>	<b>66 KV Dharuhera</b>	<b>Pipaki AP</b>		<b>Rabbit-50 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>1</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	2.8	S STN	NRP BASS	21	Rabbit-50 sqmm.	0.93	Racson-80 sqmm.	18
21	<b>Rewari</b>	<b>66 KV Dharuhera</b>	<b>Bhatsana AP</b>		<b>Weasel-30 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>0</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	3.5	Jhil Ckt.	Bhatsana ckt.	9	Weasel-30 sqmm.	0	Racson-80 sqmm.	18
22	<b>Rewari</b>	<b>66 KV Dharuhera</b>	<b>Khatwali AP</b>		<b>Weasel-30 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>0</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)

## Augmentation of 11 KV or 22 KV Line for Supplementary DPR

State : HARYANA  
District : Rewari

	Section 1	3.5	Kutabi Ckt.	Mau	4.5	Squirrel-20 sqmm.	0	Racson-80 sqmm.	18
23	<b>Rewari</b>	<b>66 KV Dharuhera</b>	<b>Akera AP</b>		<b>Weasel-30 sqmm.</b>		<b>PCC</b>	<b>70</b>	<b>1</b>
	Section	Existing Load in Overloaded Section(In MW)	Section Start From	Section Upto	Length(In Kms.)	Existing Conductor	%age Loading	Renovated Conductor	Intermediatory pole(Nos.)
	Section 1	2.5	Akera	Ashok Vihar	4.5	Squirrel-20 sqmm.	2.34	Racson-80 sqmm.	13

# **SAGY**

State : HARYANA

District : Rewari

## Block-wise coverage of villages for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Total no. of villages as per census	Villages proposed under present scheme	Habitations proposed under present scheme	Total RHhs (Incl. BPL Hhs)	No of RHhs already electrified upto 31.03.15	% Electrification as on 31.03.15	RHhs(Incl. BPL) Already sanctioned and under execution in erstwhile RGGVY/State/ other schemes	Balance to be electrified	RHhs Proposed under present scheme	BPL Proposed under present scheme
1	2	3	4	5	6	7	8	9	10	11	12
1	Bawal	1	1	1	704	686	97.44	0	18	18	0
2	Jatusana	0	0	0	0	0	0	0	0	0	0
3	Khol At Rewari	0	0	0	0	0	0	0	0	0	0
4	Nahar (P)	0	0	0	0	0	0	0	0	0	0
5	Rewari	0	0	0	0	0	0	0	0	0	0
<b>Total</b>		<b>1</b>	<b>1</b>	<b>1</b>	<b>704</b>	<b>686</b>	<b>97.44</b>	<b>0</b>	<b>18</b>	<b>18</b>	<b>0</b>

## Villagewise/Habitation wise coverage for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Total No. of RHhs	No of RHhs electrified as on 31.03.2015	Balance Nos. of RHH to be electrified as on 31.03.2015	Total BPL already sanctioned under execution in erstwhile RGGVY/State/Ce ntral Scheme as on 31/3/2015	No of RHhs proposed to be electrified including BPL	No of BPL Hhs proposed to be electrified
1	2	3	4	5	6	7	8	9	10	11
<b>Block :: Bawal</b>										
1	Bolni (164)	062654	BOLNI	062654-004	704	686	18	0	18	0
Total - Bawal					704	686	18	0	18	0
<b>Summary</b>										
<b>Bawal</b>					704	686	18	0	18	0
<b>Grand Total</b>					704	686	18	0	18	0

## Existing Habitation Wise Infrastructure for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Existing LT Networks (in Kms)				Existing Distribution Transformers (DT)	Total (DT)
					Overhead	AB cable	Overhead	AB cable		
1	2	3	4	5	6	7	8	9	10	11
<b>Block :: Bawal</b>										
1	Bolni (164)	062654	BOLNI	062654-004	0.5	0	5.4	1.3	20 * (25 KVA (3 Ph)) + 3 * (100 KVA (3 Ph	23
Total - Bawal					0.5	0	5.4	1.3		
<b>Summary</b>										
<b>Bawal</b>					0.5	0	5.4	1.3		
<b>Grand Total</b>					0.5	0	5.4	1.3		

## Village Wise/Habitation Proposed Works for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)				
1	2	3	4	5	6	7	8	9	10				
<b>Block :: Bawal</b>													
1	Bolni (164)	062654	BOLNI	062654-004	New 11 KV Line	11 KV Raccon Conductor	2.5	0	0				
						25 KVA (3 Ph)	0	8	0				
						63 KVA (3 Ph)	0	2	0				
									Capacity Augmntation of DTR	From Existing to 63 KVA	0	3	0
									Reconductoring of existing LT Overhead lines by following configuration	Raccoon (75sqmm) 3Ph-N (4W)	5.2	0	0
									Conversion of existing LT Overhead lines to ABC Cable	3X95+1X70	0.5	0	0
									New LT Line	Raccoon (75sqmm) 3Ph-N (4W)	1	0	0
					New ABC Line	3X95+1X70	0.12	0	0				
<b>Block Wise Summary</b>													
1	Bawal				New 11 KV Line	11 KV Raccon Conductor	2.5	0	0				
						25 KVA (3 Ph)	0	8	0				
						63 KVA (3 Ph)	0	2	0				
									Capacity Augmntation of DTR	From Existing to 63 KVA	0	3	0
									Reconductoring of existing LT Overhead lines by following configuration	Raccoon (75sqmm) 3Ph-N (4W)	5.2	0	0
									Conversion of existing LT Overhead lines to ABC Cable	3X95+1X70	0.5	0	0

## Village Wise/Habitation Proposed Works for Supplementary DPR

State : HARYANA  
District : Rewari

Sl.No. (Vill.)	Name of Village (all villages as per census)	Census Code (2011)	Name of Habitation including main villages	Habitation Code	Works Type	Item	Line Length(Kms)	DTR(Nos)	Earthing(Kms)
1	2	3	4	5	6	7	8	9	10
					New LT Line	Raccoon (75sqmm) 3Ph-N (4W)	1	0	0
					New ABC Line	3X95+1X70	0.12	0	0
<b>District Wise Summary</b>									
1	New 11 KV Line				11 KV Raccon Conductor		2.5	0	0
					25 KVA (3 Ph)		0	8	0
					63 KVA (3 Ph)		0	2	0
2	Capacity Augmntation of DTR				From Existing to 63 KVA		0	3	0
3	Reconductoring of existing LT Overhead lines by following configuration				Raccoon (75sqmm) 3Ph-N (4W)		5.2	0	0
4	Conversion of existing LT Overhead lines to ABC Cable				3X95+1X70		0.5	0	0
5	New LT Line				Raccoon (75sqmm) 3Ph-N (4W)		1	0	0
6	New ABC Line				3X95+1X70		0.12	0	0



## Details of New 11 KV or 22 KV Lines for Supplementary DPR

State : HARYANA  
District : Rewari

S.No.	Name of Block	Name of Emanating Substation	Name of feeder	Section of Feeder		Line Type	Length(k ms.)	Nos of Bay (If required)	Remarks	Line on ABC cable in Forest Area/Populated Area	Length of ABC cable (Kms.)
				From Location	To Location						
1	2	3	4	5	6	7	8	9	10	11	12
1	Bawal	33 KV JC-IV	BOLNI FEEDER DS	JC IV	BOLNI VILLAGE	PCC POLES WITH RABBIT CONDUCTOR	21	0			0
<b>Total</b>							<b>21</b>				<b>0</b>