

Damage Rate

(1) The position of transformers damaged during 07/2021 is given as under:-

Name of Circle	No. of Transformer installed	Transformers Damaged			% Damage rate excluding warranty	% Damage rate including warranty period
		Out of Warranty Period	Within warranty period	Total		
Faridabad	16938	145	20	165	0.86%	0.97%
Palwal	18512	167	166	333	0.90%	1.80%
Gurugram-1	17452	130	37	167	0.74%	0.96%
Gurugram-2	12133	74	28	102	0.61%	0.84%
Narnaul	22964	155	104	259	0.67%	1.13%
Rewari	23278	156	69	225	0.67%	0.97%
Bhiwani	44690	263	130	393	0.59%	0.88%
Hisar	26045	207	72	279	0.79%	1.07%
Fatehabad	40424	380	122	502	0.94%	1.24%
Sirsa	51107	447	165	612	0.87%	1.20%
Jind	34875	405	246	651	1.16%	1.87%
DHBVN	308418	2529	1159	3688	0.82%	1.20%

(2) The position of transformers damaged during 07/2020 is given as under:-

Name of Circle	No. of Transformer installed	Transformers Damaged			% Damage rate excluding warranty period	% Damage rate including warranty period
		Out of Warranty Period	Within warranty period	Total		
Faridabad	16256	105	23	128	0.65%	0.79%
Palwal	17955	144	118	262	0.80%	1.46%
Gurugram-1	17233	73	34	107	0.42%	0.62%
Gurugram-2	11852	65	29	94	0.55%	0.79%
Narnaul	21739	118	42	160	0.54%	0.74%
Rewari	22119	183	68	251	0.83%	1.13%
Bhiwani	43702	269	139	408	0.62%	0.93%
Hisar	25498	217	81	298	0.85%	1.17%
Fatehabad	39234	444	157	601	1.13%	1.53%
Sirsa	50427	424	146	570	0.84%	1.13%
Jind	34301	571	251	822	1.66%	2.40%
DHBVN	300316	2613	1088	3701	0.87%	1.23%

(3) The Cumulative position of transformers damaged for the year 2021-22 (upto 07/2021) is given as under:

Name of Circle	No. of Transformer installed	Transformers Damaged			% Damage rate excluding warranty	% Damage rate including warranty period
		Out of Warranty Period	Within warranty period	Total		
Faridabad	16938	480	60	540	2.83%	3.19%
Palwal	18512	536	399	935	2.90%	5.05%
Gurugram-1	17452	344	107	451	1.97%	2.58%
Gurugram-2	12133	268	101	369	2.21%	3.04%
Narnaul	22964	489	295	784	2.13%	3.41%
Rewari	23278	493	183	676	2.12%	2.90%
Bhiwani	44690	899	375	1274	2.01%	2.85%
Hisar	26045	549	197	746	2.11%	2.86%
Fatehabad	40424	1051	293	1344	2.60%	3.32%
Sirsa	51107	1490	450	1940	2.92%	3.80%
Jind	34875	1297	626	1923	3.72%	5.51%
DHBVN	308418	7896	3086	10982	2.56%	3.56%

(4) The Cumulative position of transformers damaged for the year 2020-21 (upto 07/2020) is given as under:

Name of Circle	No. of Transformer installed	Transformers Damaged			% Damage rate excluding warranty period	% Damage rate including warranty period
		Out of Warranty Period	Within warranty period	Total		
Faridabad	16256	364	76	440	2.24%	2.71%
Palwal	17955	489	318	807	2.72%	4.49%
Gurugram-1	17233	226	96	322	1.31%	1.87%
Gurugram-2	11852	169	81	250	1.43%	2.11%
Narnaul	21739	418	162	580	1.92%	2.67%
Rewari	22119	488	172	660	2.21%	2.98%
Bhiwani	43702	923	433	1356	2.11%	3.10%
Hisar	25498	691	283	974	2.71%	3.82%
Fatehabad	39234	1226	352	1578	3.12%	4.02%
Sirsa	50427	1406	402	1808	2.79%	3.59%
Jind	34301	1384	643	2027	4.03%	5.91%
DHBVN	300316	7784	3018	10802	2.59%	3.60%