

DAKSHIN HARYANA BIJLI VITRAN NIGAM

Instruction No.- 13 /2006/PD&C

From

The Chief Engineer/PD&C,
DHBVN, Hisar.

To

All C.E.s(OP) in DHBVNL.
All S.E.s(OP) in DHBVNL

Memo No.Ch-30/DD-169

Dated : 03.08.2006

Sub : Guidelines for laying of HVD System.

In continuation to this office instruction No. 10/2006/PD&C issued vide this office memo No. Ch-14/DD-169 dated 21.7.2006, it is further added that HVD system may not be laid in small villages/hamlets, where number of existing connections are less than 100 Nos. In such villages/hamlets, LT system may be replaced with ABC cable and the meters should be installed outside the houses in steel MCB. Proper connections from LT ABC cables be taken out with connectors.

**Chief Engineer/PD&C,
DHBVN, Hisar.**

Copy to the :

1. Sr.PS to M.D., DHBVNL, Hisar for kind information of the M.D. please.
2. Sr.PS to Director (OP)/Projects, DHBVNL, Hisar for kind information of the Directors.
3. Chief Engineer (MM), DHBVNL, Hisar.
4. G.M./Commercial, DHBVNL, Hisar.
5. S.E./Const. Circle, DHBVNL, Hisar.