

21

DAKSHIN HARYANA BIJLI VITRAN NIGAM

Instruction No:- 27/2006/PD&C

From

The Chief Engineer/P&D
DHBVN, Hisar.

To

- 1 All Chief Engineers (Operation)
- 2 All SEs 'Operation' Circle,
Under DHBVN

Memo No.Ch- ~~89~~ 90/DD-169

Dated : 20.11.06.

Sub : Releasing of HT T/Well connections on turnkey basis.

While issuing the NIT for releasing of HT T/Well connections on turnkey basis, it should be ensured that a compact unit of "DT Meter, MCCB (Moulded case circuit breaker) and LT capacitor" is also to be included in the scope of the work for installation of the same on every pole mounting S/stn Distribution transformer provided for releasing the connection to the consumer. The Technical Specifications of all these items i.e. Distribution T/Fs, D.T Meters, L.T. MCCB's and the L.T. static capacitors has already been issued and are available on web site of DHBVN. Further it may also be ensured that these DT's having all the above noted provisions should be an integral part of the DT's.

These instructions are issued for strict compliance in the field.

CC :


Chief Engineer/P&D,
DHBVN, Hisar


1. SPS to M.D., DHBVN, Hisar for kind information of the M.D. please.
2. SPS to Director (Project) for kind information of Director please.
3. SPS to Director (Operation) for kind information of Director please.