

DAKSHIN HARYANA BIJLI VITRAN NIGAM

Sales Circular No. D-28/2019

From

Superintending Engineer /Commercial,  
DHBVN Hisar

To

All CEs/SEs/XENs/SDOs/OP,  
JES-I Incharge Sub office in DHBVN

**Memo No.Ch-28/SE/C/R-16/10/2006/F-9 Dated: 11/07/2019**


**Subject: Connection of new consumer on existing independent feeder.**

The existing instructions with regard to independent feeder have been provisioned in Sales Circular No. D-23/2016 and D-28/2016 as per HERC regulation No. HERC/34/2016 dated 11.7.2016 on power to recover expenditure. As per the provisions of clause 4.8.2(vii) of the regulations, the consent of original consumer is not required when the load is less than 70% of the rated capacity of the feeder. Since the maximum capacity allowed is 5 MVA on 11 KV feeder and 25 MVA on 33 KV level and keeping in view the fact that the size of the conductor/ cable provided is not exactly equivalent to the existing load, therefore for proper implementation of the regulations, following clarifications are hereby given:-

- a) For independent feeder, at 11 KV level, the maximum capacity to be considered for feeder is 5000 KVA and 70% would be 3500 KVA. Therefore when the contract demand of the consumers already connected on independent feeder is equal to or greater than 3500 KVA irrespective of size of conductor / cable, for new addition the consent of original consumer must be taken before sanctioning the connectivity of new consumer on existing independent feeder. Also, when on adding the load of new consumer the combined load exceeds 3500 KVA, in that case also the consent of original consumers be taken.
- b) For independent feeder, at 33 KV level, the maximum capacity to be considered for feeder is 25 MVA and 70% would be 17.5 MVA. Therefore, when the contract demand of the consumers already connected on independent feeder is equal to or greater than 17.5 MVA irrespective of size of cable/ conductor, for new addition the consent of original consumer must be taken before sanctioning the connectivity of new consumer on existing independent feeder. Also, when on adding the load of new consumer the combined load exceeds 17.5 MVA in that case also the consent of original consumer be taken.

The sales circulars No. D-23/2016 and D-28/2016 are amended to the above extent.

The above instructions may be brought to the notice of all concerned for meticulous compliance

  
**Superintending Engineer/Commercial,  
DHBVN Hisar**