

**DAKSHIN HARYANA BIJLI VITRAN NIGAM**

**SALES INSTRUCTION No. 14/2007**

From

The General Manager/Commercial,  
DHBVNL, Hisar

To

All CGMs (OP)/GMs (OP)/DGMs (OP)/AGMs (OP),  
SFM-I Incharge Sub Office in DHBVNL

Memo No. Ch-14//SE/Comml/R-17/44/2006 Dated: - 1.3.2007

**Subject:- Installation of Earth Leakage Circuit Breaker (ELCB)**

The earth leakage at the consumer premises is one of the main reasons for electrical mishaps, which are required to be avoided at all cost.

As per section 61-A of the Indian Electricity Rules, 1956, it is mandatory for all consumers having electricity load of five or more than five KW, to have an ELCB installed in their houses.

With a view to ensure customer safety, the Nigam has decided that all the consumers shall install the earth leakage Circuit Breaker (ELCB). SDO Operation will ensure that all the consumers having load of five KW or more than five KW, shall install the Earth Leakage Circuit Breaker (ELCB) at their premises.

The above instructions may be brought to the notice of all concerned for meticulous and careful compliance.

**-sd-**

**G.M./Commercial,  
For CGM/Commercial, DHBVN, Hisar.**