

**DAKSHIN HARYANA BIJLI VITRAN NIGAM**  
Vidyut Sadan, Vidyut Nagar, Hisar-125005

**SALES INSTRUCTION NO. 2/2007**

From

GM/Commercial,  
DHBVN, Hisar.

To

All CEs/SEs (OP)/Xens/SDOs (OP)  
JE-I I/c Sub offices in DHBVNL

Memo No. Ch-2/SE/Comml./R-17-48/2007      Dated: 17/1/2007

**Subject: -    Use of Distribution Transformer by HT Industrial Applicants.**

It has been observed that no load losses in distribution transformers with Amorphous Core is very less in comparison to conventional core transformer.

In order to conserve electricity, Nigam has decided that all new applicants of HT Industrial categories should be asked to install Amorphous Core Distribution transformer with inbuilt MCCB for self protection of transformer only.

The revised instructions shall be applicable on the applications received after the date of issue of this Sales Instructions.

The above instructions should be got noted from all concerned for meticulous compliance.

**-sd-**  
**SE/Commercial,**  
**For GM/Commercial, DHBVN, Hisar.**