

DAKSHIN HARYANA BIJLI VITRAN NIGAM**Sales Instruction No. 15/2011**

From

CE/Commercial,
DHBVN, Hisar.

To

All CEs/SEs/XENs/SDOs/OP,
JEs-I, Incharge Sub office, in DHBVN.**Memo No. Ch. 15/SE/C-R-16/94/2004/F-5****Dated : 29/6/2011****Subject: Guidelines for release of power connection under modified HVDS Scheme.**

This is in continuation of Sales Instruction No. 10/2011 vide which guidelines for release of power connection under modified HVDS scheme was issued.

The Management has reviewed the matter and decided as under:-

1. To release the tubewell connections under modified HVDS Scheme as per Sales Circular No. D-12/2011 & Sales Instruction No. 10/2011, process for its execution may be followed as per time schedule given below:-

Sr. No.	Action to be taken	Duration
I	Issue notices for seeking consent / option	10 days from issue date of SI No. 14/2011
II	Receipt / Collection of consent/options	Next 15 days
III	Site verification, preparation of estimate & issuance of Demand Notices	Next 30 days
IV	Compliance of Demand Notices	Next 3 Months
V	To issue SCO & Work order etc.	Requisites received during 1 st Month
VI	To issue SCO & Work order etc.	Requisites received during 2 nd Months
VII	To issue SCO & Work order etc.	Requisites received during 3 rd Months.

2. Expression of Interest (EOI) for empanelment of contractors to carry out the work on turnkey basis for release of tubewell connections is being floated by the office of CE/P&D. The respective SE/OP will issue work order on such empanelled contractor & as such no separate tender enquiry will be floated.
3. The length of LT line required for release of connection shall be restricted to 900 Ft. for option a & b of the above said instruction and each span of HT /LT should not be more than 70 Meter.
4. Clause (b) of Sales Instruction No. 10/2011 may be read as :-

“Upto three connection per transformer where the consumer pays Rs. 30,000/- and Rs. 7000/- per span”

The ibid Sales Circular & Sales Instruction are amended to the above extent please.

The above instructions should be brought to the notice of all concerned for careful and meticulous compliance.

**SE/Commercial,
for CE/Commercial,
DHBVN, Hisar.**