

DAKSHIN HARYANA BIJLI VITRAN NIGAM
Sales Instruction No. 19/2015

From

CE/Commercial,
DHBVN, Hisar.

To

All CEs/SEs/XENs/SDOs/OP,
JEs-I, Incharge Sub office, in DHBVN.

Memo No. Ch-19/SE/Comml./R-16/Loose-699 **Dated: 14/10/2015**

Sub:- Conversion of feeding source from Rural to Urban mode viz-a-viz redefining of MC limits.


Please refer to S.I. No. 17/2015 dated 24/9/2015 vide which guidelines were circulated regarding providing Urban mode supply to the areas (villages/town/localities) falling within the redefined Municipal limit. Now, the amended guidelines in compliance to the decision of MDs Coordination Committee meeting held on 18.08.2015 are as under please.

- a. The expenditure relating to the Distribution system shall be borne by the respective distribution utility and expenditure relating to transmission system shall be borne by the HVPNL. The expenditure in this regard be recovered through Capex.
- b. All the defective meters / electro mechanical meters shall be replaced with electronic meters and installed outside the premises.
- c. HVDS /LVDS shall be provided as required.
- d. The AT&C losses of the area should not be more than 20%.
- e. The beneficiaries / residents would themselves clear the arrears / defaulting amount.
- f. There should be electric connection in all the households.
- g. All the meters would be relocated outside the premises.
- h. No tube well connection would be permitted on the feeder.
- i. HT meter shall be provided to monitor the AT&C losses for every village/feeder.

The supply on Urban mode shall commence after completion of aforesaid works, especially relocation of meters outside the houses, installation of AB cables and energy accounting measures.

S.I. No. 17/2015 is superseded.

The above instructions may be brought to the notice of all concerned for strict and meticulous compliance


CE/Commercial
DHBVN, Hisar