

DHBVN HARYANA BIJLI VITRAN NIGAM

Sales Instruction No. 07/2017

From

CE/Commercial
DHBVN, Hisar,

To

All CEs/SEs/ XENs/SDOs/OP,
JEs-I Incharge Sub-office in DHBVN

Memo No.Ch-07/SE/Comml./R-17/433/2017


Dated: 04/12/2017

Subject:- Release of connection.

Presently, 11 KV industrial connections from 33 KV and above S/Stns. in Discoms are released as per the maximum demand recorded on the power transformer, feeder and distribution transformer etc.

To release the DS/NDS and other category connections upto 20 KW in order to avoid overloading on the system and damage to costly equipments, the matter has been considered and it has been decided that augmentation of transformer etc. must be taken in hand as and when, power transformer is loaded upto 70%. However, new industrial connections shall be released upto 90% loading of the transformer.

The above instructions should be brought to the notice of all concerned for careful and meticulous compliance.


**SE/Commercial,
For CE/Commercial,
DHBVN, Hisar.**