



Table of Contents

Contents

NOTICE INVITING TENDERS.....	3
Instructions to bidder on Electronic Tendering System.....	6
NECESSARY INSTRUCTION/TERMS & CONDITIONS FOR THE BIDDER	11
Pre-qualification conditions.....	15
TENDERFORM	18
(Part-I, General Conditions of Contract).....	19
(Part-II, Particular Conditions of Contract)	32
TECHNICALSPECIFICATION.....	38
SCHEDULE OF DELIVERIES.....	74
Format for raising Inspection Call by the Vendor / Supplier	75
SCHEDULE OF DEVIATIONS	76
BANKGUARANTEEPROFORMA.....	77
Format of Affidavit for last completed Purchase Order	79
DULY ATTESTED BY CHARTERED ACCOUNTANT	80
Undertaking	81
AFFIDAVIT FOR NON BLACKLISTING	82
Price Schedule as provided in the Electronic tender at website	83



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BIJLI VITRAN NIGAM



BIDDING DOCUMENTS

FOR PROCUREMENT

OF

3.5 & 5MVA,33/3.3 KV POWER TRANSFORMERS



NOTICE INVITING TENDERS

(Only through e-procurement)

NOTICE INVITED TENDER No. /DH/MM/XEN/MM-

DATED: . . .20

Offers are invited for procurement of following material on Variable Price & 'FOR' destination basis anywhere in Haryana, as per details given below:-

Description of item	Total Quantity	Estimated cost
Three phase, 50 Hz, 33/3.3 KV Step down, outdoor ONAN Power Transformers of following capacity complete with all accessories/fittings and conforming to Nigam's Technical Specification No. CSC-78/R-I/DH/UH/P&D/2015-16 (with amendment) and relevant ISS with latest amendments. i) 3.5 MVA ii) 5MVA		
Date of start	Last date of submission	Opening date of part-I

Tender documents having detailed terms and conditions can be seen/downloaded from the portal <https://haryanaeprocurement.gov.in> and www.dhbvn.org.in/web/portal/tenders

Superintending Engineer/MM
For CE/MM, DHBVN, Hisar

For Publication only



Schedule-A

DAKSHIN HARYANA BIJLI VITRAN NIGAM

NOTICE INVITING TENDER

(Only through e-procurement)

SCHEDULE OF TENDER (SOT)

a) NOTICE INVITING TENDER (NIT) NO.	/DH/MM DATED: - . . .20				
b) e-tender no.					
c) MODE OF TENDER	e-Procurement System (Online Part I - Techno-Commercial Bid and Part II - Price Bid Through https://haryanaeprocurement.gov.in of Nextenders India Pvt. Ltd.)				
d) Tender Enquiry No. under NIT No.	QD-				
e) Date of NIT available to parties to download	. . .				
f) i) Earnest Money Deposit ii) Tender Fees (Non-refundable)	2% of estimated cost subject to max. Rs. 2 Lacs <table border="1"><thead><tr><th>For all the bidders except Haryana based MSMEs and KVI units (Rs.)</th><th>For the Haryana based MSMEs and KVI units (Rs.)</th></tr></thead><tbody><tr><td>5000/-</td><td>1000/-</td></tr></tbody></table>	For all the bidders except Haryana based MSMEs and KVI units (Rs.)	For the Haryana based MSMEs and KVI units (Rs.)	5000/-	1000/-
For all the bidders except Haryana based MSMEs and KVI units (Rs.)	For the Haryana based MSMEs and KVI units (Rs.)				
5000/-	1000/-				
iii) E-Service Fee (Non-refundable)	Rs. 1000/-				

Offer are invited for procurement of following material on 'Variable' & 'FOR' destination rates basis anywhere in Haryana, as per details given below.

SCHEDULE OF MATERIAL: -

T.E. no.	Description of material	Quantity (in Nos.)		
		DHBVN	UHBVN	Total
QD-	Three phase, 50 Hz, 33/3.3 KV Step down, outdoor ONAN Power Transformers of following capacity complete with all accessories/fittings and conforming to Nigam's Technical Specification No. CSC-78/R-I/DH/UH/P&D/2015-16 (with amendment) and relevant ISS with latest amendments. i) 3.5 MVA ii) 5MVA			

1) Only those tenders will be considered who fulfill the **Pre Qualification Conditions** mentioned in the tender documents (as elaborated in **Annexure-II**)



- 2) Only those tender shall be considered who deposit the earnest money and tender cost & E-Service Fee by due date.

Information Regarding Online Payment of Tender Document, eService & EMD Fee.

- 1) The Bidders can download the tender documents from the Portal: <https://haryanaeprocurement.gov.in>. The Bidders shall have to pay for the Tender documents, EMD Fees & e-Service Fee online by using the service of secure electronic payment gateway. This secure electronic payment gateway is an online interface between suppliers and online payment authorization networks. The Payment for Tender Document Fee and e-Service Fee can be made by eligible bidders/suppliers online directly through Debit Cards & Internet Banking Accounts and the Payment for EMD can be made online directly through RTGS / NEFT.
- 2) If the tenders are cancelled or recalled on any grounds, the tender document fees & e-service fee will not be refunded to the agency.
- 3) The detailed procedure/instructions to bid on Electronic Tendering System are at **Annexure-I**.
- 4) **For any clarification regarding bid preparation and bid submission, please contact: M/s Nextenders (India) Pvt. Ltd.**
O/o. DS&DHaryana, SCO-09, II Ind Floor, Sector-16, Panchkula – 134108
E -mail: Chandigarh@nextenders.com Help Desk: 1800-180-2097 (**Toll Free Number**)
- 5) The Tenderers can submit their tender documents (Online) as per the dates mentioned in the key dates schedule:

Key Dates schedule:

Sr. No.	Department Stage/Activity	Tenderer's Stage	Start date and time	Expiry date and time
1.	-	Downloading of Tender Documents & Bid Preparation & submission	. . . at 10:00 Hours	. . . at 13:00 Hours
		Pre-bid meeting (If applicable)	. . .20 at 11:00 Hrs.	
2	Manual submission of technical documents (Within 4 days from the opening of part-I)		-	. . .20 at 13:00 Hours
3	Technical Opening (Part-I)	-	. . .20 at 15:00 Hours	---
4	Short-listing of Technical bids & Opening of Financial Bid			Will be intimated to the firms on their E-mail ids

Superintending Engineer/MM
For CE/MM, DHBVN, Hisar

For Uploading on website only



Annexure-I

Instructions to bidder on Electronic Tendering System

These conditions will over-rule the conditions stated in the tender documents, wherever relevant and applicable.

1. **Registration of bidders on eProcurement Portal:-**
All the bidders intending to participate in the tenders processed online are required to get registered on the centralized e - Procurement Portal i.e. <https://haryanaeprocurement.gov.in>. Please visit the website for more details.
2. **Obtaining a Digital Certificate:**
 - 2.1 The Bids submitted online should be encrypted and signed electronically with a Digital Certificate to establish the identity of the bidder bidding online. These Digital Certificates are issued by an Approved Certifying Authority, by the Controller of Certifying Authorities, Government of India.
 - 2.2 A Digital Certificate is issued upon receipt of mandatory identity (i.e. Applicant's PAN Card) and Address proofs and verification form duly attested by the Bank Manager / Post Master / Gazetted Officer. Only upon the receipt of the required documents, a digital certificate can be issued. For more details please visit the website – <https://haryanaeprocurement.gov.in>.
 - 2.3 The bidders may obtain Class-II or III digital signature certificate from any Certifying Authority or Sub-certifying Authority authorized by the Controller of Certifying Authorities or may obtain information and application format and documents required for the issue of digital certificate from:
M/s Nextenders (India) Pvt. Ltd.
O/o. DS&D Haryana,
SCO – 09, IInd Floor,
Sector – 16,
Panchkula – 134108
E - mail: Chandigarh@nextenders.com
Help Desk: 1800-180-2097 (**Toll Free Number**)
 - 2.4 Bid for a particular tender must be submitted online using the digital certificate (Encryption & Signing), which is used to encrypt the data and sign the hash during the stage of bid preparation & hash submission. In case, during the process of a particular tender, the user loses his digital certificate (due to virus attack, hardware problem, operating system or any other problem) he will not be able to submit the bid online. Hence, the users are advised **to keep a backup of the certificate** and also



- keep the copies at safe place under proper security (for its use in case of emergencies).
- 2.5 In case of online tendering, if the digital certificate issued to the authorized user of a firm is used for signing and submitting a bid, it will be considered equivalent to a no-objection certificate/power of attorney /lawful authorization to that User. The firm has to authorize a specific individual through an authorization certificate signed by all partners to use the digital certificate as per Indian Information Technology Act 2000. Unless the certificates are revoked, it will be assumed to represent adequate authority of the user to bid on behalf of the firm in the department tenders as per Information Technology Act 2000. The digital signature of this authorized user will be binding on the firm.
- 2.6 In case of any change in the authorization, it shall be the responsibility of management / partners of the firm to inform the certifying authority about the change and to obtain the digital signatures of the new person / user on behalf of the firm / company. The procedure for application of a digital certificate however will remain the same for the new user.
- 2.7 The same procedure holds true for the authorized users in a private/Public limited company. In this case, the authorization certificate will have to be signed by the directors of the company.
- 3 **Opening of an Electronic Payment Account:**
- Tender document can be downloaded online. Bidders are required to pay the tender documents fees online using the electronic payments gateway service. For online payments guidelines, please refer to the Home page of the e-tendering Portal <https://haryanaeprocurement.gov.in>.
- Pre-requisites for online bidding:**
- In order to bid online on the portal <https://haryanaeprocurement.gov.in> , the user machine must be updated with the latest Java. The link for downloading latest java applet is available on the Home page of the e-tendering Portal.
- 5 **Online Viewing of Detailed Notice Inviting Tenders:**
- The bidders can view the detailed N.I.T and the time schedule (Key Dates) for all the tenders floated through the single portal eProcurement system on the Home Page at <https://haryanaeprocurement.gov.in>.
- 6 **Download of Tender Documents:**
- The tender documents can be downloaded free of cost from the e-Procurement portal <https://haryanaeprocurement.gov.in>.
- 7 **Bid Preparation (Technical & Financial) Online/offline**
- Payment of Tender Document Fee, eService fee, EMD fees and Submission of Bid Seal (Hash) of online Bids:**
- 7.1 The online payment for Tender document fee, eService Fee & EMD can be done using the secure electronic payment gateway. The Payment for Tender Document Fee and eService Fee can



be made by eligible bidders/ contractors online directly through Debit Cards & Internet Banking Accounts and the Payment for EMD can be made online directly through RTGS / NEFT . The secure electronic payments gateway is an online interface between contractors and Debit card / online payment authorization networks.

- 7.2 The bidders shall **upload** their technical offer containing documents , qualifying criteria, technical specification, schedule of deliveries, and all other terms and conditions except the rates (price bid).
- The bidders shall **quote** the prices in price bid format.
- 7.3 Submission of bids will be preceded by submission of the digitally signed & sealed bid (Hash) as stated in the time schedule (Key Dates) of the Tender.

NOTE:-

- (A) If bidder fails to complete the Online Bid Submission stage on the stipulated date and time, his/hers bid will be considered as bid not submitted, and hence shall not appear during tender opening stage.
- (B) Bidder participating in online tenders shall check the validity of his/her Digital Signature Certificate before participating in the online Tenders at the portal <http://haryanaeprocurement.gov.in>.
- (C) For help manual, please refer to the 'Home Page' of the e-Procurement website at <https://haryanaeprocurement.gov.in>, and click on the available link 'Download' to download the file.

Guidelines for Online Payments in e-tendering

Post registration, bidder shall proceed for bidding by using both his digital certificates (one each for encryption and signing). Bidder shall proceed to select the tender he is interested in. On the respective Department's page in the e-tendering portal, the Bidder would have following options to make payment for tender document & EMD:

- Debit Card
- Net Banking
- RTGS/NEFT

Operative Procedures for Bidder Payments

- A) Debit Card

The procedure for paying through Debit Card will be as follows.

- Bidder selects Debit Card option in e-Procurement portal.
- The e-Procurement portal displays the amount and the card charges to be paid by bidder. The portal also displays the total amount to be paid by the bidder.
- Bidder clicks on "Continue" button



- (iv) The e-Procurement portal takes the bidder to Debit Card payment gateway screen.
 - (v) Bidder enters card credentials and confirms payment
 - (vi) The gateway verifies the credentials and confirms with “successful” or “failure” message, which is confirmed back to e-Procurement portal.
 - (vii) The page is automatically routed back to e-Procurement portal

 - (viii) The status of the payment is displayed as “successful” in e-Procurement portal. The e-Procurement portal also generates a receipt for all successful transactions. The bidder can take a print out of the same,
 - (ix) The e-Procurement portal allows Bidder to process another payment attempt in case payments are not successful for previous attempt.
- B) Netbanking**
The procedure for paying through Netbanking will be as follows.
- (i) Bidder selects Netbanking option in e-Procurement portal.
 - (ii) The e-Procurement portal displays the amount to be paid by bidder.
 - (iii) Bidder clicks on “Continue” button
 - (iv) The e-Procurement portal takes the bidder to Netbanking payment gateway screen displaying list of Banks
 - (v) Bidder chooses his / her Bank
 - (vi) The Netbanking gateway redirects Bidder to the Netbanking page of the selected Bank
 - (vii) Bidder enters his account credentials and confirms payment
 - (viii) The Bank verifies the credentials and confirms with “successful” or “failure” message to the Netbanking gateway which is confirmed back to e-Procurement portal.
 - (ix) The page is automatically routed back to e-Procurement portal
 - (x) The status of the payment is displayed as “successful” in e-Procurement portal. The e-Procurement portal also generates a receipt for all successful transactions. The bidder can take a print out of the same.
 - (xi) The e-Procurement portal allows Bidder to process another payment attempt in case payments are not successful for previous attempt.
- C) RTGS/ NEFT**
The bidder shall have the option to make the EMD payment via RTGS/ NEFT. Using this module, bidder would be able to pay from their existing Bank account through RTGS/NEFT. This would offer a wide reach for more than 90,000 bank branches and would enable the bidder to make the payment from almost any bank branch across



- India.
- i. Bidder shall log into the client e-procurement portal using user id and password as per existing process and selects the RTGS/NEFT payment option.
 - ii. Upon doing so, the e-procurement portal shall generate a pre-filled challan. The challan will have all the details that is required by the bidder to make RTGS-NEFT payment.
 - iii. Each challan shall therefore include the following details that will be pre-populated:
Beneficiary account no: (unique alphanumeric code for e-tendering)
Beneficiary IFSC Code:
Amount:
Beneficiary bank branch:
Beneficiary name:
 - iv. The Bidder shall be required to take a print of this challan and make the RTGS/NEFT on the basis of the details printed on the challan.
 - v. The bidder would remit the funds at least one day in advance to the last day and make the payment via RTGS / NEFT to the beneficiary account number as mentioned in the challan.
 - vi. Post making the payment, the bidder would login to the e-Tendering portal and go to the payment page. On clicking the RTGS / NEFT mode of payment, there would be a link for real time validation. On clicking the same, system would do auto validation of the payment made.

List of Net banking banks

1. Allahabad Bank
2. Axis Bank
3. Bank of Bahrain and Kuwait
4. Bank of Baroda
5. Bank of India
6. Bank of Maharashtra
7. Canara Bank
8. City Union Bank
9. Central Bank of India
10. Catholic Syrian Bank
11. Corporation Bank
12. Deutsche Bank
13. Development Credit Bank
14. Dhanlaxmi Bank
15. Federal Bank
16. HDFC Bank
17. ICICI Bank
18. IDBI Bank
19. Indian Bank
20. Indian Overseas Bank



21. Indusind Bank
22. ING Vysya Bank
23. J and K Bank
24. Karnataka Bank
25. Kotak Mahindra Bank
26. KarurVysys Bank
27. Punjab National Bank
28. Oriental Bank of Commerce
29. South Indian Bank
30. Standard Chartered Bank
31. State Bank Of Bikaner and Jaipur
32. State Bank of Hyderabad
33. State Bank of India
34. State Bank of Mysore
35. State Bank of Travencore
36. State Bank Of Patiala
37. Tamilnad Mercantile Bank
38. Union Bank of India
39. United Bank of India
40. Vijaya Bank
41. Yes Bank

Schedule- B

NECESSARY INSTRUCTION/TERMS & CONDITIONS FOR THE BIDDER

Sr. No.	Necessary instruction/Terms & Conditions for the bidder
1.	Tender must be submitted on prescribed tender form and complete in all respects and submitted through e-procurement mode only. No other mode like email/fax etc. shall be acceptable.
2.	Tender enquiry has been floated for procurement of material as specified in NIT.
3.	Tenderer must carefully study the technical specifications and general terms and conditions before preparation of tender. All terms and conditions of NIT and Corrigendum shall be applicable.
4.	The tenders not meeting the requirement of pre-qualification conditions, necessary terms and conditions of the NIT and Nigam technical specifications shall be rejected.
5.	The bidders shall have to pay for the tender documents, EMD Fees & e-Service Fee online by using the service of secure electronic payment gateway. The secure electronic payments gateway is an online interface between contractors/suppliers and online payments authorization networks. The payment for Tender Document Fee and eService Fee can be made by eligible bidders/suppliers online directly



	<p>through Debit Cards & Internet banking Accounts and the Payment for EMD can be made online directly through RTGS/NEFT. The Bank charges, if any, will be to the account of the tenderer. No claims against the Nigam either in respect of interest if any due on the Security deposit/Earnest money or its depreciation in value shall be admitted</p>
6.	Detailed procedure for depositing earnest money, order preference to Haryana firms, delivery schedule and other terms and conditions are contained in SOT & schedule D of tender documents. Each tender document is required to be signed by his authorized representative alongwith stamp and is to be uploaded thereafter.
7.	The following tenders shall be exempted from the deposit of earnest money. (i) Wholly Govt. of India owned undertakings. (i) Wholly State owned undertakings of Haryana.
8.	The tenders should remain valid for 180 days from the date of opening of tender (Part-I in case of two part tender) otherwise the same will not be accepted and rejected out-rightly.
9.	The offers/tenders will be opened on the date and time prescribed in the Notice Inviting Tenders. In case the date of opening falls on a holiday including Sunday or a holiday is subsequently declared on that date, the tenders will be opened on next working day following the holiday.
10.	All tenders/offers will be regarded as constituting an offer or offers open to acceptance in whole or in part until the last date of validity as prescribed in the notice inviting tenders or as indicated by the tenderer in his tender/offer, whichever be later.
11.	The price must be quoted in Indian Rupees and any mistake in calculating the rupee price will not justify the claim for increase in prices.
12.	Authenticated documents to prove authority of signatory (legal power of attorney in favour of signatory) must be uploaded . Memorandum of article and Memorandum of association of the firm, if applicable, shall also be uploaded with the tender . The firm shall submit the detail information in the performa of particular of bidder. (Annexure-III)
13.	The tenderer shall give details of immovable property i.e. land, building, machinery, exact location of their property and copy of constitution/balance sheet alongwith the tender. The document shall be uploaded by the supplier/s.
14.	Tender not adhering to Nigam's delivery schedule will not be considered.
15.	If more than one bid is submitted by any/one bidder, (having same registered office), the same shall be rejected.
16.	The deviations in Technical & Commercial terms and Conditions, if any, must be brought out clearly on the performa enclosed (Annexure-V) , failing which it will be presumed that the same are acceptable in to-to.
17.	Tenderer/s shall submit their offer in an ambiguous free wording failing which DHBVN/UHBVN interpretation will be final.
18.	The tenders shall be submitted in two parts. Part-I shall consist technical details and commercial terms and part-II shall consist price bid only. Part-II i.e. price bids shall be opened on a date to be intimated separately for the purpose.
19.	Purchase Preference: The provision for purchase preference shall be as per policy/ guidelines issued by the State Govt. vide G.O. No. 2/2/2010-4 I B II dated 19.12.2011 and/or latest instruction issued by the State Govt. All other Policy decisions/ guidelines on procurement of Stores through the Directorate of Supplies and Disposals as applicable for the state of Haryana are also applicable in this case (Unless stated /decided otherwise). The instructions/guidelines issued by Govt. of Haryana vide G.O. No. 2/2/2010-4 I B II dated 28.05.2010, G.O. No. 2/2/2010-4 I B II dated 19.12.11, G.O. No. 2/2/2010-4 I B II dated 18.06.13, G.O. No. 2/2/2010-4 I B II dated 16.6.2014, G.O. No. 2/2/2010-4 I B II dated 9.02.15 & G.O. No. 2/2/2010-4 I B II dated 24.03.15 are available on



	website www.dsndharyana.gov.in . the bidders are requested to download the same from website and read carefully before submitting the tender. It shall be presumed that the bidder has read these instructions/guidelines and agreed the same, while evaluating for tender submitted by the firm/supplier/tenderer.
20.	The revision of price bid after opening of Part-I i.e. technical and commercial part of the tender is not allowed. In case of withdrawing the same within the validity period, EMD shall be forfeited.
21.	If any of the firm fails to supply the material within stipulated delivery period, then the leftover quantity of said firm shall be considered for allocation to the firm (s) supplying material under the same NIT and performing better. This clause shall be applicable after issuance of purchase order of the minimum quantity of Rate Contract and with mutual consent of Nigam and the remaining suppliers under the same NIT. The defaulting firm shall have to fulfill its contractual obligations against the minimum quantity of the rate contract, else shall have to bear penal action as per the provisions in the NIT.
22.	Arithmetical Errors: - in case of any inconsistency in the prices furnished, the purchaser shall be entitled to consider the lowest prices for the purpose of evaluation and award of contract. All arithmetical errors will be rectified on the basis of the unit price or total price (in figures and in words) whichever is more beneficial to the purchaser.
23.	In the event of a firm not favoring the delivery commitments of the previous contracts, this fact will weigh against the firm tendering against a subsequent enquiry and be treated as disability. Before issue of the letter of intent or of placing the order, the previous order should be fully discharged or a reliable undertaking should be given that it would be done within a reasonable period and within scope of the previous contract, if the firm declines to give this undertaking, it would be considered ineligible for competing against any subsequent tender/order and the current order would automatically pass on the next lower firm.
24.	The tender shall be issued by DHBVN for procurement on behalf of both the power utilities i.e. DHBVN & UHBVN. However, all the purchase orders will be issued by CE/MM of respective utilities in a phased manner depending on the requirement of stores. The PQRs and other liabilities of the bidder shall be as per minimum quantity offered.
25.	Material offered should be strictly according to the technical specification attached with the tender documents as laid down in Annexure-A of Schedule D (Part-I) to the Terms and conditions of the contract. Unless a deviation in the specifications given in Annexure 'A' is pointed out by the tenderer specifically, it will be presumed that Offer/tender conform to the specifications as laid down in Annexure 'A'. However, in case of any ambiguity in the Nigam's technical Specification, the provision of relevant IS with latest amendment will prevail. The concerned Director /Projects, shall be the deciding authority in such cases.
26.	EMD is liable to be forfeited in case of evidence of cartel formation by the bidder(s). The provision for penal action in case of cartel formation by the bidders shall be as per clause No. 9 of policy (guidelines) issued by the State Govt. vide G.O No. 2/2/2010-41 BII dated 28.5.2010.
27.	The purchaser reserves the right to reject any or all the tenders received without assigning any reason.
28.	The firm failing to accept the LOI after having made commitments before SPC/HPPC (Nigam)/HPPC (Govt.) shall be blacklisted/ debarred from doing business with Nigam and earnest money of the firm shall be forfeited.
29.	The bidder shall submit along with his tender documents, the details of his production capacity, orders in hand/pending with quantity, value and delivery



	schedule of the material /equipments in question. The document shall be uploaded by the supplier.
30.	The bidder shall submit all the requisite documents pertaining to the plant from where the material will be supplied. The document shall be uploaded by the supplier.
31.	List of customers to whom the material in question has been supplied/orders executed financial year wise and their performance certificates shall be enclosed by the Tenderer. The document shall be uploaded by the supplier.
32.	No change in GTPs/technical parameters/drawings submitted alongwith bid shall be allowed in case the offered material is as per technical specification of Nigam.
33.	The tenderer must submit a hard copy of all the documents related to part-I (i.e. techno-commercial terms and conditions, where the tender is invited in two parts) uploaded on the site for the said tender duly certifying that these documents are same as uploaded on designated website, within 4 days of opening of part-I. (All affidavit & undertakings should be submitted in original with hard copy).
34.	Submission of Quality Assurance Procedure The Vendor / Contractor at the time of submission of the drawings for approval from DHBVN/UHBVN is also required to submit a Quality Assurance Procedure (QAP) of the materials to be supplied for review and approval. In this QAP, the vendor / contractor shall clearly indicate the quality measures being taken by the manufacturer to maintain the quality of the finished product. The drawings/QAP once approved shall not be required to be submitted for approval again. QAP will indicate the following details:- i) Tests being performed on the raw material purchased by manufacturer for manufacturing of the finished product. ii) Tests being conducted during manufacturing of the product (In process testing). iii) Tests which shall be done on the finished product at the time of pre-dispatch inspection. iv) Test results assured by the vendor. v) Tests procedure followed for the inspection with full details of test setup etc. The Inspection shall be carried out on the basis of the approved QAP. All the details provided by the vendor / contractor shall be verified by Nigam / Third Party during the inspection and if any deviation is found from the approved documents, it will be noted in the inspection report.
35.	The firms will enter into an agreement with the Nigam to ensure that there is no fall in the prices of the item under rate contract and in case of any such price fall, the rates of the material will be revised as per any decrease in price.
36.	Deleted
37.	MODVAT benefits, if any, be included in quoted prices and confirmed in bid submission.
38.	All the other terms and conditions will be as per latest guidelines of Govt. of Haryana and schedule D (general and particular terms & conditions of contract) and technical specification of Nigam. However, any statutory variation shall be borne by the Nigam, during contractual delivery schedule only i.e. increase in statutory variation beyond the overall delivery period shall be borne by the firm. Further, in case of award of contract / PO to the firm/s having exemption in statutory levy like E.D., VAT / CST etc. at the time of quoting the bid, the rate of such statutory levies as applicable on the date of tender opening / finalization shall be deemed to be included in the rates finalized.
39.	The post tender offers or communications received from the supplier/contractors etc. which effect the quoted and equivalent rates there by changing the merit position of the tender shall not be entertained



उत्तर दक्षिण हरियाणा बिजली वितरण निगम

UTTAR DAKSHIN HARYANA BILII VITRAN NIGAM



UHBVN

Annexure-II

Pre-qualification conditions

40.	On the day the purchaser conveys acceptance to the supplier's offer either through e-mail/fax or by a letter, the date of e-mail/fax or letter will be the date of agreement and the contractual obligations of the supplier will commence from that very date. The supplier will have no right to revoke his offer after the acceptance of purchaser.
41.	The benefits applicable vide Govt. of Haryana office order no- 2/2/2010-4-IB-II dated 24.03.2015 to Haryana based Micro and Small Enterprises (Including KVI units) will be admissible only if the concerned Enterprises participate directly in the tender not through their intermediaries i.e. their dealers/agents and distributors etc. To avail the benefits of Haryana based Micro and Small Enterprises (Including KVI units), the bidders will upload the requisite documents along with the tender documents.
42.	Pre-qualification conditions: The firm quoting against the NIT shall meet with the Pre- qualification requirement as elaborated in Annexure-II without which the firm shall not be considered for placement of order.



Sr. no.	Description
i.	The firm should be ISO-9001:2008 certificate or above and should be a manufacturer/authorized agent of manufacturer, if Manufacturer being outside India. (His agent shall have the necessary testing facilities in India).
ii.	<p>The turnover of the firm in any one financial year during the last five financial years should be equivalent or more to the estimated cost of the material of the NIT /estimated cost of the material offered. The documents showing turnover should be duly attested by CA and in support of the same, the balance sheet of that particular year may also be attached. (Estimated cost of material of NIT by taking min. qty. of the tender is Rs. ____.)</p> <p>Manufacturing Small Enterprises (Including Khadi & Village industries) that have filed Entrepreneurs Memoranda in Haryana will be entitled to a concession of 50% on the turnover and shall be considered qualifying accordingly.</p> <p>Manufacturing Micro Enterprises that have filed Entrepreneurs Memoranda in Haryana will be entitled to a concession of 75% on the turnover and shall be considered qualifying accordingly.</p> <p>Note:- The turnover mentioned in this clause signifies “Overall turnover of the firm”.</p> <p>(format for CA certificate regarding turnover is enclosed as Annexure VIII).</p>
iii.	<p>Past Performance of the firm with DHBVN or UHBVN or any Central/State Govt. Power Utility in India should be satisfactory in adhering to the delivery schedule relating to purchase of material only.</p> <p>On the date of opening of bid, the bidder should have completed at least 50% supply of the ordered quantity within contractual delivery period against the latest completed purchase order of any rating/capacity at 33 KV or higher level executed for UHBVN and DHBVN & any other power utility subject to the condition that PO has been executed successfully with or without levy of penalty or delivery extension.</p> <p>In case of supply of any other central/state govt. power utility the firm shall submit self certification in the form of affidavit on NJSP alongwith requisite proofs(Format of affidavit attached as Annexure-VII). If bidder has not supplied any material to DHBVN/UHBVN, Nigam shall get pre-order inspection of his facilities done to be sure of his manufacturing capabilities.</p> <p>The supplies should be considered preferably against direct purchase orders placed by central/state Govt. Power Utility for supply of tendered items. However, the offered material supplied against Turnkey works shall be accounted for in adjudging the past performance where offered material was supplied to Haryana DISCOMs for consideration of supplies against turnkey works i.e if the potential supplier qualifies in PQR clause (v) then he shall be qualifying PQR clause (iii). However, for PQR clause (iii) & (v) for turnkey supplies, a continuous period of 12 month shall be considered as valid periodicity instead of a calendar year or a financial year.</p> <p>For consideration of supplies against turnkey works, the T/Fs should have been successfully energised on the date of opening of tender (Part-I)</p>
iv.	Minimum qty. to be quoted shall be atleast 20% of the minimum quantity of NIT. An offer below 20% of the minimum quantity of NIT shall be rejected and its price bid shall not be opened. <i>Please quote the max / min quantity of supply against this NIT.</i>



v.	<p>The firm bidding 20% or more of NIT quantity should have supplied at least 50% of the offered quantity of any rating/capacity at 33 KV or higher level in any one financial year during the last 5 financial years to UHBVN/ DHBVN or any other Power Utilities. The capacity wise list of supplies for that particular financial year duly attested by CA must be attached.</p> <p>The past experience of the suppliers on the basis of supply of total MVA of assorted ratings of Power T/Fs (33KV and above levels) in any one year during the last 5 years to UHBVN/DHBVN or any other Power Utility may be considered</p> <p>The turnkey experience of the suppliers for the aforementioned material in respect of DISCOMs of Haryana should also be included while considering the numerical value of 50% material (in shape of MVA) having been supplied by the suppliers to qualify towards past experience. The performance of the suppliers in respect of their turnkey experience should also be got verified from the Construction Wing of the concerned Utility.</p> <p>Haryana State SSI/MSME (including KVI) units shall be considered qualifying this clause provided they have supplied at least 25 % of offered quantity to any power utility in any one year during the last five financial years.</p>
vi.	<p>Only those firms who have not been blacklisted by DHBVN/UHBVN or any State/Central Govt. Power Utility in India on the date of issuance of NIT shall be entitled to submit the tenders. The firm shall submit an affidavit of non-blacklisting on the non-judicial stamp paper of the appropriate value attested by Notary public.</p>
vii.	<p>The bidder should have completed the supplies up to the date of opening of Part-I tenders against all the previous purchase orders of similar item irrespective of size/rating placed by UHBVN/DHBVN whose delivery period has already expired with max. Penalty, failing which the bid shall be treated as non responsive and price bid shall not be opened.</p>



SCHEDULE 'C'
UTTAR/DAKSHIN HARYANA BIJLI VITRAN NIGAM LIMITED

TENDERFORM

From _____

To _____

Offer No. _____

Dated _____/20

Subject: Submission of e-tender against Notice Inviting Tender No. _____

dated _____ (Tender enquiry no. _____ & tender ID No. _____)
of Dakshin Haryana Bijli Vitran Nigam Ltd.

Dear Sir,

With reference to your above mentioned notice inviting tender & tender ID, I/We hereby offer to supply/provide genuine goods/services (as per details given in the tender documents) and shall execute the supply contract truly and faithfully within the time specified and set forth in the attached terms and conditions. The goods/services to be supplied/provided will be of the quality and answerable in every aspect with this tender. I/We shall be responsible for all complaints as regards the quality of goods/services and in case of dispute the decision of the Nigam will be final and binding on me/us.

1. Rs. _____ Rupees _____) have been deposited online through designated e-procurement website, as earnest money as desired. I fully understand that in the event of my/our tender being accepted this earnest money shall be retained by you till the submission of performance guarantee by me as per clause 6, Schedule-D.

2. I/We shall have no claim to the refund of the earnest money prescribed against this tender in the event of my/our non-compliance of the purchase order provided such order is placed within the period of validity of my/our tender as indicated in paragraph 4 below.

I further understand that my earnest money will stand forfeited even if I withdraw my tender at any stage during the currency of the period of validity.

3. My/our tenders shall remain valid for a period of _____ days from the last date prescribed for submission of the tenders against the NIT No. _____ dt. _____ (tender ID No. : _____).

4. My/our tender along with the terms and conditions with the relevant columns and annexures duly filled in, including the enclosed terms and conditions, (in the capacity of sole owner/general or special attorney, in proof of which power of attorney is attached) is submitted for your favourable consideration.

5. I/We have read the enclosed terms and conditions carefully and accept the same in toto. My/our tender constitutes a firm offer under the Indian Contract Act 1872 and is open to an acceptance in whole or in parts. My/our offer, if accepted on the attached terms and conditions will constitute a legally binding contract and shall operate as a contract as defined in the Indian Contract Act 1872 and the Indian Sale of Goods Act 1930.

6. Detail of documents submitted, duly paginated, by me is attached herewith for ready reference.

Thanking you.



DA/Details of documents

Place

Yoursfaithfully,

Dated

Name&Full Addressof Tenderers

NITNo. _____

EnquiryNo. _____

SCHEDULE 'D'

(Part-I, General Conditions of Contract)

UTTAR/ DAKSHIN HARYANA BIJLI VITRAN NIGAM LIMITED

GENERAL TERMS AND CONDITIONS FOR PROCUREMENT OF EQUIPMENT STORES AND OTHER MATERIAL

In construction of the terms and conditions of the contract, the following words shall have the meaning herein assigned to them, unless the subject or context otherwise requires:

- (a) The "PURCHASER" shall mean the Haryana DISCOMs (DHBVNL /UHBVNL) or their authorized agent and shall include their Successors in office, and assigns.
- (b) The "SUPPLIER" shall mean M/s ___ and shall include the supplier's legal representatives, successors, and assigns.
- (c) "MANUFACTURERS: shall mean M/s _____ and shall include their legal representatives, successors, and assigns.
- (d) "MATERIAL" all the material to be supplied by the supplier under the contract as per clause of material specifications, price etc.
- (e) 'SPECIFICATION' shall mean and include the specifications as detailed in the attached herewith and Drawings attached thereto as well as samples and patterns, (if any).
- (f) The 'SITE' shall mean and include the lands and building over/under/upon and in which the materials are to be installed and used in accordance with the terms and conditions.
- (g) 'PLACE OF DELIVERY' shall mean the place of delivery at which the supplier is responsible to deliver the material at the contract price as specified in the clause "Material-Specification: Price etc.
- (h) 'COMMERCIAL USE' shall mean the use to which the material can commercially be put.
- (i) 'MONTH' shall mean a calendar month.
- (j) 'THE TERMS' F.A.S., F.O.R., F.O.B., C.I.F. and other shipping/despatch terms as used



- herein, shall have meaning in accordance with their uses in India.
- (k) 'WORK' shall mean and include supply of all the materials, plants and equipment and rendering of other services by the supplier under this contract.
- (l) 'ACT' shall mean the Companies Act 1956 and shall include any statutory amendments, Modifications or re-enactment thereof for the time being in force.
- (m) 'Haryana DISCOMs' shall mean the UTTAR HARYANA BIJLI VITRAN NIGAM LIMITED / DAKSHIN HARYANA BIJLI VITRAN NIGAM LIMITED as incorporated under Companies Act 1956 and shall include their successors and assigns.
- (n) 'MANAGING DIRECTOR' shall mean the Managing Director of the NIGAM (DHBVN/UHBVN) duly appointed by the Govt.
- (o) 'CONSIGNEE' shall mean the officer to whom the materials are required to be dispatched or the persons specified in the purchase order.
- (p) 'CONTRACT' shall mean the Notice Inviting Tender, Instructions for tenderers, Tender Forms, terms and conditions of contract with their annexures and purchase order/ acceptance of offer/ Tender/ Rate Contract.
- (q) 'DRAWING' shall mean the drawing/ drawings annexed to the specification (if any) or as approved by the purchaser.
- (r) 'PURCHASE AUTHORITY' shall mean the officers signing the acceptance of tender and shall include any officer who has authority to execute the relevant contract on behalf of the purchaser.
- (s) 'PURCHASE ORDER' shall mean an order of supply of material including the acceptance of the tender.
- (t) 'ANNEXURE' shall mean the Annexure to the terms and conditions.
- (u) 'ACCEPTANCE OF TENDER' shall mean the letter or memorandum communicating to the supplier the acceptance of his offer (Tender) and shall include advance acceptance of his offer i.e. Letter of Intent or Rate Contract.
- (v) 'TEST' shall mean such test as is prescribed by the Indian Standards Institution or by the Haryana DISCOMs and/or considered necessary by the authorized agents of the purchaser, whether conducted/performed or made by them or any other agency acting under their directions.
- (w) 'DELIVERY' shall be deemed to take place on delivery of the material in accordance with the terms and conditions of the Contract after test and inspection by the purchaser or his authorized agent, to the consignee.
- (x) D.G.S&D shall mean the Director General of Supplies and Disposals, Government of India.
- (y) DS&D shall mean the Director Supplies & Disposal, Haryana.



2. PARTIES.

The parties to the contract are the supplier and the purchaser, Legal address of the parties to the Contract is under:

Supplier M/s _____

Purchaser: Dakshin Haryana Bijli Vitran Nigam (Hisar)/UTTAR Haryana Bijli Vitran Nigam (Panchkula)

For all purposes of the contract including the arbitration there under, the address of the supplier mentioned above, shall be the address to which all communications addressed to the suppliers shall be sent, unless the supplier has notified a change by a separate letter containing no other communication and sent by a Speed Post (Acknowledgement Due) to the purchaser. The supplier shall be solely responsible for the consequences of an omission to notify the change of address in the manner aforesaid.

3. AUTHORITY OF THE PERSONS SIGNING THE CONTRACT ON BEHALF OF THE SUPPLIER.

The person who has assigned these Tender papers (including the terms and conditions) has got authority to sign on behalf of the supplier. It is discovered at any time that the persons signing had no authority to do so, the purchaser without prejudice to any other right or remedy available to him may, cancel the contract and hold such person liable to the purchaser for all costs and damages arising from the cancellation of the contract including any loss which the purchaser may sustain on account of such purchase.

4. RESPONSIBILITY OF THE SUPPLIER FOR EXECUTING THE CONTRACT.

(i) RISK IN MATERIAL

The supplier shall execute the contract in all respects in accordance with the terms and conditions. The material and every constituent part thereof, whether in possession or control of the supplier, his agents or servants or a Carrier or in the joint possession of the supplier, his agents, servants and the purchaser, shall remain in every respect at the risk of the supplier until its actual delivery to the consignee at the stipulated place or destination. The supplier shall be responsible for all loss, destruction, damage or deterioration of the material from any cause whatsoever while the material after test and inspection is awaiting dispatch or delivery in course of transit from the supplier to the consignee. The supplier shall alone be entitled and responsible to make claims against the carrier in respect of non-delivery, mis-delivery, short delivery, loss, destruction,

damage or the deteriorated material entrusted to such carrier by the supplier for transmission to the consignee.

(ii) CONSIGNEE'S RIGHT OF REJECTION

Notwithstanding any approval which the purchaser may have given in respect of the material, it shall be lawful for the consignee to reject the material or any part thereof on behalf of the purchaser within a reasonable time after actual delivery thereof to him at the place or destinations specified in Annexure 'B' if the material or any part or portion thereof is not in all respects in conformity with the terms and conditions of the contract.



whether on account of any loss, deterioration or damage before dispatch or delivery or during transit or otherwise howsoever.

The provision contained in clause 14(vi) below relating to the removal of material rejected by the purchaser or his authorised agents shall, mutatis mutandis, apply to material rejected by the consignee as herein provided.

(iii) SUBLETTING AND ASSIGNMENT:

The suppliers shall not save with the previous consent in writing of the purchaser sublet, transfer or assign the contract or any part thereof or interest therein or behalf or advantage thereof in any manner whatsoever.

5. ASSISTANCE TO SUPPLIER

The suppliers shall be solely responsible to procure any raw material, license or permit required for the fulfillment of the contract. Any assistance for the procurement or attempt to tender assistance in the matter aforesaid, shall not be construed or constitute any promise, undertaking or assurance on the part of the purchaser regarding the procurement of the same to effect any variation in the rights and liabilities of the parties under the contract.

6. SECURITY DEPOSIT

- i) The earnest money furnished by the successful tenderers to whom the purchase order/ contract is allotted shall be refunded within 7 days from the verification received from the concerned Bank of performance guarantee as per contract (performa enclosed as **Annexure-VI**) by the accounts wing/DDO. The earnest money of lowest (L-2) shall be released after submission of performance Bank Guarantee by the successful bidder i.e. L-1. For remaining participating firms, EMD shall be refunded after finalization of the procurement case.
- ii) BG shall be retained by the purchaser for the period valid for 90 days after the expiry of warranty period as per clause of 'WARRANTY'.
- iii) No claim of the suppliers shall lie against the purchaser either in respect of interest or any depreciation in the value of security deposit.
- iv) If, the supplier fails or neglects to observe or perform any of his obligations under this contract, it shall be lawful for the purchaser to forfeit at his absolute discretion, the Available EMD shall be forfeited and BG shall be encashed besides invoking clauses no. 21 & 28 i.e "Termination of Contract for default" & "Blacklisting of Firm" respectively.

The ibid forfeiture of EMD and encashment of BG shall be without prejudice to the right of the purchaser to recover any further amount of any liquidated and/or other damages, undue payment or overpayment made to the supplier under this contract and / or any other contract.

7. MATERIAL, SPECIFICATIONS, PRICES, ETC.

- i- The suppliers shall supply the quantities of different items of material within the NIT of the best quality, workmanship and strictly in accordance with the prescribed specifications **(Annexure A)** and rates shown against each, unless any deviation in specification has been expressly pointed out in the purchase order.

The rates offered by the supplier and subsequently finalized shall remain Variable / FIRM as specified in Particular Conditions of Schedule-D (Part-II) of NIT



documents.

ii- **Periodical Assessment of Rate and Undertaking for Price Fall.**

a) **Periodical Assessment of Rate:**

Deleted

b) **Price Fall Clause:**

- i) The prices charged for the material supplied under the rate contract by the firm shall in no way exceed the lowest price at which the firm sales the material to any person/organization Including the purchaser or any other department of the central Govt. or any Deptt. of the State Govt. or any Statutory Undertaking of the Central or State Govt. as the case may be during the delivery period till performance of all supply orders placed during the currency of the rate contracts is completed.
- ii) If at any time during the said period, the firm reduces the rates of the material as contained/ described in the contract or offer to sell such material to any person / Organization including the purchaser or any Deptt. of Central Govt. or any Deptt. of the State Govt. or any Statutory Undertaking of the Central or State Govt. as the case may be, at price lower than the price chargeable under the rate contract, shall forthwith notify such reduction / sale or offer to sale to the Nigam and the price payable under the rate contract for the material supplied after the date of coming into force of such reduction or sale offer to sale, shall stand correspondingly reduced.
- iii) The firm shall furnish the following certificate to the concerned Consignee's along with each bill against the rate contract:-

"I / we certify that there has been no reduction in sale price of the material of description identical to the material supplied to Nigam under the rate contract herein and such material has not been offered and sold by me / us to any person / organization including the purchase of any Deptts. of the Central Govt., any Deptts. of the State Govt., any statutory undertaking of the Central or State Govt. as the case may be upto the date of bill/ date of completion of supplies against all supply orders placed during the currency of the rate contract at prices lower than the prices charged to Nigam under the rate contract".

8. **SAMPLE** :- This clause shall be applicable as specified in Particular conditions of Schedule-D (Part-II)

9. **(i) DELIVERY**

The suppliers shall deliver the material in accordance with the terms and conditions of the contract at the time/times and at the place/places and in the manners specified in the Annexure 'B' attached thereto. In case the due date of delivery in terms of delivery schedule fall on a holiday including Sunday or holiday is subsequently declared on that date, the firm shall be required to complete the supply by the first working day falling next to the due date.

(ii) **TIME FOR AND DATE OF DELIVERY; THE ESSENCE OF THE CONTRACT.**



The time for and the date of delivery of the material stipulated in the Annexure 'B' purchase orders shall be the essence of the contract and delivery must be completed not later than the date(s) as specified in Annexure 'B' / purchase order.

(iii) **NOTIFICATION OF DELIVERY:**

Notification of delivery of dispatch in regard to each and every consignment shall be made to the purchaser and respective consignees. The suppliers shall supply to consignee a packing account and full details of the contents of the package and quantity of material in order to enable the consignee to check the material on arrival at destination.

(iv) **Early Supplies:-** This clause shall be applicable as specified in Particular Conditions of Schedule- D (Part-II).

(v) **DAMAGES FOR DELAY IN DELIVERY:**

The delivery of material as per the Annexure "B" attached to the Terms and Conditions of Contract (Schedule 'D') shall be the essence of the contract between the supplier and the Nigam and the delivery of such consignment must accordingly be insisted upon the date it is due in terms thereof.

No supplies/consignments received after the due date, on which they were actually

due according to the terms of the purchase order, shall be accepted by the consignee except, with the approval of the purchasing authority.

In case the purchasing authority decides to accept a delayed supply, the suppliers shall be liable to pay penalty @ one half of one percent per week or part thereof of the value of goods so delayed subject to a maximum of 5% of the total value of the delayed supplies. In case the delivery schedule provides lot wise delivery of material, lot wise penalty shall be imposed.

(vi) **PASSING OF PROPERTY:**

Property in the material shall not pass to the purchaser unless and until the material has been delivered to the consignee, in accordance with the terms and conditions.

(vii) **TAKING OVER CERTIFICATES:**

The consignee(s) shall issue a taking over certificate after the material has been received at site(s), taken into possession, inspected, counted, measured and the supplier has supplied the copies of tests and inspection-certificate, if any, vide clause-14 "Test and Inspection".

10. FORCE MAJEURE:

The suppliers shall not be liable for any loss or damage due to delay in manufacture or delivery of the material for reason arising out of compliance with regulations, orders or instructions of Central/State Govt., Acts of God, acts of Civil and Military authorities, fires, floods, strikes, Lockouts, freight embargoes, war-risk, riots and civil commotion.



Whenever the supplier is not in a position to supply the material within the delivery period and he wants extension in the due date (s) of delivery under this clause, he will request for such extension of the delivery period along with all necessary evidence, before the expiry of the scheduled date (s) of delivery. In no case, the delivery period shall be extended under this clause, in case the request is received after the due date of delivery has expired. Extension in the delivery period may be granted only for the period for which the completion of the work is proved by the supplier to have been delayed for circumstances mentioned in this clause.

In all such cases, the Nigam shall have the option to accept any portion of the balance material and cancel the order for the rest, provided, however, if any material had been manufactured exclusively for the purchaser under this contract prior to the commencement of the force majeure circumstances, it shall be accepted by the purchaser and secondly, the cancellation will be without any liability for damages on the part of the supplier.

The decision of the purchaser in all matters under this clause shall be final and binding on the supplier.

Non-availability of raw material or any other similar causes shall not be considered as a force majeure circumstance.

11. **WARRANTY:** - This clause shall be applicable as specified in Particular Conditions of Schedule- D (Part-II).
12. **DRAWINGS :**-This clause shall be applicable as specified in Particular Conditions of Schedule- D (Part-II).
13. **MISTAKES IN DRAWINGS:** This clause shall be applicable as specified in Particular Conditions of Schedule- D (Part-II).
14. **TESTS AND INSPECTION:**

The material shall be inspected and tested by the purchaser or his authorised agent before dispatch unless dispensed with in writing by the purchaser. The Supplier shall give to the purchaser at least 10 days advance notice from the date of readiness of material for such inspection and test.

The Inspection call will be generated in a pre-specified format as per **Annexure-IV**. The vendor /supplier shall also provide a copy of approved QAP, drawings along with the inspection call. Vendor / supplier should give it in writing that he is ready for the inspection.

On receipt of the advance notice from the supplier offering the material for inspection the purchasing authority will get the material inspected and issue the dispatch authorization within 20 days. In case the Inspecting Officer finds on arrival at the supplier's premises that the material was not ready for inspection and that the notice given by the supplier was unfruitful, the firm shall be liable to bear actual expenditure incurred by the Nigam on this account plus a fixed penalty of Rs. 20,000/- for each such call made by the supplier. In addition to above a fixed amount of Rs. 10,000 per officer per-day would also be payable by the bidder in case inspecting officer deputed by Nigam and in case of 3rd party inspector, the amount of bills submitted by them. In case of joint inspection, the bidder shall be liable to pay Rs. 10,000 per man-day for the Nigam's inspector and amount of actual bills submitted by the 3rd party agency.



In case the material offered for inspection fails in 1st inspection, the Nigam will have the right to levy a penalty at 0.25 % of the value of offered material. In case the material offered for inspection fail during the 2nd inspection, the Nigam will have the right to increase the penalty to 0.5% of the value of offered material. In case, the material offered fails during the 3rd and final inspection also, the firm will be liable for penal action viz. encashment of BG, debarring/ blacklisting in future and no further opportunity for inspection would be provided to the supplier firm.

i) **FACILITIES FOR TESTS AND INSPECTION:**

The Suppliers shall, at his own expense, afford to the Purchaser or his authorised agent, all reasonable facilities and such accommodation as may be necessary for such tests and inspection. The Purchaser or his authorised agent shall have full and free access at any time, during the execution of the contract to the supplier's work for the purpose aforesaid, and he may require the Supplier to make arrangement for inspection of the material or any part thereof at his premises or at any other place specified by the Purchaser or his authorised agent.

- ii) The Suppliers shall provide, without any extra charges, all materials, tools labour and assistance of every kind which the Purchaser or his authorised agent may demand of him for any test and inspection. The purchaser or the authorised agent, shall in his sole judgment, be entitled to remove for tests and inspection any of the material to any premises other than his (Supplier's) premises.

iii) **LIABILITY FOR COSTS OF LABORATORY TEST:**

In the event of rejection of material or any part thereof by the purchaser or his authorized agent which is removed to the Laboratory or other place of test, the Supplier, on demand, shall pay to the Purchaser all costs incurred in such removal.

iv) **METHOD OF TESTING:**

The Purchaser or his authorized agent shall have the right to put all the material or part thereof to such tests as he may think fit and proper. The suppliers shall not be entitled to object on any ground whatsoever to the method of testing by the purchaser or his authorized agent.

- v) The Suppliers shall mark or permit the purchaser or his authorized agent to mark all the approved material with a recognized Purchaser's mark. The material which cannot be so marked, shall, if so, required by the Purchaser or his authorized agent, be packed in suitable packages or cases which shall be sealed and marked with such mark.

vi) **REMOVAL OF REJECTED MATERIAL:**

If any material is rejected by the Purchaser or his authorized agent after tests and inspection or by the consignee, the material so rejected shall be removed from the premises of rejection by the supplier at his own cost. Such rejected material shall under all circumstances lie at the risk of the Supplier from the moment of such rejection; and if such material is not removed by the Supplier within a period of 45 days, from the date of notice given by the consignee/Purchasing Department for lifting of such material, Purchaser or his authorized Agent or consignee may dispose of such material in any way at the Supplier's risk and cost and retain such portion of the proceeds as may be necessary to



cover any expense incurred in connection with such disposal and shall also

be entitled to recover handling and storage charges for the period during which the rejected material is not removed.

vii) **CERTIFICATE OF TEST & INSPECTION**

When the test and inspection have been satisfactory carried out by the purchaser or his representative, the purchaser or his authorized representatives shall issue a communication to that effect, the material will then be dispatched by the Supplier according to dispatch instructions of the Purchaser or his authorized representative vide Clause-19 Dispatch Instructions.

viii) **POST RECEIPT INSPECTION:**

The material after receipt in the stores of the Nigam shall be subjected to inspection for its conformity to the specification by a representative of the Nigam in the presence of representative of the contractor/supplier after issuance of e-mail notice/telephonic communication to the supplier/ contractor. In case the firm fails to depute a representative on the specified date, the Nigam would be free to get the material checked in the absence of firm's representative for which the firm would have no reason to protest at any stage and would be fully responsible of the outcome.

ix) **TYPE TEST CONDITIONS:** This clause shall be applicable as specified in Particular Conditions of schedule-D (Part-II)

x) **Non – conformance of material with provisions of technical specification: -**
The material offered/received after the inspection by the authorized inspecting officer may again be subjected to the test for losses or any other parameter from any Testing House/in-house technique of the Nigam & the results if found deviating, un-acceptable or not complying to approved GTP, the lot shall be rejected and bidders shall arrange to supply the replacement within forty-five (45) days of such detection at his cost including to and fro transportation. In addition to this, a penalty @ 5% of cost of the rejected lot of material shall be imposed. The rejected material shall be lifted back by firm only after replacement with fresh material or by submission of additional BG of equivalent to the cost of material. This BG shall be released when the replacement of material with fresh material received in the Nigam Stores and material is accepted by the Nigam.

15. VAT/CENTRAL SALES TAX

The Purchaser shall pay Central Sales Tax/Value Added Tax at the prescribed rates (if applicable) on the production of the following Certificates by the supplier in triplicate:

- i) Certified that the transaction in which the sales tax/Value Added Tax has been claimed has been/will be included in the returns submitted/to be submitted to the Taxation authorities for the assessment of Central Sales Tax and amount claimed from the Haryana DISCOMs has been/shall be paid to the Sales Tax authorities.
- ii) Certified that the goods on which the Sales Tax/Value Added Tax has been charged in Bill No. _____ dt. _____ for Rs. _____ have not been exempted under the Central Sales Tax Act 1956/Haryana VAT Act 2003 or



therulesmadethereunderandthechargesonaccountofSalesTaxonthese goodsarecorrectundertheprovisionoftherelevantActortheRulesmade thereunder.

- iii) Certifiedthatweshallalwaysindemnifythe Haryana DISCOMs incaseitisfoundatalaterstage,thatwrongorincorrectpaymenthadbeen recoveredonaccountofSalesTaxpaid/tobepaidbyus.
- iv) Certifiedthatweareregistered asadealerundertheCentral/StateSalesTax/ VATandourregistrationNo.is_____.

ProvidedthatinrespectoftheitematSr._____and ofclause- 7whicharerequiredbytheNigamforuseonthe generationanddistributionofelectricalenergytothePublic,noHaryanaSales Tax/VATshallbepayableastheyareexemptedunderSection-27,Sub-section (I)(a)(III)ofHaryanaGeneralSales TaxAct1973.

16. DOCUMENTATION:

- i) Allbillsand/orinvoiceswhetherinrespectofanadvancepaymentorfullpayment, shall contain complete details of Code No., name of the item, description of materialsupplied,quantitysupplied,rates,detailsofextraclaims,etc.aswellas the name of the consignee who received the material, shall be submitted in triplicate, duly accompanied by the receipted good challan, inspection note/test certificateinoriginal,prescribedsalestax/excisedutycertificates,documentary evidence regarding transportation of the material from the place of manufacturing to the contractor and then from contractor to the
- ii) Nigamandexcise dutygatepass,whererequired.
- iii) Allfreightchargeswhetherpaidortopay,andwhetherchargeabletotheNigam orincludedinthequotedprice,shallbeshownintheinvoicesseparately.
- iv) Allbillsand/orinvoicesshallbesentbythesupplierto:

forpayment.

17. TERMS OF PAYMENT: This clause shall be applicable as specified in Particular Conditions of Schedule-D (Part-II)

18. NEGLIGENCE:

Ifthesuppliershallneglecttoexecutethesupply contractwithduediligenceandexpeditionor shallrefuseorneglectto complywithanyreasonableordersgiveninwritingbythe purchaseror hisauthorizedagentinconnectionwiththiscontractorshallcontravene thisprovisionofthecontract,the purchasermaygive15daysnoticeinwritingtothe suppliertomakegoodthefailure,neglectorcontraventioncomplainedofandshould theSupplierfailtocomplywiththenoticewithintheabovesaidtimefromthefieldof service thereof (in case of failure, neglect or contravention capable of being made good,withinthattimeorotherwisewithinsuchtimeasmaybereasonably necessary formakingitgood),theninsuchcase,the purchasershallbeatlibertytotakethework



wholly or in part out of Supplier's hand and re-contract at a reasonable price with any other person(s). In such event, it shall be lawful for the purchaser to retain any balance which may otherwise be due by him to the Supplier on any account, and apply the same towards the execution of the whole or balance of the supply contracts so re-contracted, as aforesaid, if no such balance is due by him to the supplier or if due, is not sufficient to cover the amount thus recoverable from the supplier, it shall be lawful for the purchaser to recover the whole or the balance of the amount from the supplier by action at law or otherwise. The remedy under this clause will be in addition to and without prejudice to right available to the purchaser under other clause of these terms and conditions.

19. DESPATCH OF MATERIAL AND DESPATCH INSTRUCTIONS:

The suppliers shall be responsible to obtain complete Dispatch instructions from the purchaser before the dispatch of each consignment.

The supplier shall sufficiently pack at his own cost the material for transit so as to ensure this being free from loss or damage on arrival without opening the packages while in transit at their destination. All containers in which the material is supplied shall be non-returnable.

20. REPLACEMENT AND REJECTION:

Material found sub-standard or defective or not conforming to the prescribed specification in any manner, at consignee's end shall not be accepted and intimation to this effect shall be given to the supplier, the purchasing authority and the Controller of Stores by the consignee. The purchasing authority shall promptly take up the matter with the supplier and ask him to rectify or replace the defective/sub-standard material forthwith and in any case within a period of 45 days from the date of intimation about such defective material by the stores wing, failing which, the Nigam shall reserve the right to get the defect rectified at the supplier's cost or to withhold the amount equal to cost of defective material. The supplier shall also be intimated that all expenses involved in the replacement by way of handling, transportation, storage, etc. shall be to their account. The payments so withheld shall be released after the receipt of repaired/replacement material. In case, the supplier still does not respond for lifting the defective material, despite continuous follow-up, the procedure as prescribed in as per clause no. 21 read with sub-clause 28.1 (a & b) shall be invoked for termination of contract, encashment of BG, imposing LD charges @ 5% of the value of defective/ rejected/ undelivered material and initiation of action for blacklisting etc. Even after expiry of 90 days, if there is no response from the firm, Nigam can deduct the cost of the defective equipments/material from the pending liabilities of the firm, including encashment of the BG of the firm, available with Nigam against the same P.O. or in other cases.

If there is sufficient financial cover against the same or other P.O.s available then

the principal supplier can lift the material against the financial cover of same P.O.s. If the financial cover falls short of cost of material to be lifted for repair/replacement then either he would have to deposit the BG of the balance cost of the equipments through DD or cost thereof in cash.

In respect of the defective/sub-standard supplies, the date on which such a supply is replaced shall be reckoned as the effective date of delivery there against and the delay shall be worked out accordingly with reference to the date on which the supply was due as per the terms of contract, for the purpose of determining penalties/liquidated damages



recoverable under Clause 9 (v).

21. TERMINATION OF CONTRACT FOR DEFAULT

21.1 The purchaser may, without prejudice to any other remedy for breach of contract, by written notice of default sent to the supplier, terminate the contract in whole or in part:

- a) If the supplier fails to deliver any or all of the stores within the time period(s) specified in the contract, or any extension thereof granted by the Purchaser; or
- b) If the supplier fails to perform any other obligation under the contract within the period specified in the contract or any extension thereof granted by the purchaser.
- c) If the supplier, in the judgment of the purchaser has engaged in corrupt or fraudulent practices in competing for or in executing the contract (The definition of corrupt or fraudulent practices defined under clause-25).

21.2 In the event the purchaser terminates the contract in whole or in part. Available EMD submitted by the firm/suppliers shall be forfeited and available BG shall be got encashed towards recovery of LD Charges and any other dues from the firm.

22. SET-OFF:

Any sum of money due and payable to the supplier under the contract (including Security deposit returnable to the supplier) may be appropriated by the purchaser and set-off against any claim of the purchaser for the payment of a sum of money arising out of or under this contract or any other contract entered into by the supplier with the purchaser.

23. SUPPLIER'S DEFAULT LIABILITY:

In the event of breach of any of these terms and conditions by the supplier, the purchaser can terminate the contract without Notice to the supplier at any stage and the supplier shall have no claim whatsoever on the purchaser on this account. But the suppliers shall be liable to pay to the purchaser as a sum equivalent to 5% of the value of the undelivered material as liquidated damages and not as a penalty.

24. LAWS GOVERNING THE CONTRACT

- (i) This contract shall be governed by the Laws of India for the time being in force.
- (ii) Irrespective of the place of delivery, place of performance or place of payment under the contract, the contract shall be deemed to have been made at the place from which the acceptance of tender has been issued.
- (iii) Jurisdiction of courts: The court of the place from where the acceptance of tender has been issued shall alone have exclusive jurisdiction to decide any dispute arising out of or in respect of the contract.

25. Corrupt or Fraudulent Practices

The Nigam requires that Tenderers/Suppliers/Contractors observe the highest standard of ethics during the procurement and execution of Nigam contracts. In pursuance of this policy, the Nigam:-

- (a) Defines, for the purposes of this provision, the terms set forth as follows:
 - (i) "corrupt practice" means the offering, giving, receiving or soliciting of any thing of value to influence the action of a public official in the procurement process or in contract execution; and



- (ii) “fraudulent practice” means a misrepresentation of facts in order to influence procurement process or the execution of a contract to the detriment of the Nigam, and includes collusive practice among Tenderers (prior to or after tenders submission) designed to establish tender prices at artificial, non-competitive levels and to deprive the Nigam of the benefits of free and open competition;
- (b) will reject a proposal for award if it determines that the Tenderer recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question;
- (c) will declare a firm ineligible, either indefinitely or for a stated period of time, to be awarded a Nigam contract if at any time it determines that the firm has engaged in corrupt or fraudulent practices in competing for, or in executing, a Nigam contract.

26. PATENT RIGHTS

The suppliers shall indemnify the Purchaser against all third-party claims of infringement of patent, trademark or industrial design rights arising from use of the Goods or any part thereof in India.

In the event of any claim asserted by a third party of infringement of copyright, patent, trademark or industrial design rights arising from the use of the Goods or any part thereof in the Purchaser's country, the suppliers shall act expeditiously to extinguish such claim. If the supplier fails to comply and the Purchaser is required to pay compensation to a third party resulting from such infringement, the suppliers shall be responsible for the compensation including all expenses, court costs and lawyer fees. The Purchaser will give notice to the supplier of such claim, if it is made, without delay.

27. SETTLEMENT OF DISPUTES

If any dispute or difference of any kind whatsoever arises between the Purchaser and the Supplier in connection with or arising out of the Contract, the parties will make every effort to resolve amicably such dispute or difference by mutual consultation.

If, after thirty (30) days the parties failed to resolve their dispute or difference by such mutual consultation, then either the Purchaser or the Supplier may give notice to the other party of its intention to commence arbitration, as hereinafter provided, as to the matter in dispute, and no arbitration in respect of the matter may be commenced unless such notice is given.

28. Blacklisting of the Firms:

As the purchase order becomes a valid contract between the purchaser and supplier on the date of its issue, no further changes in the terms and conditions thereof are permissible and any request received in this regard from the supplier should be summarily rejected, making it clear to supply the goods strictly in accordance with the terms and conditions of the contract. It should be noted that such a liability can be enforced on the supplier only if the purchase order does not contain any term or condition contrary to what had been quoted in the supplier's tender. Once this is ensured, any attempt by the supplier to back out of his commitment should be taken seriously and his earnest money deposited be forfeited forthwith, without prejudice to any further legal remedies open to the Nigam under



the relevant laws. Where necessary, the case of supplier illegally backing out of the commitment, should also be put up to the Board of Directors for consideration and to decide for black-listing of the firm and damages, if any, to be recovered

28.1. Procedure for Blacklisting of firm

In case the supplier intends to illegally back out of the commitment, the steps for blacklisting of the firm, besides enforcement of damages recoverable under the law will be taken as per procedure given below:-

- a) *A notice shall be served by the purchasing department on the supplier by registered post/speed post bringing his defaults to his notice and asking him to complete all pending supplies / or to settle dispute within a period of 15 days from the date of issue of Notice.*
- b) *In case the firm fails to comply with the notice(s), a show Cause notice of 21 days shall be issued why the firm/supplier/contractor should not be blacklisted. In the Show Cause Notice complete details of the case, default committed by the firm/supplier/contractor and details of notices issued by the Nigam shall be incorporated.*
- d) *In case the supplier/firm/contractor fails to comply with the notice issued for blacklisting or does not respond to show cause notice or the reply as submitted is not found justified/convincing. The contract with the firm/supplier shall be terminated inter-alia*
- e) *taking other action as per regulation no. 20 & further the firm may be blacklisted with the approval of BODs.*
- d) *The period of blacklisting of the defaulting firm/ supplier/contractor will be approved upto 3 years by BOD's and shall be notified to all Power Utilities in the country and the names of such blacklisted supplier/contractor would also be put on the website of the Nigam*

29. ARBITRATION

All the matters, questions, disputes, differences and / or claims arising out of and /or concerning and /or in connection and /or relating to this contract whether or not obligations of either or both parties under this contract be subsisting at the time of such dispute and whether or not this contract has been terminated or purported to be terminated or completed, shall be referred to the Sole Arbitrator to be nominated by Managing Director/DHBVNL or UHBVNL (as the case may be). The Award of the Arbitrator shall be final and binding on the Parties to this contract. Provisions of the Arbitration & conciliation Act, 1996 and the Rules made there under, the statutory modifications thereof for the time being in force, shall be deemed to apply to the Arbitration proceedings under this clause.

Place:

Date:

Signature of the Supplier.

SCHEDULE 'D'

(Part-II, Particular Conditions of Contract)

UTTAR/ DAKSHIN HARYANA BIJLI VITRAN NIGAM LIMITED



PARTICULAR TERMS AND CONDITIONS FOR PROCUREMENT OF EQUIPMENT STORES AND OTHER MATERIAL

The below mentioned terms & conditions shall be applicable in addition to the terms & conditions mentioned in Part-I of Schedule D

1) PRICE :-

The prices quoted shall be 'Variable' as per latest applicable IEEMA formula and 'FOR' destination basis anywhere in Haryana. The breakup of prices quoted viz. Ex-works prices, excise duty, cess, sales tax, freight and insurance etc. should be clearly given in schedule of prices as per details in the enclosed Performa, which is a must. The base date for updating the price will be first working day of the month, one month prior to the date of tender opening without any ceiling.

2) SAMPLE : Not applicable

3) Delivery:

i) Acceptance Early Supplies

- a) In case the material is required early by the Nigam and the purchasing authority requests for the same, then the payment and IEEMA would be regulated as per PO provisions i.e. actual delivery (physical) date shall be considered as due date of delivery.
- b) in case any firm supplied the material earlier than the actual due date of supply, then the payment procedure/terms shall remain the same as per terms and conditions and lots due date mentioned in the relevant PO/work order. Moreover, in case of price variation, the lowest IEEMA between the actual (physical) date of delivery and scheduled date of delivery would be made applicable.

ii) Acceptance of delay supply :-

In case of delayed supply (beyond overall delivery schedule), the same may be considered and accepted by the purchaser with levy of penalty as per provision of PO and for computing the price variation, the lowest IEEMA indices announced by IEEMA during the intervening period from the due date of supply and the date of actual (physical) delivery, would be made applicable.

In case of delayed lots, for computing the price variation the lowest IEEMA indices announced by IEEMA, during the intervening period from the schedule date of delivery to actual (physical) date of delivery, would be applicable.

4) Warranty:-



The supplier shall be made responsible to replace free of cost, with no transportation or insurance-cost to the Nigam, up to the destination, the whole or any part of the material which in normal and proper use proves defective in quality or workmanship, subject to the condition that the defect is noticed within 78 months from the date the material is received by the consignee or 72 months from the date of installation whichever ever period may expire earlier. The consignee or any other officer of the Nigam actually using the material will give prompt notice of each such defect to the supplier as well as the Purchasing authority and the Controller of Stores. The replacement shall be effected by the supplier within a reasonable time, but not, in any

case, exceeding 45 days. The supplier shall also arrange to remove the defective supply within a reasonable period but not exceeding 45 days from the date of issue of the notice in respect thereof, but only after replacement of defective material. Upon the firm failing to do so, the damages/defects may be got rectified by the Nigam and the cost adjusted from the firm's pending dues and/or security deposit against this or any other contract in force and the balance left be got deposited by the supplier. The Nigam may also withhold the amount equal to cost of defective material.

The warranty for 78/72 months shall be one time. In addition to above, warranty should be extended by the supplier for the period for which the service was not rendered by the material/equipment supplied by the supplier which would be allowable for one occasion only. In case of recurrence, the material/ equipment shall have to be replaced afresh or cost of the material shall be recoverable from the pending liabilities of the supplier/contractor towards Nigam.

After completion of overall warranty period, if it is found that any material defective/ damaged within warranty period is still lying in the store/field/with the firm then equivalent amount of cost of material as BG shall be accepted. After receipt of fresh BG, the old BG should be released.

In case of breach of contractual obligations with reference to non responding for repairing /replacement of defective material, notices of 15 days & 21 days shall be issued to the firm and in case of still persistence of default, the Nigam shall reserve the right to terminate the contract, encashment of BG towards recovery of damages and further initiation of action for blacklisting

5) **DRAWINGS:-**

a) Deleted.

b) **Procedure to be followed where specification/design of the product is not standardized but prepared for specific use of Nigam:**

- i- The successful bidder shall submit the drawing as per Nigam's specification/design within 45 days from the date of LOI.
- ii- The purchase Department shall approve the drawings within 10 days from the date of its receipt except in case of observance of deviations there against.
- iii- Time taken in any clarification of the drawings will be attributable to the supplier. In this case the delivery schedule shall commence from the date of



approval of drawing OR 56th day from the date of issue of LOI whichever is earlier.

6) MISTAKES IN DRAWINGS:

The supplier will be responsible for and shall pay for alterations of the material due to any discrepancies, errors or omissions in the drawings or other particulars supplied by him whether such drawings or particulars have been approved by the purchaser or not. Mistakes in drawing will be set right by the Supplier after obtaining approval of the purchaser.

7) TERMS OF PAYMENT:-

Subject to any deductions which the purchaser may be authorized to make under this contract, the payment for the material shall be made as under:-

- (a) One hundred percent payments shall be made on 30th day from the date of receipt of material by the consignee or date of submission of documents i.e. bills/invoices in triplicate, receipted challans, inspection report, prescribed sales tax/excise duty certificates and excised duty gate pass, wherever required etc., whichever is later.
- (b) The Bank Guarantee of the value of 10% [5% in case of Haryana based micro and small enterprises (including khadi and village industries units)] of the contract price of PO for complete requisite period shall be furnished within 15 days from the date of issue of PO which should remain valid for 90 days after the expiry of warranty period (the BG shall be issued by any Nationalized /Private Bank in India, failing which:
 - i) Penalty @ 0.05% per day of the value of BG with a ceiling of 2% of value of BG would be charged from due date of submission, till the BG or DD in lieu of BG is submitted by the firm.
 - ii) In case the performance bank guarantee or DD in lieu of performance security is not submitted within 45 days from the date of issue of PO or the date if any stipulated by the purchasing authority, the Nigam reserves the right to cancel the PO/RC and initiate the action for allotment to L-2 firm.
 - iii) In the event of receipt of material without the receipt of BG, amount equivalent to BG along with penalty shall be deducted from the payments due to the supplier. However, on receipt of requisite BG from the firm, the amount deducted in lieu of the BG only, shall be refunded without accrual of any interest thereon and amount of penalty so deducted shall not be refunded.

Further rebate of 0.05 percent per day shall be availed of by the Nigam if payment is made earlier than the period specified. The rebate will be calculated on the payable amount.

The delay in payment to the suppliers beyond the stipulated credit period indicated in the supply order, unless supported by cogent reasons and approved by a higher authority, would attract penal interest on the defaulting amount @ Rs. 25/- per one lac per day of delay beyond the credit stipulated period. Payment of such interests would be brought to the notice of Administrative Secretary of the department and call for fixation of responsibility. In case of delayed supply duly



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BIJLI VITRAN NIGAM



accepted by the purchasing authority, no penal interest on the same shall be applicable.

In case the due date of payment in terms of payment schedule falls on a holiday including Sunday or holiday is subsequently declared on that date, the payment shall be released on the first working day falling next to the due date.

Place:

Date:

Signature of the Supplier.



Annexure-III

PARTICULARS OF THE BIDDER

1.	Name of the firm	
2.	Postal address.	
3.	Telephone No.	
4.	Fax No.	
5.	Email.	
6.	Type of organization:	
7.	Date of commencement of business.	
8.	Name of proprietor/ Partners/Directors and their detail Bio-data.	Page _____ to _____ page
9.	Details of offices other than H.O./Controlling office and	Page _____ to _____ page
10.	Detailed organizational structure with background of key personnel.	Page _____ to _____ page
11.	Type of service being offered.	Page _____ to _____ page
12.	List of clients' along with their addresses and contact telephone. Fax Nos. and type of services offered and/or being offered to them. Electricity Companies/Board.	Page _____ to _____ page Page _____ to _____ page
13.	Details of Empanelment accreditation Electricity Board/Companies/other Client along with empanelment/ accreditation letter.	Page _____ to _____ page
14.	Balancesheet and P&L Accounts of past 3 financial years.	Page _____ to _____ page
15.	Letters/certificates for successful completion of work from Electricity Companies/ Board/other.	Page _____ to _____ page
16.	Details of any collaboration/ tie up with Indian/Overseas Agency/Organization.	Page _____ to _____ page
17.	Any other additional information/certificate.	Page _____ to _____ page
18.	Details of workforce with the agency.	



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BIJLI VITRAN NIGAM



ANNEXURE 'A' TO SCHEDULE 'D' (Part-I)

UTTAR & DAKSHIN HARYANA BIJLI VITRAN NIGAM

Specification No. 78/R-I/DH/UH/P&D/2015-16

TECHNICAL SPECIFICATION

OF

**“3.5 & 5.0 MVA, 33 / 3.3 kV Power
Transformer”**

Issue Month: Common Specifications Committee
DHBVN & UHBVN



UTTAR & DAKSHIN HARYANA BILJI VITRAN NIGAM

TECHNICAL SPECIFICATION FOR 33/3.3 KV 3.5 & 5 MVA POWER TRANSFORMER

1.0 SCOPE

1.1 These specifications are to cover design, engineering, manufacture, testing/ inspection before dispatch, forwarding, packing, transportation to site, insurance (during transit, storage), storage, of three phase, 50 Hz, 3.5 & 5.0 MVA, 33/3.3KV step-down Outdoor ONAN Power transformers complete with all accessories/fittings, for use in sub-transmission and Distribution systems. The transformer shall be equipped with surge arrestors at HV and LV side. The surge arrestors shall also be mounted on the bracket fitted on the transformer. Contractor shall be responsible of properly choosing the rating of the surge arrestors on HT and LT side both including coordination with other arrestor installed in the sub-station. The offered material shall be complete with all the accessories and components necessary for their desired / effective and trouble free operation. Such components shall be deemed to be within the scope of Bidders supply irrespective of whether those are specifically brought out in this specification and / or the commercial order or not.

1.1.1 CLIMATIC CONDITIONS:

The equipment/material to be supplied against this specification shall be suitable for satisfactory operation under the following climatic Conditions.

The equipment/material to be supplied against this specification shall be suitable for satisfactory operation under the following climatic conditions

i)	Location	At various locations in the state of Haryana
ii)	Maximum ambient temperature (°C)	60
iii)	Minimum ambient air temperature (°C)	-5
iv)	Maximum average daily ambient temperature (°C)	40
v)	Maximum yearly weighed average ambient temperature (°C)	32
vi)	Maximum altitude above mean sea level (Meters)	1000
vii)	Minimum Relative Humidity (%age)	26
viii)	Maximum Relative Humidity (%age)	95
ix)	Average no of Rainy days/ year	120
x)	Average annual rainfall	900 mm
xi)	Maximum wind pressure	195 kg/m sq.



The equipment shall be for use in moderately hot and humid tropical climate, conducive to rust and fungus growth.

1.2 SPECIFIC TECHNICAL REQUIREMENTS (STANDARD CONDITIONS)

1.	Rated MVA (ONAN rating)	3.5 & 5.0 MVA
2.	No. of phases	3
3.	Type of Installation	Outdoor
4.	Frequency	50 Hz
5.	Cooling medium	Insulating oil
6.	Rated voltage: a) High voltage winding	33 kV
	b) Low voltage winding	3.3 kV
7..	Highest continuous system voltage	
	a) HV Side	36 kV
	b) LV side	3.6 kV
8.	Type of tap changer	Off-load tap changer
9.	Range tapings	+5% to -10% in 6 equal steps of 2.5% each on HV winding
10.	Neutral terminal to be brought out	On LV side only
11.	Impedance on rated MVA base at 75°C (3.5 & 5.0 MVA)	6.25% with tolerance limits as per IS
12.	Type of insulation and insulation level	Uniform
13.	One minute power frequency withstand test (KV rms)	33 kV 11kV
		70 10
14.	Impulse withstand test voltage (KV Peak)	As per IS 2026
15.	Winding connection	
	a) HV Side b) LV Side	Delta Star
16..	Winding material	Electrolytic Copper
17.	Vector group	Dyn 11
18..	Type of cooling	ONAN
19.	Neutral earthing	LV neutral shall be solidly earthed
20.	Winding temperature indicator	One No.
21.	Provision for differential Protection for differential	Yes
22.	Oil temperature indicator	One No.
23.	No load losses at rated voltage and frequency (KW)	3.5 MVA=3.0 KW 5.0 MVA= 4.0 KW
		3.5 MVA=16.0 KW 5.0 MVA= 23.0 KW
24.	Load Losses at 75° C (KW)	



1.2.1 MAXIMUM TEMPERATURE RISE OVER AN AMBIENT OF 45⁰

a)	Temperature rise of top oil 50 ⁰ C	(Measured by thermometer)
b)	Temperature rise of winding 50 ⁰ C	(Measured by resistance)

The rise in temperature of top-oil and winding given above shall be reduced as per clause 3.2 & 3.3 of IS: 2026 (part-I) in case of increase in Ambient above 50⁰ C and an increase in altitude above 1000m.

1.2.2 RATING & SERVICES

a) Over load capacity As per IS:6600

1.2.3 NOISE LEVEL AT RATED VOLTAGE & FREQUENCY

As per NEMA Publication No. TR-I.

1.2.4 MARSHALLING BOX

A metal enclosed, weather, vermin and dust proof marshalling box fitted with required glands, locks, glass door, terminal board, heater with switch, illumination lamp with switch etc. shall be provided with each transformer to accommodate temperature indicators, terminal blocks etc. It shall have a degree of protection of IP 55 as per IS:2147 (Refer Clause 3.12).

1.2.5 Rejection of Power Transformer.

- i) In case during the test, the actual losses are found within guaranteed figures, the transformer shall be accepted without any advantage to the supplier / contractor for lower loss.
- ii) When actual losses during testing are found in excess of maximum guaranteed figures, the transformer shall be rejected.

1.3 PERFORMANCE

- i) Transformer shall be capable of withstanding for two seconds without damage to any external short circuit, with the short circuit MVA available at the terminals.
- ii) The maximum flux density in any part of the core and yoke at rated MVA, voltage and frequency shall be such that the flux density under 12.5% over voltage condition shall not exceed 1.9 Tesla.
- iii) Transformer shall under exceptional circumstances due to sudden disconnection of the load, be capable of operating at the voltage approximately 25% above normal rated voltage for a period of not exceeding one minute and 40% above normal for a period of 5 seconds.
The transformer may be operated continuously without danger on any particular tapping at the rated MVA $\pm 12.5\%$ of the voltage corresponding to the tapping.
- v) The thermal ability withstand short circuit shall be demonstrated by calculation.
- vi) With combined voltage variation of +12.5% and frequency variation of -5%, the flux density shall not exceed 1.9 Tesla.
- vii) Transformer shall be capable withstanding thermal and mechanical stress caused by any symmetrical and asymmetrical faults on any winding.
- viii) DGA of oil shall be periodically monitored by the employer and the interpretation of DGA results shall be as per IEC – 599.



- ix) The transformers shall be capable of being loaded in accordance with IS:6600/IEC-354. There shall be no limitation imposed by bushings, tap changers etc. or any other associated equipment.
- x) Transformers shall withstand, without injurious heating, combined voltage and frequency fluctuations which produce the following over fluxing conditions:
 - i) 125% for 1 – minute
 - 140% for 5 – seconds
 - ii) Bidder shall indicate 150% and 170% over voltage withstand time.

AUXILIARY POWER SUPPLIES

The following power supplies shall be available at site:

- i) AC, 3 phase, 400 volts, 50 Hz, earthed
- ii) AC, 1 phase, 230 volts, 50 Hz, earthed
- iii) 24V DC

1.4 DRAWINGS/DOCUMENTS INCORPORATING THE FOLLOWING

PARTICULARS SHALL BE SUBMITTED WITH THE BID

- a) The contractor shall furnish, within fifteen days after issuing of Letter of Award, six copies each of the following drawings/documents incorporating name of project and transformer rating for approval.
 - i) Detailed overall general arrangement drawing showing front and side elevations and plan of the transformer and all accessories including radiators and external features with details of dimensions, spacing of wheels in either direction of motion, net weights and shipping weights, crane lift for un-tanking, size of lugs and eyes, bushing lifting dimensions, clearances between HV and LV terminals and ground, quantity of insulating oil etc.
 - ii) Foundation plan showing loading on each wheel and jacking points with respect to centre line of transformer.
 - iii) GA drawings/details of bushing and terminal connectors.
 - iv) Name plate drawing with terminal marking and connection diagrams.
 - v) Wheel locking arrangement drawing.
 - vi) Transportation dimensions drawings.
 - vii) Magnetization characteristic curves of PS class neutral and phase side current transformers, if applicable.
 - viii) Interconnection diagrams.
 - ix) Over fluxing withstand time characteristic of transformers.
 - x) GA drawing of marshalling box.
 - xi) Control scheme/wiring diagram of marshalling box
 - xii) Technical leaflets of major components and fittings.



- xiii) As built drawings of schematics, wiring diagram etc.
 - xiv) Setting of oil temperature indicator, winding temperature indicator.
 - xv) Completed technical data sheets.
 - xvi) Details including write-up of tap changing gear.
 - xvii) H.V. conductor bushing.
 - xviii) Bushing assembly
 - xix) Bi-metallic connector for connection to 'Wolf' ACSR conductor.
 - xx) Radiator type assembly
- b) All drawings/documents, technical data sheets and test certificates/results/calculations shall be furnished.
- c) Any approval given to the detailed drawings by the purchaser shall not relieve the contractor of the responsibility for correctness of the drawing and in the manufacture of the equipment. The approval given by the purchaser shall be general with over all responsibility of the manufacturer.

1.5 MISCELLANESOUS

- i) Padlocks alongwith duplicate keys as asked for various valves, marshalling box etc. shall be supplied by the contractor, wherever locking arrangement is provided.
 - ii) Foundation bolts for wheel locking devices of transformer shall be supplied by the Contractor.
- 1.6 The equipment shall be delivered, erected and commissioned at site in case of turnkey contract executions.

1.7 SERVICES AND EQUIPMENT

The following is also in the Contractor's scope of work for turnkey executions only:

- i) Design of soak pit, cable trenches and foundations for transformers and other ground mounted equipment.
- ii) Construction of soak pit, cable trenches and foundations for transformers and other ground mounted equipment.
- iii) All the civil works.

1.8 SCHEDULES

All schedules annexed to the specification, shall be duly filled by the bidder separately.

1.9 NAME PLATE

Transformer rating plate shall contain the information as given in clause 15 of IS-2026 (Part-I). The details on rating plate shall be finalized during the detailed engineering. Further each transformer shall have inscription of Purchaser name and clear mention of "Property of UHBVN/DHBVN".



2.0 GENERAL TECHNICAL REQUIREMENT

2.1 CODES AND STANDARDS

- i) The design, material, fabrication, manufacture, inspection, testing before dispatch, erection, testing, commissioning and performance of power transformers at site shall comply with all currently applicable statutory regulations and safety codes in the locality where the equipment will be installed. The equipment shall also conform to the latest applicable standards and codes of practice. Nothing in this specification shall be construed to relieve the contractor of this responsibility.
- ii) Transformers shall conform to the current applicable standards and codes of

practice as specified in clause no. 2.2.

- 2.2 The equipment, materials and service covered by this specification shall conform to the latest applicable provision of the following standards:

IS:5	Colour for ready mixed paints
IS:325	Three Phase Induction Motors
IS:325	New insulating oil for transformers, Switchgears
IS:1271	Classification of insulating materials for electrical machinery and apparatus in relation to their stability in services.
IS:2026(Part I to IV)	Power transformer
IS:2071	Method of high voltage testing
IS:2099	High voltage porcelain bushings
IS:2147	Degree of protection
IS:2705	Current transformers
IS:3202	Code of practice for climate proofing of electrical equipment.
IS:3347	Dimensions for porcelain transformer bushings
IS:3637	Gas operated relays
IS:3639	Fittings and accessories for power transformers
IS:5561	Electric Power Connectors
IS:6600/BS:CP1010	Guide for loading of oil immersed transformers
IS:10028	Code of practice for selection, installation and maintenance of transformers, Part I, II & III.
C.B.I.P. Publication	Manual on transformers

If the standard is not quoted for any item, it shall be presumed that the latest version of Indian Standard shall be applicable to that item.

The equipment complying other internationally accepted standards, may also be considered if they ensure performance superior to the Indian standards.

3.0 GENERAL CONSTRUCTIONAL FEATURES

- 3.1 All material used shall be of best quality and of the class most suitable for working under the conditions specified and shall withstand the variations of temperature and atmospheric conditions without distortion or deterioration or the setting up of undue stresses which may impair suitability of the various parts for the work which they have to perform.
- 3.2 Similar parts, particularly removable ones, shall be interchangeable.



- 3.3 Pipes and pipe fittings, screws, studs, nuts and bolts used for external connections shall be as per the relevant standards. Steel bolts and nuts exposed to atmosphere shall be galvanized.
- 3.4 Nuts, bolts and pins used inside the transformers and tap changer compartments shall be provided with lock washers or locknuts.
- 3.5 Exposed parts shall not have pickets where water can collect.
- 3.6 Internal design of transformer shall ensure that air is not trapped in any location.
- 3.7 Material in contact with oil shall be such as not to contribute to the formation of acid in oil. Surface in contact with oil shall not be galvanized or cadmium plated.
- 3.8 Labels, indelibly marked, shall be provided for all identifiable accessories like relays, switches, current transformers etc. All label plates shall be of in corrodible material.
- 3.9 All internal connections and fastenings shall be capable of operating under overloads and over excitation, allowed as per specified standards without injury.
- 3.10 Transformer and accessories shall be designed to facilitate proper operation, inspection, maintenance and repairs.
- 3.11 No patching, plugging, shimming or other such means of overcoming defects, discrepancies or errors will be accepted.
- 3.12 Schematic drawing of the wiring, including external cables shall be put under the pros pane sheet on the inside door of the transformer marshalling box.

3.13 Painting

3.13.1 All paints shall be applied in accordance with the paint manufacturer's recommendations. Particular attention shall be paid to the following:

- a) Proper storage to avoid exposure as well as extremes of temperature.
- b) Surface preparation prior to painting.
- c) Mixing and thinning.
- d) Application of paints and the recommended limit on time intervals between coats.
- e) Shelf life for storage.

3.13.1.1 All paints, when applied in normal full coat, shall be free from runs, sags, wrinkles, patchiness, brush marks or other defects.

3.13.1.2 All primers shall be well marked into the surface, particularly in areas where painting is evident, and the first priming coat shall be applied as soon as possible after cleaning. The paint shall be applied by airless spray according to the manufacturer's recommendation. However, wherever airless spray is not possible, conventional spray be used with prior approval of purchaser.

3.13.1.3 The supplier shall, prior to painting protect nameplates, lettering gauges, sight glasses, light fittings and similar such items.

3.13.2 Cleaning and Surface Preparation:

3.13.2.1 Surface preparation for tank, pipes, etc.-



All surfaces of transformer tank, pipes etc. shall be thoroughly blast cleaned with sand or shot or grit in accordance with ISO 8501 Part 1 to a minimum standard of Sa21/2 to make the surface free from visible oil, grease and dirt, mill scale, rust, paint coatings and foreign matter. Machined areas and threaded components etc. are to be covered during blasting to prevent damage.

The air that is used for blasting should be dry and free from oil. The flanges, angles, tank curbs and other such areas shall be preferably blast cleaned prior to fabrication and paint these with one coat of primer. After adequate blast cleaning of each large surface where blasting time is more than three hours, an overall blast cleaning is to be done on the entire surface once more so that entire surface areas ie exposed as fresh for first coat of primer paint. The first coat of primer paint should be applied not later than 3-4 hours after preparation of surface to avoid oxidation.

3.13.2.2 **Surface preparation for radiator-**

All internal and external surfaces of radiator shall be thoroughly cleaned either by chemical cleaning or by blast with sand or shot or grit in accordance with ISO 8501 Part 1 to make the surface free from visible oil, grease and dirt, mill scale, rust, paint coatings and foreign matter. Suitable chemical should be used for chemical cleaning, if required. The air that is used for blasting should be dry and free from oil. After adequate surface cleaning, the first coat of primer paint/varnish should be applied not alter than 3-4 hours after preparation of surface to avoid oxidation.

3.13.2.3 **Painting-external & internal surfaces-**

Painting shall be carried out in closed and dust free area. The external surfaces shall be coated with suitable layers of paint and to form an impermeable layer so that air and water cannot reach the substrate. The paint selected shall be stable in outdoor condition such as rain, sunlight, pollution etc. Paint used for primer, under coat and top or finish coat should be from the same manufacturer and compatible to each other. In case in the rare event, paint used for primer, under coat and finish coat are not from the same manufacturer the compatibility test of the paint from different source shall be carried out. Painting shall be applied as per the recommendation of the paint manufacturer. The number of coats shall be such that the minimum dry film thickness (DFT) specified is achieved. The DFT of painted surface shall be checked with a measuring gauge to ensure specified DFT. Complete painting scheme for the transformer is tabulated below:

3.13.2.4 Painting-Transformer tank, pipes, radiator etc.-

Description	Surface preparation	Primer coat	Intermediate undercoat	Finish coat	Total DFT	Colour shade
Tank, pipes etc. (External surfaces)	Blast cleaning Sa2½	Epoxy base Zinc primer (30-40 µm)	Epoxy HB MIO (30-40µm)	Aliphatic Polyurethane (Min 50 µm)	Min. 155 µm	697 shade as per IS:5
Tank. (Internal surfaces)	Blast cleaning Sa2½	Hot oil resistant, non-corrosive varnish or paint or epoxy	--	--	Min. 30 µm	Glossy white for paint
Radiator (External surfaces)	Chemical/blast cleaning (Sa2½)	Epoxy base Zinc primer (30-40 µm)	Epoxy base Zinc primer (30-40 µm)	PU paint (Min. 50 µm)	Min. 110 µm	Matching Shade of tank./different shade aesthetically matching to tank
Radiator & pipes. (Internal surfaces)	Chemical cleaning if required	Hot oil proof, Low viscosity varnish, flushing with transformer oil.	-	-	-	-

3.13.3 Surface preparation for control cabinets/Marshalling Boxes-

3.13.3.1 Surface preparation for all transformer control cabinets/Marshalling boxes shall be carried out confirming to following Indian Standard in dust free area:

i) IS: 3618:Degreasing by solvent wiping: Phosphate Treatment of Iron & Steel for protection against corrosion.

ii) IS:6005: Code of practice for phosphating of Iron and Steel

3.13.3.2 Chemicals: Suitable chemicals should be used and concentration of chemicals/weight of phosphate coating should be regularly as per recommendation of the chemical manufacturer and applicable IS.

3.13.4 Inspection: The surface for application of paint should be dry, free from oil, dirt, acid & loose adhering powder and reasonably smooth in finish without uncovered areas, rusty surfaces and roughness.

3.13.5 Painting: Control cabinets/Marshalling Boxes-enamel paint shall be used with total paint thickness as minimum 80 microns.



4.0 DETAILED DESCRIPTION

4.1 Tank

- 4.1.1 The transformer tank and cover shall be fabricated from high grade low carbon plate steel of tested quality. The tank and the cover shall be of welded construction.
- 4.1.2 Tank shall be designed to permit lifting by crane or jacks of the complete transformer assembly filled with oil. Suitable lugs and bosses shall be provided for this purpose.
- 4.1.3 All beams, flanges, lifting lugs, braces and permanent parts attached to the tank, shall be welded and where practicable, they shall be double welded.
- 4.1.4 The main tank body of the transformer excluding tap changing compartments and radiators shall be capable of withstanding pressure of 760mm of Hg.
- 4.1.5 Inspection hole(s) with welded flange(s) and bolted cover(s) shall be provided on the tank cover. The inspection hole(s) shall be of sufficient size to afford easy access to the lower ends of the bushings, terminals etc.
- 4.1.6 All bolted connections to the tank shall be fitted with suitable oil-tight single piece of Nitrile Rubber gaskets or equivalent which shall give satisfactory service under the operating conditions for complete lift of the transformer. Special attention shall be given to the methods of making the hot oil-tight joints between the tank and the cover as also between the tank cover and the bushings and all outlets to ensure that the joint can be remade satisfactorily and with ease, with the help of semi-skilled labour. Where compressible gaskets are used, steps shall be provided to prevent over compression.
- 4.1.7 Suitable guides shall be provided for positioning the various parts during assembly or dismantling. Adequate space shall be provided between the cores and windings and the bottom of the tank for collection of any sediment.

4.2 TANK COVER

The transformer top shall be provided with a detachable tank cover with bolted flanged gasket joint. Lifting lugs shall be provided for removing the cover. The surface of the cover shall be suitably sloped so that it does not retain rain water.

4.3 UNDER CARRIAGE

- 4.3.1 The transformer tank shall be supported on steel structure with detachable plain rollers completely filled with oil. Suitable channels for movement of roller with transformer shall be spaced accordingly. Rollers Wheels shall be provided with suitable roller bearings, which will resist rust and corrosion and shall be equipped with fittings for lubrication. It shall be possible to swivel the wheels in two directions, at right angle to or parallel to the main axis of the transformers.
- 4.3.2 Jacking pads shall be provided on the transformer. It shall be possible to change the direction of the wheels through 90 degree when the transformer is lifted on jacks to permit movement of the transformer both in longitudinal and transverse directions.

4.4 CORE

- 4.4.1 The core shall be wound or cut or stack type.
- 4.4.2 Stage level inspection for core construction shall be carried out by the owner.
- 4.4.3 Each lamination shall be insulated such that it will not deteriorate due to mechanical pressure and the action of hot transformer oil.



- 4.4.4 The core shall be constructed either from high grade, non-aging Cold Rolled Grain Oriented (CRGO) silicon steel laminations conforming to grade M4 or better or of amorphous metal. The amorphous core shall be of high quality amorphous ribbons having very low loss formed into wound cores rectangular shape and clamped together by frames firmly to prevent vibration or noise. The maximum flux density in any part of the cores and yoke at normal voltage and frequency shall be such that the flux density with + 12.5% voltage variation from rated voltage and frequency variation of -5% shall not exceed 1.9 tesla. The bidder shall provide saturation curve of the core material proposed to be used.
- 4.4.5 The bidder should offer the core for inspection and approval by the purchaser during the manufacturing stage. Bidder's call notice for the purpose should be accompanied with the following documents as applicable as a proof towards use of prime core material:
- Invoice of the supplier
 - Mills test certificate
 - Packing list
 - Bill of lading
 - Bill of entry certificate to customs
- Core material shall be directly procured either from the manufacturer or through their accredited marketing organization of repute and not through any agent.
- 4.4.6 The laminations shall be free of all burrs and sharp projections. Each sheet shall have an insulating coating resistant to the action of hot oil.
- 4.4.7 The insulation structure for the core to bolts and core to clamp plates shall be such as to withstand 2000V DC voltage for one minute.
- 4.4.8 The completed core and coil shall be so assembled that the axis and the plane of the outer surface of the core assembly shall not deviate from the vertical plane by more than 25 mm.
- 4.4.9 All steel sections used for supporting the core shall be thoroughly shot or sand blasted, after cutting, drilling and welding.
- 4.4.10 The finally assembled core with all the clamping structures shall be free from deformation and shall not vibrate during operation.
- 4.4.11 The core clamping structure shall be designed to minimize eddy current loss.
- 4.4.12 The frame work and clamping arrangements shall be securely earthed.
- 4.4.13 The core shall be carefully assembled and rigidly clamped to ensure adequate mechanical strength.
- 4.4.14 Oil ducts shall be provided, where necessary, to ensure adequate cooling inside the core. The welding structure and major insulation shall not obstruct the free flow of oil through such ducts.
- 4.4.15 The design of magnetic circuit shall be such as to avoid static discharges, development of short circuit paths within itself or to the earthed clamping structure and production of flux component at right angle to the plane of the lamination, which may cause local heating. The supporting framework of the cores shall be so designed as to avoid the presence of pockets, which would prevent complete emptying of the tank through the drain valve or cause trapping of air during filling.
- 4.4.16 The construction is to be of 'core' type. The core shall be provided with lugs suitable for lifting the complete core and coil assembly. The core and coil assembly shall be so fixed in the tank that shifting will not occur during transport or short circuits.
- 4.5 INTERNAL EARTHING**



- 4.5.1 All internal metal parts of the transformer, with the exception of individual laminations, core bolts and their individual clamping plates shall be earthed.
- 4.5.2 The top clamping structure shall be connected to the tank by a copper strap. The bottom clamping structure shall be earthed by one or more of the following methods:
- By connection through vertical tie-rods to the top structure.
 - By direct metal to metal contact with the tank base.
 - By a connection to the top structure on the same side of the core as the main earth connection to the tank.
 - The magnetic circuit shall be connected to the clamping structure at one point only and this shall be brought out of the top cover of the transformer tank through a suitably rated insulator. A disconnecting link shall be provided on transformer tank to facilitate disconnections from ground for IR measurement purpose.
- 4.5.3 Coil clamping rings of metal at earth potential shall be connected to the adjacent core clamping structure on the same side as the main earth connections.

WINDING

- 4.5.4 Winding shall be subjected to a shrinking and seasoning process, so that no further shrinkage occurs during service. Adjustable devices shall be provided for taking up possible shrinkage in service.
- 4.5.5 All low voltage windings for use in the circular coil concentric winding shall be wound on a performed insulating cylinder for mechanical protection of the winding in handling and placing around the core.
- 4.5.6 Winding shall not contain sharp bends which might damage the insulation or produce high dielectric stresses. No strip conductor wound on edge shall have width exceeding six times the thickness.
- 4.5.7 Materials used in the insulation and assembly of the windings shall be insoluble, non catalytic and chemically inactive in the hot transformer oil and shall not soften or the otherwise affected under the operating conditions.
- 4.5.8 Varnish application on coil windings may be given only for mechanical protection and not for improvement in dielectric properties. In no case varnish or other adhesive be used which will seal the coil and prevent evacuation of air and moisture and impregnation by oil.
- 4.5.9 Winding and connections shall be braced to withstand shocks during transport or short circuit.
- 4.5.10 Permanent current carrying joints in the windings and leads shall be welded or brazed. Clamping bolts for current carrying parts inside oil shall be made of oil resistant material which shall not be affected by acidity in the oil steel bolts, if used, shall be suitably treated.
- 4.5.11 Terminals of all windings shall be brought out of the tank through bushings for external connections.



- 4.5.11.1 The completed core and coil assembly shall be dried in vacuum at not more than 0.5mm of mercury absolute pressure and shall be immediately impregnated with oil after the drying process to ensure the elimination of air and moisture within the insulation. Vacuum may be applied in either vacuum over or in the transformer tank.
- 4.5.11.2 The winding shall be so designed that all coil assemblies of identical voltage ratings shall be interchangeable and field repairs to the winding can be made readily without special equipment. The coils shall have high dielectric strength.
- 4.5.11.3 Coils shall be made of continuous smooth high grade electrolytic copper conductor, shaped and braced to provide for expansion and contraction due to temperature changes.
- 4.5.11.4 Adequate barriers shall be provided between coils and core and between high and low voltage coil. End turns shall have additional protection against abnormal line disturbances.
- 4.5.11.5 The insulation of winding shall be designed to withstand voltage stress arising from surge in transmission lines due to atmospheric or transient conditions caused by switching etc.
- 4.5.11.6 Tapings shall not be brought out from inside the coil or from intermediate turns and shall be so arranged as to preserve as far as possible magnetic balance of the transformer at all voltage ratios.
- 4.5.11.7 Magnitude of impulse surges transferred from HV to LV windings by electro magnetic induction and capacitance coupling shall be limited to B.I.L. of LV winding.

4.6 INSULATING OIL

- 4.6.1 The insulating oil for the transformer shall be of EHV grade, generally conforming to IS:335. No inhibitors shall be used in the oil.
- 4.6.2 The quantity of oil required for the first filling of the transformer and its full specification shall be stated in the bid. The bidder shall quote the price of transformer complete with first filling of oil plus 10% extra. The transformer oil shall be supplied in non-returnable drums.
- 4.6.3 The design and materials used in the construction of the transformer shall be such as to reduce the risk of the development of acidity in the oil.



4.6.4 The contractor shall warrant that oil furnished is in accordance with the following specification:

Sr. No.	Characteristic	Requirement	Method of Test
1.	Appearance	The oil shall be clear & transparent & free from suspended matter or sediment	A representative sample of oil shall be examined in a 100 mm thick layer at ambient temp.
2.	Density at 20°C	0.89 g/cm ³ Max.	IS:1448
3.	Kinematic viscosity at 27°C Max.	27 CST	IS:1448
4.	Interfacial tension at 27°C Min.	0.03 N/m	IS:6104
5.	Flash point	136°C	IS:1448
6.	Pour point Max.	- 6°C	IS:1448
7.	Neutralization value (Total acidity) Max.	0.03 mg KOH/gm	IS:335
8.	Electric strength breakdown (Voltage) Min.	Less than 72.5 kV	IS:6792
9.	Dielectric dissipation factor tan delta at 90°C	0.03 Max.	IS:6262
10.	Min. specific resistance (resistivity) at 90°C	35×10^{12} ohm cm (min.)	IS:6103
11.	Oxidation stability		
12.	Neutralization value after oxidation	0.04 mg KOH/g	
13.	Total sludge after oxidation	0.10% by weight max.	
14.	Presence of oxidation inhibitor	The oil shall not contain anti-oxidant Additives.	IS:335
15.	Water content Max.	Less than 25 ppm	IS:2362



4.8 VALVES

- i) Valves shall be of forged carbon steel up to 50 mm size and of gun metal or of cast iron bodies with gun metal fittings for sizes above 50 mm. They shall be of full way type with screwed ends and shall be opened by turning counter clockwise when facing the hand wheel. There shall be no oil leakage when the valves are in closed position.
- ii) Each valve shall be provided with an indicator to show the open and closed positions and shall be provided with facility for padlocking in either open or closed position. All screwed valves shall be furnished with pipe plugs for protection. Padlocks with duplicate keys shall be supplied along with the valves.
- iii) All valves except screwed valves shall be provided with flanges having machined faced drilled to suit the applicable requirements. Oil tight blanking plates shall be provided for each connection for use when any radiator is detached and for all valves opening to atmosphere. If any special radiator valve tools are required, the contractor shall supply the same.
- iv) Each transformer shall be provided with following valves on the tank:
 - a) Drain valve so located to completely drain the tank.
 - b) Two filter valves on diagonally opposite corners of 50 mm size.
 - c) Oil sampling not less than 8mm at top and bottom of main tank.
 - d) One 15 mm air release plug.
 - e) Valves between radiators & tank

4.9 ACCESSORIES

4.9.1 Bushing

- ii) All porcelain used in bushings shall be homogeneous, non-porous, uniformly glazed to brown colour and free from blisters, burns and other defects.
- iii) Stress due to expansion and contraction in any part of the bushing shall not lead to deterioration.
- iv) Bushing shall be designed and tested to comply with the applicable standards.
- v) Liquid/oil filled bushings shall be equipped with liquid level indicators and means for sampling and draining the liquid.
The angle of inclination to vertical shall not exceed 30 degree.
- vi) Oil in oil-filled bushings shall meet the requirements of the transformer oil standards.
- vii) Bushing rated for 400A and above shall have non-ferrous flanges and hardware.
- vii) Fittings made of steel or malleable iron shall be galvanized.



- ix) Bushing shall be so located on the transformers that full flashover strength will be utilized. Minimum clearances as required for the BIL shall be realized between live parts and live parts to earthed structures.
- x) All applicable routine and type tests certificates of the bushings shall be furnished for approval.
- xi) Bushing shall be supplied with bi-metallic/terminal connector/ clamp/washers suitable for fixing to bushing terminal and the PURCHASER'S specified conductors. The connector/ clamp shall be rated to carry the bushing rated current without exceeding a temperature rise of 55°C. The connector/ clamp shall be designed to be corona free at the maximum rated line to ground voltage.
- xii) Bushing of identical voltage rating shall be interchangeable.
- xiii) The insulation class of high voltage neutral bushing shall be properly coordinated with the insulation class of the neutral of the low voltage winding.
- xiv) Each bushing shall be so coordinated with the transformer insulation that all flashover will occur outside the tank.

4.9.2 Protection & Measuring Devices

- i) Oil Conservator Tank
 - (a) The conservator tank shall have adequate capacity between highest and lowest visible levels to meet the requirement of expansion of the total cold oil volume in the transformer and cooling equipment.
 - (b) The conservator tank shall be bolted into position so that it can be removed for cleaning purposes.
 - (c) The conservator shall be fitted with magnetic oil level gauge with low level electrically insulated alarm contact.
 - (d) Plain conservator fitted with silica gel breather.
- ii) Pressure Relief Device

The pressure relief device provided shall be of sufficient size for rapid release of any pressure that may be generated in the tank and which may result in damage of the equipment. The device shall operate at a static pressure of less than the hydraulic test pressure of transformer tank. It shall be mounted direct on the tank. A pair of electrically insulated contacts shall be provided for alarm and tripping.



- iii) Buchholz relay
A double float type Buchholz relay shall be provided. Any gas evolved in the transformer shall collect in this relay. The relay shall be provided with a test cock suitable for a flexible pipe connection for checking its operation. A copper tube shall be connected from the gas collector to a valve located about 1200 mm above ground level to facilitate sampling with the transformer in service. The device shall be provided with two electrically independent potential free contacts, one for alarm on gas accumulation and the other for tripping on sudden rise of pressure.

iv) Temperature Indicator

(a) Oil Temperature Indicator (OTI)

The transformers shall be provided with a 150 mm dial type thermometer for top oil temperature indication. The thermometer shall have adjustable, electrically independent potential free alarm and trip contacts. Maximum reading pointer and resetting device shall be mounted in the local control panel. A temperature-sensing element suitably located in a pocket on top oil shall be furnished. This shall be connected to the OTI by means of capillary tubing. Accuracy class of OTI by means of capillary tubing. Accuracy class of OTI shall be $\pm 1\%$ or better. One No electrical contact capable of operating at 5A AC at 230 Volt supply.

(b) Winding temperature indicator (WTI)

A device for measuring the hot spot temperature of the winding shall be provided. It shall comprise the following:

- i) Temperature sensing element.
- ii) Image Coil
- iii) Auxiliary CTS, if required to match the image coil, shall be furnished and mounted in the local control panel.
- iv) 150 mm dial local indicating instrument with maximum reading pointer mounted in local panel and with adjustable electrically independent ungrounded contacts, besides that required for control of cooling equipment, one for high winding temperature alarm and one for trip.



- v) Calibration device.
- vi) Two number NO electrical contact with each capable of operating at 5 A ac at 230 Volt supply.

4.9.3 Oil Preservation equipment

4.9.3.1 Oil Sealing

The oil preservation shall be diaphragm type oil sealing in conservator to prevent oxidation and contamination of oil due to contact with atmospheric moisture.

The conservator shall be fitted with a dehydrating filter breather. It shall be so designed that,

- i) Passage of air is through a dust filter and silica gel.
- ii) Silica gel is isolated from atmosphere by an oil seal.
- iii) Moisture absorption indicated by a change in colour of the crystals of the silica gel can be easily observed from a distance.
- iv) Breather is mounted not more than 1400 mm above rail top level.

4.10 MARSHALLING BOX

- i) Sheet steel, weather, vermin and dust proof marshalling box fitted with required glands, locks, glass door, terminal board, heater with switch, illumination lamp with switch, water tight hinged and padlocked door a suitable construction shall be provided with each transformer to accommodate temperature indicators, terminal blocks etc. The box shall have slopping roof and the interior and exterior painting shall be in accordance with the specification.
Padlock alongwith duplicate keys shall be supplied for marshalling box. The degree of protection shall be IP55.
- ii) The schematic diagram of the circuitry inside the marshalling box be prepared and fixed inside the door under a pros pone sheet.
- iii) The marshalling box shall accommodate the following equipment:
 - (a) Temperature indicators
 - (b) Space for accommodating Control & Protection equipment in future
for the cooling fan (for ONAF type cooling, may be provided in future).
 - (c) Terminal blocks and gland plates for incoming and outgoing cables.

All the above equipment except (c) shall be mounted on panels and back of panel wiring shall be used for inter-connection. The

temperature indicators shall be so mounted that the dials are not more than 1600 mm from the ground level and the door(s) of the compartment(s) shall be provided with glazed window of adequate size. The transformer shall be erected on a plinth which shall be 2.5 feet above ground level.

- iv) To prevent internal condensation, a metal clad heater with thermostat shall be provided. The heater shall be controlled by a MCB of suitable rating mounted in the box. The ventilation louvers, suitably padded with felt, shall also be provided. The louvers shall



be provided with suitable felt pads to prevent ingress of dust.

- v) All incoming cables shall enter the kiosk from the bottom and the gland plate shall not be less than 450 mm from the base of the box.

The gland plate and associated compartment shall be sealed in suitable manner to prevent the ingress of moisture from the cable trench.

- vi) The control connection, wiring etc. shall be as per clause 3.15 of this specification.

4.11 OFF LOAD TAP CHAGER

The transformers shall be provided with an OFF-Load Tap Changer (OFF-LTC) of well reputed and of proven make as per technical requirement. The off circuit tap changer shall be of high quality and robust

in construction. It shall be located at a convenient position so that it can be

operated from ground level by a standing operator. The handle of OFF-LTC shall be provided with a locking arrangement, thus enabling the

OFF-LTC to be locked in position. Arrangement for indicating of tap position shall also be provided. It shall be suitable for local manual operations. The tap changer shall be capable of permitting parallel

operation with other transformer of the same type. When one unit is in parallel with another of same type as mentioned in clause No.3.12 under

normal condition, the tap changer shall not become out of step.

The OFF-LTC shall be capable of carrying rated MVA on all taps. The breaking capacity of the OFF-LTC shall be compatible with the highest system voltage and current based on maximum over loading permissible under IS:6600-1972 (150% of rated value). The voltage rating for each step shall be 2.5% on HV side. However, each step of OFF-LTC shall withstand voltage not less than 115% of rated step voltage. The rated through current of OFF-LTC at this voltage will not be less than 150% of rated current of HV winding at lowest tap.

4.12 FITTINGS

The following fittings shall be provided on the transformers:

- i) Conservator with isolating valves, oil filling hole with cap and drain valve. The conservator vessel shall be filled with constant oil pressure diaphragm oil sealing system.
- ii) Magnetic type oil level gauge (150 mm dia) with low oil level alarm contacts.
- iii) Prismatic/toughened glass oil level gauge.
- iv) Silica gel breather with oil seal and connecting pipe complete with first fill of activated silica gel or alumina mounted at a level of 1300 mm above ground level.
- v) A double float type Buchholz relay with isolating valve, bleeding



pipe and a testing cock, the test cock shall be suitable for a flexible (pipe connection for checking its operation). A 5 mm dia

Copper pipe shall be connected from the relay test cock to a valve located at a suitable height above ground level to facilitate

sampling of gas with the transformer in service. Interconnection

between gas collection box and relay shall also be; provided. The device shall be provided with two electrically independent ungrounded contacts, one for alarm on gas accumulation and the other for tripping on sudden oil surge. These contacts shall

be wired up to transformer marshaling box. The relay shall be provided with shut off valve on the conservator side as well as on the tank side.

- vi) Pressure relief devices (including pressure relief valve) and necessary air equalizer connection between this and the conservator with necessary alarm and trip contacts.
- vii) Air release plugs in the top cover.
- viii) Inspection cover, access holes with bolted covers for access to inner ends of bushing etc.
- ix) Winding temperature (hot spot) indicating device for local mounting complete in all respects. Winding temperature indicator shall have three sets of contacts to operate at different settings:
 - a) To provide winding temperature 'high alarm'
 - b) To provide temperature too high 'trip'
- x) Dial thermometer with pocket for oil temperature indicator with one set of alarm and one set of trip contacts and maximum reading pointer.
- xi) Lifting eyes or lugs for the top cover, core and coils and for the complete transformer.
- xii) Jacking pads
- xiii) Haulage lugs
- xiv) Protected type mercury/alcohol in glass thermometer and a pocket to house the same.
- xv) Top and bottom filter valves on diagonally opposite ends with pad locking arrangement on both valves.
- xvi) Top and bottom sampling valves.
- xvii) Drain valve with pad locking arrangement.
- xviii) Rating and connection diagram plate.
- xix) Two numbers tank earthing terminals with associated nuts and bolts for connections to purchaser's grounding strip.
- xx) Bi-directional flagged rollers with locking and bolting device.
- xxi) Marshalling Box (MB)
- xxii) Shut off valve on both sides of flexible pipe connections between radiator bank and transformer tank.
- xxiii) Cooling accessories:
 - a) Requisite number of radiators provided with:



- One shut off valve on top
 - One shut off valve at bottom
 - Air release device on top
 - Drain and sampling device at bottom
 - Lifting lugs
- b) Air release device and oil drain plug on oil pipe connectors.
- xxiv) Terminal marking plates for Current Transformer and Main transformer.
- a) Off-Load Tap Changer
- xxv) Oil Preservation equipment
- xxvi) Oil Temperature indicator

Note:- (i) The fittings listed above are indicative and any other fittings which are

generally required for satisfactory operation of the transformer are deemed to be included in the quoted price of the transformer.

(ii) The contacts of various devices required for alarm and trip shall be potential free and shall be adequately rated for continuous, making and breaking current duties as specified.

4.13 CONTROL CONNECTIONS AND INSTRUMENT AND WIRING TERMINAL,

BOARD AND FUSES

- i) Normally no fuses shall be used anywhere instead of fuses MCBs (both in AC&DC circuits) shall be used. Only in cases where a .MCB cannot replace a fuse due to system requirements, a HRC fuse can be accepted.
- ii) All wiring connections, terminal boards, fuses MCBs and links shall be suitable for tropical atmosphere. Any wiring liable to be in contact with oil shall have oil resisting insulation and the bare ends of stranded wire shall be sweated together to prevent seepage of oil along the wire'
- iii) Panel connections shall be neatly and squarely fixed to the panel. All instruments and panel wiring shall be run in PVC or non-rusting metal cleats of the compression type. All wiring to a panel shall be taken from suitable terminal board.
- iv) Where conduits are used, the runs shall be laid with suitable falls, and the lowest parts of the run shall be external to the boxes. All conduit runs shall be adequately drained and ventilated. Conduits shall not be run at or below ground level.
- v) When 400 Volt connections are taken through junction boxes or marshalling boxes, they shall be adequately screened and 400 volts Danger Notice must be affixed to the outside of the junction boxes or marshalling box. Proper colour code for Red, Yellow, Blue wires



- shall be followed.
- vi) All box wiring shall be in accordance with relevant IS. All wiring shall be of stranded copper (48 strands) of 1100 Volt grade and size not less than 2.5 Sq.mm.
 - vii) All wires on panels and all multi-core cables shall have ferrules, for easy identifications, which bear the same number at both ends, as indicated in the relevant drawing.
 - viii) At those points of interconnection between the wiring carried out by separate contractors, where a change of number can not be avoided double ferrules shall be provided on each wire. The change of numbering shall be shown on the appropriate diagram of the equipment.
 - ix) Stranded wires shall be terminated with tinned Ross Courtney terminals, claw washers or crimped tubular lugs. Separate washers shall be suited to the size of the wire terminated. Wiring shall, in general, be accommodated on the sides of the box and the wires for each circuit shall be separately grouped. Back of panel wiring shall be arranged so that access to the connecting items of relays and other apparatus is not impeded.
 - x) All circuits in which the voltage exceeds 125 volts, shall be kept physically separated from the remaining wiring. The function of each circuit shall be marked on the associated terminal boards.
 - xi) Where apparatus is mounted on panels, all metal cases shall be separately earthed by means of stranded (48 no) copper wire of strip having a cross section of not less than 2 sq.mm where strip is used, the joints shall be sweated. The copper wire shall have green coloured insulation for earth connections.
 - xii) All wiring diagram for control and relay panel shall preferably be drawn as viewed from the back and shall show the terminal boards arranged as in services.
 - xiii) Terminal block rows should be spaced adequately not less than 100 mm apart to permit convenient access to external cables and terminations.
 - xiv) Terminal blocks shall be placed with respect to the cable gland (at a minimum distance of 200 mm) as to permit satisfactory arrangement of multicore cable tails.
 - xv) Terminal blocks shall have pairs of terminals for incoming and outgoing wires. Insulating barriers shall be provided between adjacent connections. The height of the barriers and the spacing between terminals shall be such as to give adequate protection while allowing easy access to terminals. The terminals shall be adequately protected with insulating dust proof covers. No live metal shall be exposed at the back of the terminal board. CT terminals shall have shorting facilities. The terminals for CTs should have provision to insert banana plugs and with isolating links.
 - xvi) All interconnecting wiring, as per the final approved scheme



between accessories of transformer and marshalling box is included in the scope of this specification and shall be done by the Transformer supplier.

- xvii) The schematic diagram shall be drawn and fixed under a transparent propane sheet on the inner side of the marshalling box cover.
- xviii) To avoid condensation in the Marshalling Box, a space heater shall be provided with an MCB and thermostat.
- xix) Suitable 11W, CFL light shall be provided in the Marshalling Box at lightning purpose.

4.14 INSPECTION AND TESTING

- i) The contractor shall carry out a comprehensive inspection and testing programme during manufacture of the transformer. An indicative of inspection is given under clause no. 4.1. This is, however, not intended to form a comprehensive programme as it is contractor's responsibility to draw up and carry out such a programme duly approved by the purchaser.
- ii) The contractor shall carry out routine tests on the transformers.
- iii) The pre-shipment checks shall also be carried out by the contractor.
- iv) The requirements on site tests are as listed in the specifications.
- v) Certified test report and oscillograms shall be furnished to the Purchaser/Consultants for evaluation as per the schedule of distribution of documents. The contractor shall also evaluate the test results and rectify the defects in the equipment based on his and the purchaser's evaluations of the tests without any extra charges to the Purchaser Manufacturer's Test Certificates in respect of all associated auxiliary and ancillary equipment shall be furnished.
- vi) The bidder shall state in his proposal the testing facilities available at his works. In case full testing facilities are not available, the bidder shall state the method proposed to be adopted so as to ascertain the transformer characteristics corresponding to full capacity.

5.1 INSPECTION

- i) Tank and Conservator
 - a) Inspection of major weld.
 - b) Crack detection of major strength weld seams by dye penetration test.
 - c) Check correct dimensions between whets, demonstrate turning of wheels, through 90° and further dimensional check.
 - d) Leakage test of the conservator.



- ii) Core
 - a) Sample testing of core materials for checking specific loss properties, magnetization characteristics and thickness.
 - b) Check on the quality of varnish if used on the stampings.
 - c) Check on the amount of burrs.
 - d) Visual and dimensional check during assembly stage.
 - e) Check on completed cover for measurement of iron loss.
 - f) Visual and dimensional checks for straightness and roundness of core, thickness of limbs and suitability of clamps.
 - g) High voltage DC test (2 KV for one minute) between core and clamps.
- iii) Insulating Material
 - a) Sample check for physical properties of materials.
 - b) Check for dielectric strength
 - c) Check for the reaction of hot oil on insulating materials.
- iv) Winding
 - a) Sample check on winding conductor for mechanical and electrical conductivity.
 - b) Visual and dimensional checks on conductor for scratches, dent mark etc.
 - c) Sample check on insulating paper for PH value, electric strength.
 - d) Check for the bonding of the insulating paper with conductor.
 - e) Check for the reaction of hot oil and insulating paper.
 - f) Check and ensure that physical condition of all materials taken for windings is satisfactory and free of dust.
 - g) Check for absence of short circuit between parallel strands.
- v) Checks Before Drying Process
 - a) Check condition of insulation on the conductor and between the windings.
 - b) Check insulation distance between high voltage connections, between high voltage connection cables and earth and other live parts.
 - c) Check insulating distances between low voltage connections and earth and other parts.
- vi) Checks during drying process
 - a) Measurement and recording of temperature and drying time during vacuum treatment.
 - b) Check for completeness of drying.
- vii) Assembled Transformer
 - a) Check completed transformer against approved outline drawing, provision for all fittings, finish level etc.
 - b) Jacking test on the assembled transformer.
- viii) Oil

Oil sample taken from Power Transformers may be got inspected from NABL accredited lab for its conformance as per IS 1866. In addition to the above, the firm shall also submit a proof of purchase of oil as per IS 335.



- ix) Test reports for bought out items
The contractor shall submit the test reports for all bought out/sub contracted items for approval.
- Buchholz relay
 - Sudden pressure rise relay on Main Tank
 - Winding temperature indicators (for TX capacity 3.5 & 5.0 MVA)
 - Oil temperature indicators
 - Bushings
 - Bushing current transformers in neutral (if provided)
 - Marshalling box
 - Off load tap changer
 - Any other item required to complete the works
 - Porcelain, bushings, bushing current transformers, wherever provided, winding coolers, control devices, insulating oil and other associated equipment shall be tested by the contractor in accordance with relevant IS. If such equipment is; purchased by the contractor on a sub-contract, he shall have them tested to comply with these requirements.

5.2 FACTORY TEST

- All standards routine tests in accordance IS:2026 with dielectric tests corresponding as per latest amendments to IS:2026 shall be carried out.
- All auxiliary equipment shall be tested as per the relevant IS. Test certificates shall be submitted for bought out items.
- High voltage withstand test shall be performed on auxiliary equipment and wiring after complete assembly.
- Following additional routine tests shall also be carried out on each transformers:
 - Magnetic Circuit Test
 - Each core shall be tested for 1 minute at 2000 volt DC.
 - Oil leakage test on transformer

OIL LEAKAGE TEST ON TRANSFORMER.

5.2.1 Type test - Deleted in view of non standard rating

5.2.2 Routine Tests :

Transformer routine tests shall include tests stated in latest issue of IS:2026 (Part-I). These tests shall also include but shall not be limited to the following:-

- Measurement of winding DC resistance.
- Voltage ratio on each tapping and check of voltage vector relationship.
- Impedance voltage at all tapings.



- iv) Magnetic circuit test -
After routine tests, each core shall be tested for 1 minute at 2 KV DC between all bolts, side plates and structural steel work. Immediately prior to the dispatch of the transformer, the magnetic circuit shall be pressure tested for 1 minute at 2 KV A.C. between the core and the earth.
- v) Load losses
- vi) No load losses and no load current.
- vii) Absorption index i.e. insulation resistance for 15 seconds and 60 seconds (R60/R15) and polarization index i.e. Insulation Resistance for 10 minutes and one minute R10 mt/R1 mt.).
- viii) Induced over voltage withstand test.
- ix) Separate source voltage withstand test (applied potential).
- x) Measurement of power consumed by fans & oil-pumps.
- xi) Oil sample test as per IS 1866

Six (6) sets of certified test reports and oscillographs shall be submitted for evaluation prior to dispatch of the equipment. The contractor shall also evaluate the test results and shall correct any defect indicated by his and Purchaser's evaluation of the tests without charge to the Purchaser.

5.3 TANK TESTS

- 5.3.1 a) Oil leakage test:
The tank and oil filled compartments shall be tested for oil tightness completely filled with air or oil of viscosity not greater than that of insulating oil conforming to IS:335 at the ambient temperature and applying a pressure equal to the normal pressure plus 35 KN/m² measured at the base of the tank. The pressure shall be maintained for a period of not less than 12 hours for oil and one hour for air and during that time no leak shall occur.
- b) Vacuum test
One transformer tank of each size shall be subjected to the specified vacuum as in Cl. 15.1.2. The tanks designed for full vacuum shall be tested at an internal pressure of 3.33 KN per m² (25 mm of Hg.) for one hour. The permanent deflection of flat plates, after the vacuum has been released shall not exceed the value specified below without affecting the performance of the transformer: -

Horizontal length of flat plate in mm	Permanent Deflection in mm
Up to & including 750	5
751 to 1250	6.5
1251 to 1750	8



1751 to 2000	9.5
2001 to 2250	11
2251 To 2500	12.5
2501 To 3000	16
Above 3000	19

The permanent deflection of flat plates after the vacuum has been released shall not exceed the value specified in C.B.I.P. Manual on Transformers (Revised 1999) without affecting the performance of the transformers

c) PRESSURE TEST:

One transformer tank of each size shall be subjected to a pressure corresponding to twice the normal head of oil or to the normal pressure plus 35 KN per m² (5 Lb. Per sq. inch.) whichever is lower measured at the base of the tank and will be maintained for one hour. The permanent deflection of flat plates after the excess pressure has been released shall not exceed the figure specified above.

5.4 PRESHIPMENT CHECK AT MANUFACTURS WORKS

- i) Check for proper packing and preservation of accessories like radiators, bushings, explosions vent, dehydrating breather, rollers, buchholz relay, control cubicle connecting pipes and conservator etc.
- ii) Check for proper provision of bracing to arrest the movement of core and winding assembly inside the tank.
- iii) Gas tightness test to conform tightness.

5.5 INSPECTION AND TESTING AT SITE:

The contractor shall carry out detailed inspection covering areas right from the receipt of material up to commissioning stage. An indicative program of inspection as envisaged by the engineer is given blow. This is however not intended to form a comprehensive program as it is contract's responsibility to draw up and carry out such a program.

5.5.1 Receipt and Storage checks

- i) Check and record condition of each package visible parts of the transformers etc. for any damage.
- ii) Check and record the gas pressure in the transformer tank as well as in the gas cylinder.
- iii) Visual check of core and coils before filling up with oil and also check condition of core and winding in general.

5.5.2 Installation checks

- i) Inspection and performance testing of accessories like tap changers etc.
- ii) Check choking of the tubes of heat exchangers.



- iii) Test on oil samples taken from main tank top and bottom and cooling system. Samples should be taken only after the oil has been allowed to settle for 24 hours.
- iv) Check the whole assembly for tightness, general appearance etc.
- v) Oil leakage tests.

5.5.3 Pre-commissioning tests

After the transformer is installed, the following pre-commissioning tests and checks shall be done before putting the transformer in service.

- i) Dry out test
- ii) Megger test
- iii) DC Resistance measurement of windings
- iv) Ratio test on all taps
- v) Phase relationship test (Vector grouping test)
- vi) Buchholz relay alarm & surge operation test
- vii) Low oil level (in conservator) alarm
- viii) Temperature indicators
- ix) Marshalling kiosk
- x) Protective relays
- xi) Magnetizing current

5.5.4 The following additional checks shall be made:

- i) All oil valves are in correct position closed or opened as required.
- ii) All air pockets are cleared
- iii) Thermometer pockets are filled with oil
- iv) Oil is at correct level in the bushing, conservator, diverter switch & tank etc.
- v) Earthing connections are made
- vi) Colour of Silica gel is blue
- vii) Bushing arcing horn is set correctly and gap distance is recorded.
- viii) CT polarity and ratio is correct.

5.6 PERFORMANCE

The performance of the transformer shall be measure on the following aspects:

- i) The transformer shall be capable of being operated without danger on any tapping at the rated KVA with voltage variation $\pm 10\%$ corresponding to the voltage of the tapping.
- ii) The maximum flux density in any part of the cores and yokes at normal voltage and frequency shall be such that the flux density on any taps position with $+ 12.5\%$ voltage variations and -5% frequency variations, shall not exceed 1.9 wb/m^2 .
- iii) Ratio interference and Noise Level
- iv) The transformer shall be designed with particular attention to the suppression of third and fifth harmonics so as to minimize interference with communication circuits.

5.7 FAULT CONDITIONS

- (a) The transformer shall be capable of withstanding for two (2) seconds without damages any external short circuit to earth.
- (b) Transformers shall be capable of withstanding thermal and



mechanical stresses conveyed by symmetrical or asymmetrical faults on any winding.

(c) Transformers shall accept, without injurious heating, combined

voltage and frequency fluctuation which produce the 125% over

fluxing condition for one minute.

5.8 TEST WAIVAL, PROCEDURE AND COSTS

- i) The purchaser, at his option, may waive impulse tests provided type test reports of impulse tests carried out on essentially identical units in their factory in India are furnished by the manufacturer.
- ii) No load losses and exciting current shall be measured at rated voltage, rated frequency and at 90% and 110% of rated voltage, both before and after the lightning impulse tests.
- iii) The method of test loading shall be described in the test report for determination of both average and hottest spot temperature. Where the winding temperature equipment is specified, data shall also be included for calibration of hottest spot temperature indicator.
- iv) Resistance of each winding of each phase shall be measured at principal and at all the taps and corrected to 75°C.
- v) Impedance voltage shall be measured at principal and at all taps.
- vi) No load loss measurement at 415 Volt.
- vii) Certified test report and oscillograms shall be furnished to the Purchaser/Consultants for evaluation as per the schedule of distribution of documents. The Contractor shall also evaluate the test results and rectify the defects in the equipment based on his and the purchaser's evaluations of the tests without any extra charges to the: Purchaser. Manufacturer's test certificates in respect of all associated auxiliary and ancillary equipment shall be furnished.
- viii) The bidder shall state in his proposal the testing facilities available at his works. In case full testing facilities are not available, the bidder shall state the method proposed to be adopted so as to ascertain the transformer characteristics corresponding to full capacity testing.

5.9 WITNESSING OF TESTS AND EXCESSIVE LOSSES

- i) The Purchaser and/or his representative reserve the right to witness any or all tests, or to accord waiver at its sole discretion.
- ii) The purchaser reserves the right to reject the Transformer if losses exceed the declared losses beyond tolerance limits as per IS or if temperature rise of oil and winding exceed the values specified elsewhere. (See clause 3.5.0)

6.0 REJECTION



The purchaser may reject any transformer if during tests or service any of the following conditions arise:

- iii) Impedance value exceeds the guaranteed value by $\pm 10\%$ or more.
- iv) The difference in impedance values of any two phases during single phase short circuit impedance test exceeds 2% of the average value guaranteed by the vendor.
- v) Oil or winding temperature rise exceeds the specified value.
- vi) Transformer fails on impulse test
- vii) Transformer fails on Power Frequency Voltage withstand test
- viii) Transformer is proved to have been manufactured not in accordance with the agreed specification.

7.0 SPARES: - Deleted

7.9 Pressure Relief valve

8.0 INSTRUCTIONS MANUAL

8.1 Eight sets of the instruction manuals shall be supplied at least four (4) weeks

before the actual dispatch of equipment. The manuals shall be in bound volumes and shall contain all the drawings and information required for erection, operation and maintenance of the transformer. The manuals shall include amongst other the following particulars:

- a) Marked erection prints identifying the components parts of the transformer as dispatched with assembly drawings.
- b) Detailed dimensions assembly and description of all auxiliaries.
- c) Detailed views of the core and winding assembly, winding connections & tapplings, tap changer construction etc. These drawings are required for carrying out overhauling operation at site.
- d) Salient technical particulars of the transformers.
- e) Copies of all final approved drawing.
- f) Detailed O & M instructions with periodical check lists and performance etc.

8.2 COMPLETENESS OF EQUIPMENT

- i) All fittings and accessories, which may not be specifically mentioned in the specification but which are necessary for the satisfactory operation of the plant, shall be deemed to be included in the specification and shall be furnished by the contractor without extra charges. The equipment shall be complete in all details, whether such details are mentioned in the specification or not, without any financial liability to the Purchaser under any circumstances.
- ii) All deviations from this specification shall be separately listed under the requisite schedules, in the absence of which it will be presumed that all the provision of the specification are complied with by the bidder.

9.0 TOOLS & TACKLES

All the necessary tools and tackles required for normal operation & maintenance shall be supplied by the contractor.



10.0 COMMISSIONING

The equipment shall be commissioned as per CBIP manual, IS 10028 and manufacturer's recommendations. All the as built drawings/manuals shall be pre-requisite for commissioning of Transformer. The authorized technical representative of successful bidder shall remain at site at the time of commission of Power Transformer (including taking sample of Transformer Oil by Nigam before commission of Transformer.).

11.0 STAGE INSPECTION:

The purchaser reserves the right for stage inspection of one or all the transformers during the course of manufacture to ensure that the internal details are in accordance with the data / information supplied / G.T.P.'s as per Contract/P.O.

12 ACCESSORIES AND FITTINGS:

Each transformer shall be provided with the following in accordance with details to the extent these are specified in IS 2026-1977/relevant IEC: -

- a) Inspection cover with lifting lugs
- b) Rating Plate
- c) Diagram Plate
- d) Two earthing terminals
- e) Lifting Lugs
- f) Jacking Lugs
- g) Conservator Tank with drain plug and oil filling hole
- h) Dehydrating Breather
- i) 1. Thermometer (dial type) with one pair of contacts for top oil over temperature alarm.
2. Thermometer (dial Type) with two pairs of contacts for winding over temperature Alarm & Trip & for On & OFF Motor Blower / Cooling fans.
- j) Thermometer Pockets
- k) One No. Magnetic oil level gauge mounted on conservator tank for main transformer tank with 3 positions marked as follow: Min -5° C, 30° C and Maximum 98° C for main tank.
- l) One No. Plain Sight Glass Oil Level Gauge for OLTC Tank with Min.& Max. Oil Level Markings.
- m) Oil filling hole with cap.
- n) Air release device.
- o) Pressure relief device
- p) i. Gas & oil actuated relay with alarm and trip contacts and shut off valves on conservator as well as main tank side for Main tank.
ii -do- with one pair of trip contacts for OLTC tank also
- q) Filter valves (lower valve to be used as a drain valve)
- r) Terminal marking plate
- s) Marshalling box
- t) Necessary oil for the first filling
- u) Bottom mounting channel
- v) Flanged bi-directional rollers (four Nos.)



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BIJLI VITRAN NIGAM



- x) Studs & pulling eyes in both directions.
13. SPECIAL TOOLS:

Any special tools required for erection and for maintenance work shall be provided along with each transformer.

This issues with the approval of Common Specifications Committee.

General Manager/P&D
Cum-Member Secretary CSC
UHBVN & DHBVN



ANNEXURE "A"

SCHEDULE OF GUARANTEED AND OTHER TECHNICAL PARTICULARS.

NOTE: I For the purpose of this specification the rated load shall be taken as 3.5 & 5.0 MVA.

II. Particulars under guaranteed shall be clearly marked.

1. Name of the Manufacturer:
2. Normal continuous rating with ONAN cooling.
3. Normal ratio of transformer.
4. Phase Connections:
 - a. HV winding.
 - b. LV Winding.
 - c. Vector Group Reference
5. Max. Temperature rise of oil over ambient air Temperature of 50⁰C.
6. Max Hot spot Temperature under normal full load conditions with Max. Yearly weighted ambient temperature of 32⁰C.
7. Max. Temperature rise of winding by resistance over a Max. Ambient air temperature of 50⁰C.
8. Temperature Gradient between oil and winding.
9. Calculated time constant of cooling system.
10. No Load loss at normal ratio, rated voltage and rated frequency without any tolerance.
10. Load loss at 75⁰C
11. a) Auxiliary Losses.
b) No. of cooling fans
- 13 Impedance voltage at normal current and voltage at 75⁰C average winding temperature at Tap No. 3.
14. Reactance voltage drop expressed as percent of rated voltage.
15. Efficiency at normal ratio, rated voltage, rated frequency and 75⁰C average winding temperature at:
 - a. Rated Load
 - b. ¾ Rated Load
 - c. ½ Rated Load
- 16 Regulation at rated load and at:
 - a. Unity Power Factor.
 - b. 0.8 Power Factor (Lagging)
- 17 Max Flux density at normal Voltage and frequency in:
 - a. CORE.
 - b. YOKE
- 18 Limit for over fluxing
- 19 Max Current Density at Continuous Maximum Rating in:
 - a. HV Winding.
 - b. LV Winding



- 20 Magnetizing current and its power factor at normal ratio and frequency.
- 21 CORE:
 - a) Whether core laminations are of cold rolled grain oriented silicon steel
 - b) Insulator material of core laminations
 - c) Detail of oil duct in core (Whether in or at right angles to the plane of core laminations).
- 22 Type of Winding
 - a. HV Side winding
 - b. LV Side winding
- 23 Type of Insulation
 - a. HV side winding
 - b. LV side winding
 - c. Between HV & LV Windings
- 24 Rated short duration power frequency withstand test voltage on:
 - a HV Winding
 - b LV Winding
 - c Neutral and of LV winding
- 25 Rated lightning impulse with stand test voltage with 1.2/50 micro-second wave on
 - a. HV Winding
 - b. LV Winding
- 26 Voltage to earth for which the star point shall be insulated
- 27 Details of special arrangement made to improve stress conditions.
- 28 Details of Bushings
 - a. HV side
 - b. LV side
 - c. Neutral Side
 - i. Type & standard reference.
 - ii. One minute dry with stand power frequency voltage kV (rms)
 - iii. One-minute wet withstand Power frequency voltage kV (rms)
 - iv. Impulse with stand test voltage with 1.2/50 micro sec. Wave kV (Peak)
 - v. Creepage distance in air
 - vi. Maximum current rating of the Bushing both HV & LV
 - vii. Recommended gap setting
 - viii. Assembled weight of bushing(Kg)
- 30 Type & Details of winding Temperature indicator.
- 31 Type & Details of Transformer oil Temperature Indicator
- 32 Type & Details of main Buchholz relay
- 33 Weight of copper to be used in the complete Transformer
- 34
 - a) Weight of core (Kg)
 - b) Weight of Winding (Kg)
- 35 Weight of Oil in Transformer (Kg)
- 36 Weight of Transformer complete with oil and accessories (Kg)
- 37 Weight of complete Transformer arranged for transport or the heaviest packet if broken down (Kg)
- 38 Dimensions of transformer



उत्तर दक्षिण हरियाणा बिजली वितरण निगम

UTTAR DAKSHIN HARYANA BILII VITRAN NIGAM



- a) Over all length
 - b) Over all breadth
 - c) Max. height to top of conservator.
- 39 Volume of conservator tank between the highest & lowest indicated levels.
- 40 Free space required at top for removal of bushings.
- 41 List of reference of similar transformer already in service
- 42 Deviation from this technical Specification
- 43 No. of years for which the design offered has been in commercial use.
- 44 Noise level when energized at normal voltage and normal frequency at no load.
- 45 Shipping details: -
- i) Parts detached for transport
 - ii) Weight of heaviest package (Kg)
 - iii) Weight of other heavy packages (Kg)
 - iv) Dimensions of largest package
- a. Length in mm.
 - b. Breadth in mm.
 - c. Height in mm.

NOTE: The transformer oil shall comply in all respects with the requirement of IS:335.



SCHEDULE OF DELIVERIES

Sr.No.	Name of item / Specification	Name of consignee	Delivery Schedule
	Three phase, 50 Hz, 33/3.3 KV Step down, outdoor ONAN Power Transformers of following capacity complete with all accessories/fittings and conforming to Nigam's Technical Specification No. CSC-78/R-I/DH/UH/P&D/2015-16 (with amendment) and relevant ISS with latest amendments. iii) 3.5 MVA iv) 5MVA	Any Where in Haryana	To be decided/approved by CE/MM while issuing NIT The 1 st lot of power transformers (50% of ordered qty.) shall be delivered in the stores within 45 days after the date of commencement of delivery schedule (i.e. from the day of approval of drawing/QAP) or within 56 th day from the date of issue of LOI whichever is earlier and the balance supply shall be made 45 days thereafter.

Note:-

1. The delivery schedule as mentioned above shall be read in conjunction with the clauses of type test and drawing mentioned in schedule – D (Part- II) , wherever applicable.
2. The material should be supplied to the consignees within 15 days of issue of dispatch authorization or within contractual delivery period whichever expires earlier. After this period, the firm will supply the material at its own risk and responsibility. The acceptances of such material with or without re-inspection upto the scheduled delivery period shall be at the sole discretion of Chief Engineer/MM, UHBVN/ DHBVN. Thereafter, Nigam will have a right to refuse or accept such delayed material on the applicable rates, terms & conditions.

Name & Full Address of Tenderer

Place:

Date



ANNEXURE – IV

Format for raising Inspection Call by the Vendor / Supplier

From,

Name of the Firm with Complete Address

To,

Concerned Department (CE/MM)
Address

Subject:-

Inspection Call for _____ No [Items] as per Work Order / Purchase Order No -
_____ dt. _____

Sir,

This is with reference to subject cited Work Order / Purchase Order. We would like to inform that below mentioned material is ready for Inspection:

Sr No	Item Description	Quantity as per WO/PO	Quantity already Inspected & supplied	Quantity offered for Inspection	Balance Quantity	Contract Delivery Period

It is requested to kindly depute an officer for inspection of the materials. The name and contact details of the person responsible for getting the inspection conducted is:-

_____ [Contact Details of Person]

_____ [Date and Place for Inspection]

Signature
Name
Designation
Company Seal

Note:-



Annexure- V

(TO BE FILLED IN AND SIGNED BY THE TENDERER)

SCHEDULE OF DEVIATIONS

We/I have carefully gone through the Technical Specification and the general conditions of contract and we/I have satisfied ourselves/myself and hereby confirm that our/my offer strictly conforms to the requirements of the Technical Specifications and general conditions of contract except for the deviations which are given below:-

Sr. No.	Description	Stipulation in specification	Deviations offered	Remarks.
A.	Commercial Terms:			
	Clause No.			
B.	Technical Specifications:			
	Clause No.			

(Please use more Sheets, if required).

Dated:

Place:

Designation

Name

Status

Whether Authorized Signatory of the
Tendering Company

Name of the Tendering Company



BANK GUARANTEE PROFORMA

This agreement is made this _____ day of _____ (a) between _____ (b) a company registered under banking Companies Act/ or any other Act to be specified, having its registered office at _____ (c) called the guarantor which expressions shall unless repugnant to the context or meaning thereof, include its successors and assigns of the first part M/s _____ (d) a Company/firm registered under the companies Act 1956/ partnership firm/ proprietorship firm having its registered office at _____ (e) (hereinafter called the suppliers which expressions shall unless repugnant to the context or meaning thereof, include its successors and assigns) of the second part at the DHBVN, a body corporate under company Act 1956 (hereinafter called the purchaser, which expressions shall unless repugnant to the context or meaning thereof, include its successors and assigns) of the third part.

Whereas the supplier has inter alia agreed with the purchaser to supply the purchaser _____ (f) on the terms and conditions contained in the contract No. _____ dated ____ (g) placed by the purchaser on the suppliers and accepted by the suppliers.

And whereas under clause _____ (h) of the said contract, the supplier is required to furnish bank guarantee for a sum of Rs. _____ (i) being the _____ (j) value of all the consignments of the above material on account of retention money, which but for this guarantee value be withheld by the purchaser till such time that the material is received in good condition and in accordance with the specification of the same to guarantee the payment of the retention money on bill submitted against supply of material/ repair of equipment on order from time to time up to a maximum amount of the sum Rs. _____ (k).

And whereas at the request of the supplier the purchaser has agreed not to retain _____ (l) of the contract price of all the consignments and in lieu thereof to accept Bank Guarantee from the Guarantor for the due performance of the said contract by the said supplier on the terms and conditions herein contained. Now this deed, therefore, witness that it is hereby agreed by and between the parties hereto as follows:-

The Guarantor hereby guarantee to the purchaser the quality, workmanship and design of all the consignments of _____ (m) in accordance with the prescribed specifications and the terms of the said contract and agree to indemnify and keep indemnified the said purchaser to the extent of Rs. _____ (n) in the aggregate against all losses, damages, costs, charges and expenses which may be suffered or incurred by the purchaser on account of any defect in the materials supplied or on account of any breach on the part of said supplier or any of the terms and conditions of the said contract in the supply/ repair of the consignments. The guarantor further agrees that the said purchaser shall be the sole judge whether the supply/ repair have been made according to the prescribed specifications, design and workmanship as laid down in the said contract and the supplier had committed breach or breaches of any of the terms and conditions of the said contract and the extent of loss/damage, cost, charges, loss or expenses suffered or incurred by the purchaser on account thereof and the guarantor shall immediately on receipt of any claim or claims from the said purchaser pay to the extent of the amounts specified above "without demur or objection".

The guarantor further agrees that this guarantee shall remain in full force and effect for _____ (o) months from the date of dispatch of material by the said supplier under the said contract i.e. upto _____ (p)

The guarantor also agrees and undertakes not to revoke this guarantee before the



उत्तर दक्षिण हरियाणा बिजली वितरण निगम

UTTAR DAKSHIN HARYANA BILJI VITRAN NIGAM



same is discharged as aforesaid except with the previous consent of the said purchaser in writing.

The guarantor hereby further agrees that the said purchaser shall have the full liberty without effecting in any manner the obligation of the guarantor hereunder with or without the consent of the guarantor to vary any of the terms of the said contract or to extend time for performance of the said contract by the supplier from time to time or to postpone for any time or from time to time any of the power exercisable by the purchaser against the said supplier and either to forbear or enforce any of the terms or conditions relating to the said contract and the guarantor shall not be relieved from his liability by reason of any variation or any extension being granted to the said supplier or for any forbearance, act or omission on the part of the said supplier or any indulgence by the said purchaser to the said supplier or any such matter or thing whatsoever which under the law relating to sureties would but for this provision have effect of relieving the guarantor. Nor shall it be necessary for the said purchaser to sue the said supplier before suing the said guarantor for the amount/damages due under the deed of guarantee.

In witness whereof the parties hereto put their respective hands on the day and the year first above mentioned.

1. Witness

2. Witness

Signature of the Guarantor

1. Witness

2. Witness

Signature of the Supplier

1. Witness

2. Witness

Signature of the CE/MM

For & on behalf of the DHBVN

Note:—

1. Date of execution of Bank Guarantee.
2. Name of Bank
3. Complete address of the Bank.
4. Name of the supplier
5. Permanent address of the firm
6. Quantity and description of material
7. PO No. and date
8. Payment clause
9. Amount of Bank Guarantee
10. %age of the contract price
11. Amount of Bank Guarantee should be both in figure and words
12. Name of the material
13. Bank guarantee amount
14. Number of months
15. Date of validity



Format of Affidavit for last completed Purchase Order

I _____ Son of Shri _____ resident of _____ solemnly affirm and declare that I am holding the position as _____ the M/s _____ and I further hereby declare that.

1. Our last supply to any Govt. Power Utility in India is of _____ Power Transformers of rating _____ to _____ (Name of the Power Utility) against P.O. No. _____ dated _____ and we have supplied more than 50% of ordered quantity within delivery schedule (copy of P.O. along with copy of receipted challan enclosed)

Deponent

Verification

I, the above said deponent solemnly affirm and declare that the above said statement is true and correct to the best of my knowledge and belief and nothing has been concealed therein.

Deponent _____

Date:-

NIT No. _____

Enquiry No. _____

Attested by Notary Public



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BIJLI VITRAN NIGAM



Annexure- VIII

TO BE SUBMITTED ON FIRMS LETTER HEAD

DULY ATTESTED BY CHARTERED ACCOUNTANT

The firm M/s _____ has supplied following quantity of

material to state/Central Govt. organization during last 5 years.

Sr. no.	Financial year	Name of the item	Quantity billed	Total value of items	bill of	Remarks
1.						
2.						
3.						
4.						
5.						

(The above information should be supported by documentary evidence)



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BILJI VITRAN NIGAM



Annexure- IX

Undertaking

From

To

The Chief Engineer/MM,
DHBVN, Hisar

Subject;- Undertaking in respect of Tender Enquiry no. QD- for the procurement of 3.5 & 5 MVA, 33/3.3 KV Power Transformer.

We hereby confirm our unconditional acceptance of all the terms and conditions mentioned in the tender documents against your tender enquiry no. QD- _____ for the procurement of 3.5 & 5 MVA,33/3.3 KV Power Transformer. The material shall be supplied strictly as per technical specification of the Nigam/relevant ISS without any deviation.

(Authorized Signatory of the firm)



Annexure– X

AFFIDAVIT FOR NON BLACKLISTING

(On NJSP)

I, _____ Director of M/S
_____ with
Headquarter at _____ being
their authorized signatory, do hereby solemnly affirm and declare that M/S ____
_____ is not blacklisted by any State/Central
Govt. or any of its agencies. I understand that if upon acceptance of our offer dated
_____ against DHBVN/UHBVN tender enquiry No. _____ for supply of
_____ any P.O. is placed upon us, the same is liable
to be cancelled if this declaration is found wrong at any subsequent time and further I
understand to compensate the UHBVN, for the consequences arising out of wrong
declaration.

Attested by Notary Public



उत्तर दक्षिण हरियाणा बिजली वितरण निगम
UTTAR DAKSHIN HARYANA BIJLI VITRAN NIGAM



Annexure-XI

Price Schedule as provided in the Electronic tender at website

Sr. No.	Description of Item	NIT quantity	Place of Billing (Haryana/ Out of Haryana)	Quantity Offered	Ex-work Price (Rs./Unit)	Excise Duty (%)	VAT/CST (%)	Freight and Insurance Charges (Rs/Unit)	Any Other duties or taxes (Rs./Unit)	Discount (Rs./Unit)	Landed Cost Formula